

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month August, 2023		Day : Wednesday		Date : 23.08.23											
Probable Maximum Demand : 14600 MW		Probable Maximum Generation : 15135 MW													
Water Level of Kaptai Lake at 06:00 AM		Yesterday = 102.81 ft		Today = 102.62 ft											
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Dated/ Present Capacity (MW)	22.08.23 (Yesterday)		23.08.23 (Today)		Rule Curve = 95.72 ft		22.08.23 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/Oil/Water Limitation MW		Machines shut down (MW)		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening							
(A) Plants in operation:															
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260		Under project work		
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	120	120	150	150						
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	170	180	180	180						
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0						
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	12	0	12	12	108			Gas Shortage		
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105			Gas Shortage		
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0						
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	333	336	330	330						
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450						
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115		Under Overhauling		
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	406	413	380	400						
11	Siddhirganj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	98	193	100	200	17			Gas Shortage		
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	317	310	330	330						
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0		115		Under maint.		
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	30	55	15	55						
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	66	50	64	102						
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	17	19	19	19						
17	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	44	38	40	40						
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33						
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	24	33	33	33						
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	25	8	25						
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	35	88	35	88						
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	82	98	48	100						
23	Kamalaghat 54 MW PP (Barco Energy)	HFO (IPP)	3x18.69	54	54	17	35	17	35						
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	258	130	130	198						
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	89	133	70	135						
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	0	0						
27	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	5	55	35	55						
28	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	35	35	35						
29	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	71	71	53	70						
30	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	54	108	54	108						
31	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	16	0	35	0						
32	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	17	17	17						
33	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	62	32	70	70						
34	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	68	8	74	74						
35	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	30	35	17	51						
36	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	8	23	12	55						
Dhaka Zone Total			5904	5722	2975	3123	2846	3450	230	490					
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	202	200	200	200						
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	116	117	120	120		180		Under maint.		
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0						
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0						
40	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	8	8	25						
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	13	0	20	0						
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	39	6	47						
43	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	51	51	51	51						
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150		Under maint.		
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	190	202	225	225						
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	66	287	66	300						
47	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	12	25	25						
48	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	0	0	0						
49	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	24	75	34	75						
50	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	10	10	10	10						
*	Malancha, Clp EPZ (United)	Gas	5x8.73+3x9.34			7	25	5	25						
51	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	12	0	12						
52	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	17						
53	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	55	55	55	55						
54	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	25	12	25	25						
55	Juldah 100 MW Unit-1 (Acom)	HFO (QRRP)	8x13.45	100	100	25	12	35	35						
56	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	34	51	34	51						
57	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	17	17	17	143						
	SS Power Unit-1	Coal (IPP)				0	0	0	0						
	Matarbari 2*600 MW (CPGCL)	Coal				299	346	390	390				Test run		
	Cox's Bazar Wind PP	(Wind) (IPP)				7	1	10	10						
Chattogram Zone Total			2605	2545	1201	1549	1358	1841	0	330					
58	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	0	0	0	0	45			Gas Shortage		
59	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	169	209	180	190						
60	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	240	250	250	250	110			Gas Shortage		
61	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	270	280	300	300	80			Gas Shortage		
62	Ashuganj 420 MW CCPP(East)	Gas (APSCL)	1x284+1x116	400	400	280	250	300	300	150			Gas Shortage		
63	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	0	0	0	0	195			Gas Shortage		
64	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51						
65	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	25	28	5	30						
66	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	30	47	47	47						
67	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0		163		Under maint.		
68	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	51	86	51	85						
69	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	16	16	16	16						
70	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	10	10	11	11						
71	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	25	25	25	25						
72	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	43	43	43	43						
73	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	20	20	20						
74	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	34	70	106	106						
75	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	18	28	9	28						
76	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17						
77	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	72	115	72	115						
**	Import (Tirupura)	India		160	160	136	132	146	163						
Cumilla Zone Total			2904	2896	1507	1677	1649	1797	580	163					
78	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	35	58	32	80	144			Gas Shortage		
79	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	16	16	16	16						
80	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	28	84	24	85						
81	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	114	67	115	165						
82	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0						
83	Sulakshai 50 MW Solar PP	Solar (IPP)	1x50	50	50	24	0	50	0						
84	Tangail 22 MW PP(PGCL)	HFO (IPP)	4x6.7	22	22	6	6	6	6						
Mymensingh Zone Total			622	614	224	231	245	352	144	0					

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	22.08.23 (Yesterday)		23.08.23 (Today)		22.08.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	Machines shut down (MW)			
85	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43	27	GT-1 Under maint.	
86	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	40	40	40	40	50	GT-4 Under maint.	
87	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	46	50	50	50			
88	Kushiera 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	112	80	112	112	54	ST Under maint.	
89	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	3	5	5			
90	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	61	57	60	60			
91	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0	330	Under maint.	
92	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	75	84	86	86			
93	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	115	115	113	113			
94	Sylhet 20 MW GTTP	Gas (PDB)	1x 20	20	20	17	17	17	17			
95	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10			
96	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	24	24	24	24			
97	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	280	290	300	300			
98	Bibiyana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	367	367	350	370			
99	Bibiyana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	260	250	350	350			
100	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0	100	Under project work	
101	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.4+5*2	50	50	44	47	42	42			
Sylhet Zone Total					2472	2427	1505	1477	1602	1622	0	561
102	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0			
103	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0	410	Gas Shortage	
104	Fairdipor 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	22	0	40			
105	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	19	52	40	52			
106	Khulna 225 MW CAPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0			
107	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	36	53	17	17			
108	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	15	15	15	15			
109	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	65	0	100	0			
110	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	16	16	16	16			
111	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	8	8	8			
112	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	401	573	400	400			
113	Khulna 330 MW CAPP (GT)	Gas/HSD (BFD)	1x220	220	220	182	313	120	120			
**	Bheramara (HVDC)	India		1000	1000	914	797	909	909			
Khulna Zone Total					3125	3121	1648	1849	1625	1577	410	0
114	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	48	16	16	110			
115	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	23	30	22	30			
116	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	130	126	130	132			
117	Payra 1320 MW TTP	Coal (BCPCL)	2x622	1244	1244	1220	1220	1220	1220			
118	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	35	150	35	150			
119	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	0	0	0	0	307	Coal Shortage	
120	Bhola 220MW CAPP (Nutan Bidyt BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	221	215	220	220			
Barishal Zone Total					2265	2265	1677	1757	1643	1862	307	0
121	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71	Gas Shortage	
122	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100	Under maint.	
123	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	14	28	0	35			
124	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0			
125	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	18	0	20			
126	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	45	91	50	92			
127	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	40	39	30	40			
128	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	0	0			
129	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	24	24	0	24			
130	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210	Gas Shortage	
131	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220	Gas Shortage	
132	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	206	207	215	200			
133	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	414	360	350	414			
134	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	0	0	0	0	0			
135	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8			
136	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	8	8	25			
137	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	35	55	35	55			
138	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6*18.55	113	113	35	51	35	50			
139	Amnura 50 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	0	0	0	0			
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	3	0	6	0			
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	1312	1360	1300	1360			
Rajshahi Zone Total					3675	3631	2144	2249	2037	2323	501	100
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Coal Shortage	
142	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Under Overhauling	
143	Barapukuria 275 MW TTP Unit-3	Coal (PDB)	1 x 274	274	274	220	210	180	180	64	Coal Shortage	
144	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	48	48	35	56			
146	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
147	Majma. Talsia 9 MW Solar PP (Syma Power)	Solar (IPP)	1 x 9	9	9	3	0	8	0			
148	Thakurgaon 119MW PP (Energypac)	HFO (IPP)	6*20	119	115	0	74	0	75			
149	Lalmohini 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	6	0	30	0			
150	Teesa Solar Limited	Solar (IPP)	1 x 200	200	200	52	0	130	0			
Rangpur Zone Total					1030	950	329	332	383	311	149	85
Sub-total: Plants in operation					24602	24171	13210.0	14244	13388	15135	2321	1729
(B) Plants under long term maintenance/ contract expired												
151	Jamailpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			
152	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			
153	Bosilia 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			
154	Ashugani 55 MW PP (Precision)	Gas (RPP)	15*4	55	0	0	0	0	0			
Sub-Total: Plants under long term maintenance/ contract expired					309	0	0	0	0	0	0	0
Gross Total					24911	24171	13210	14244	13388	15135	2321	1729
(C) Actual data of 22.08.23 (Yesterday) Tuesday :												
01.	Max. Demand at eve. peak (Generation end)	:	14513 MW, at =	21:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	13784 MW, at =	21:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	14244 MW, at =	21:00 hrs	Dhaka	4827	4827	0	Mymensingh	1214	997	217
04.	Minimum Generation (Generation end)	:	11931 MW, at =	7:00 hrs	Chattogram	1220	1220	0	Sylhet	558	543	15
05.	Day-peak Generation (Generation end)	:	13210 MW, at =	12:00 hrs	Khulna	1768	1768	0	Barishal	415	415	0
06.	Evening-peak Generation (Generation end)	:	14244 MW, at =	21:00 hrs	Rajshahi	1575	1575	0	Rangpur	879	879	0
07.	Evening Peak Load-shed (Sub-station end)	:	257 MW, at =	21:00 hrs	Cumilla	1329	1304	25				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	11048 MW, at =	5:00 hrs					Total	13784	13527	257
09.	Generation shortfall at evening peak due to :	:			13.	Fuel cost :	(a) Gas = 160794965 Taka (b) Oil = 589488814 Taka	(c) Coal = 670335680 Taka Total = 1420619458 Taka				
a)	Gas/LF limitation	:	2172 MW									
b)	Coal supply Limitation	:	149 MW									
c)	Low water level in Kaptai lake	:	0 MW									
d)	Plants under shut down/ maintenance	:	1729 MW									
10.	Total Energy (Generation + India Import)	:	310.79 MMWh		14.	Maximum Temperature in Dhaka was :	32.5° C					
	By Gas = 145.711 MKWH	By Oil =	49.143 MKWH		15.	Export through East-West interconnections :						
	By Coal = 85.341 MKWH	By Hydro =	4.833 MKWH			At evening peak-hour	:	13210 MW, at	21:00 hrs			
	By Solar= 1.376 MKWH					Maximum	:	590 MW, at	21:00 hrs			
						Energy	:	0 MKWh				
11.	Total Gas Supplied	:	1141.69 MMCFD									
(D) Forecast of 23.08.23 (Today) Wednesday :												
01.	Maximum Demand	:	14600 MW (Generation end)		04.	Maximum Load-shed	:	0 MW	At evening peak (Sub-station end)			
02.	Maximum Generation	:	15135 MW (Generation end)		05.	Total Generation	:	318.56 MKWh				
03.	Reserve / Shortage	:	535 MW (Generation end)		06.	Probable Max. Temperature in Dhaka :	32.5° C					

#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation