

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month August, 2023		Day : Monday		Date : 28.08.23										
Probable Maximum Demand : 14500 MW		Probable Maximum Generation : 15012 MW												
Water Level of Kaptai Lake at 06:00 AM		Yesterday = 102.60 ft		Today = 103.45 ft										
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Dated/ Present Capacity (MW)	27.08.23 (Yesterday)		28.08.23 (Today)		Rule Curve = 97.68 ft		27.08.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/Oil/Water Limitation MW		Machines shut down (MW)		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening						
(A) Plants in operation:														
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260		Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	140	140	160	160					
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180					
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0					
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108			Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105			Gas Shortage	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0					
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	330	327	360	360					
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450					
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115		Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	406	412	0	412					
11	Siddhirganj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	184	75	200	200	135			Gas Shortage	
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	320	327	330	330					
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0		115		Under maint.	
14	Madanganj 55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	30	55	55					
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	24	92	102	102					
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	15	16	17	17					
17	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	43	41	44	44					
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	25	33					
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	32	33	33					
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	25	8	25					
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	35	100	35	100					
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	64	145	48	149					
23	Kamalaghat 54 MW PP (Barco Energy)	HFO (IPP)	3x18.69	54	54	17	35	17	35					
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	95	130	195	130					
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	132	133	105	130					
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	0	0					
27	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	12	55	35	55					
28	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	35	35	35					
29	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	45	72	35	70					
30	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	50	108	54	108					
31	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	23	0	35	0					
32	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	34	17	17	17					
33	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	12	83	86	86					
34	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	17	66	60	72					
35	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	2	80	85	85					
36	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	55	50	50					
Dhaka Zone Total			5904	5722	2786	3286	2856	3528	348	490				
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	200	203	204	204					
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	115	120	120	120		180		Under maint.	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0					
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	1	0	5	0					
40	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	17	8	25					
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	6	0	20	0					
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	6	6	50					
43	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	34	34	34	34		150		Under maint.	
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0					
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	194	205	212	212					
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	87	294	65	300					
47	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	12	12	12	12					
48	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	16	16	16	16					
49	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	32	72	34	75					
50	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	12	12	12	12					
*	Malancha, Clp EPZ (United)	Gas	5x8.73+3x9.34			10	15	5	25					
51	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	12	0	12					
52	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	17					
53	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	35	55	55	55					
54	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	12	12	12	12					
55	Juldah 100 MW Unit-1 (Acom)	HFO (QRRP)	8x13.45	100	100	12	12	12	12					
56	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	34	34	34	34					
57	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	17	34	17	134					
	SS Power Unit-1	Coal (IPP)				0	0	0	0					
	Matarbari 2*600 MW (CPGCL)	Coal				390	602	0	180				Test run	
	Cox's Bazar Wind PP	(Wind) (IPP)				19	0	10	10					
Chattogram Zone Total			2605	2545	1261	1784	910	1551	0	330				
58	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	10	10	10	10	35			Gas Shortage	
59	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	203	194	180	205					
60	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	240	240	250	250	120			Gas Shortage	
61	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	280	270	280	280	90			Gas Shortage	
62	Ashuganj 420 MW CCPP(East)	Gas (APSCL)	1x284+1x116	400	400	250	230	280	280	170			Gas Shortage	
63	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	0	0	0	0	195			Gas Shortage	
64	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51					
65	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	5	45	6	50					
66	Tilas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	23	43	47	47					
67	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163			Under maint.	
68	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	100	85	50	85					
69	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	16	17	16	16					
70	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11					
71	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	25	25	25	25					
72	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	16	43	43	43					
73	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	20	20	20					
74	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	88	106	106					
75	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	9	28	9	29					
76	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	35	17	17	17					
77	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	60	115	72	115					
**	Import (Tirupura)	India		160	160	118	148	148	164					
Cumilla Zone Total			2904	2896	1489	1680	1621	1804	610	163				
78	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	51	85	50	90	117			Gas Shortage	
79	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	17	17	16	16					
80	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	37	102	38	102					
81	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	116	141	114	145					
82	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0					
83	Sulakshai 50 MW Solar PP	Solar (IPP)	1x50	50	50	18	0	50	0					
84	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	6	6	6	6					
Mymensingh Zone Total			622	614	246	351	276	359	117	0				

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	27.08.23 (Yesterday)		28.08.23 (Today)		27.08.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	Machines shut down (MW)			
85	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43	27	GT-1 Under maint.	
86	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	40	39	40	40	51	GT-4 Under maint.	
87	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	47	50	50	50			
88	Kushiera 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	112	80	112	112	54	ST Under maint.	
89	Hobgiri 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	5	11	11			
90	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	60	40	60	60			
91	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0	330	Under maint.	
92	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	75	84	86	86			
93	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	185	185	200	200			
94	Sylhet 20 MW GTTP	Gas (PDB)	1x 20	20	20	17	17	17	17			
95	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10			
96	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	24	24			
97	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	294	310	310			
98	Bibiana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	366	366	385	400			
99	Bibiana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	0	0	0	0	383	Under maint.	
100	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0	100	Under project work	
101	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.4+5*2	50	50	43	46	42	42			
Sylhet Zone Total					2472	2427	1322	1275	1390	1405	0	945
102	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0			
103	Bheramara 410 MW CAPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	0	0	0	0	410	Gas Shortage	
104	Fairdipor 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	45	0	45			
105	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	24	40	52			
106	Khulna 225 MW CAPP	HSD/ Gas (NWP/GCL)	1 x 150+1x75	230	230	0	0	0	0			
107	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	35	53	75			
108	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	0	15	15	15			
109	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	60	0	100	0			
110	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	74	52	98			
111	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	32	8	32			
112	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	324	331	370	370			
113	Khulna 330 MW CAPP (GT)	Gas/HSD (BFDDB)	1x220	220	220	122	149	120	120			
**	Bheramara (HVDC)	India		1000	1000	914	863	930	930			
Khulna Zone Total					3125	3121	1420	1568	1688	1737	410	0
114	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	32	48	110			
115	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	19	29	22	30			
116	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	132	130	132	132			
117	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	1244	1210	1220	1220			
118	Potukhalhi 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	136	35	150			
119	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	0	0	0	0	307	Coal Shortage	
120	Bhola 220MW CAPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	222	220	220	220			
Barishal Zone Total					2265	2265	1617	1757	1677	1862	307	0
121	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71	Gas Shortage	
122	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100	Under maint.	
123	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	35	0	35			
124	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0			
125	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	5	0	20			
126	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	91	50	92			
127	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	35	30	40			
128	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	8	0	34			
129	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	24	0	24			
130	Sirajgonj 225MW CAPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	0	0	0	0	210	Gas Shortage	
131	Sirajgonj 225MW CAPP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	0	0	0	0	220	Gas Shortage	
132	Sirajgonj 225MW CAPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	208	213	212	210			
133	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	414	348	414	414			
134	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	0	0	0	0			
135	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8			
136	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	8	8	52			
137	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	35	55	35	55			
138	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	35	35	50			
139	Amnura 50 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	0	0	0	0			
140	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	4	0	6	0			
**	Adani Power Jharkhand Ltd	(Import)	2x748	1496	1496	1257	1367	1300	1367			
Rajshahi Zone Total					3675	3631	1961	2232	2098	2401	501	100
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Coal Shortage	
142	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Under Overhauling	
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	180	180	180	220			
144	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	35	72	35	70			
146	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
147	Mapara Taluk 9 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	6	0	8	0			
148	Thakurgaon 119MW PP (Energypac)	HFO (IPP)	6*20	119	115	0	66	0	75			
149	Lalmoharhat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	6	0	30	0			
150	Teesa Solar Limited	Solar (IPP)	1 x 200	200	200	36	0	130	0			
Rangpur Zone Total					1030	950	263	318	383	365	85	85
Sub-total: Plants in operation					24602	24171	12365.0	14251	12899	15012	2378	2113
(B) Plants under long term maintenance/ contract expired												
151	Jamailpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			
152	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			
153	Bosilia 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			
154	Ashugani 55 MW PP (Precision)	Gas (RPP)	15*4	55	0	0	0	0	0			
Sub-Total: Plants under long term maintenance/ contract expired					309	0	0	0	0	0	0	0
Gross Total					24911	24171	12365	14251	12899	15012	2378	2113
(C) Actual data of 27.08.23 (Yesterday) Sunday :												
01.	Max. Demand at eve. peak (Generation end)	:	14350 MW, at =	19:30 hrs	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	13670 MW, at =	19:30 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	14251 MW, at =	19:30 hrs	Dhaka	4933	4933	0	Mymensingh	1160	1095	65
04.	Minimum Generation (Generation end)	:	10484 MW, at =	8:00 hrs	Chattogram	1230	1230	0	Sylhet	500	500	0
05.	Day-peak Generation (Generation end)	:	12365 MW, at =	12:00 hrs	Khulna	1742	1742	0	Barishal	425	425	0
06.	Evening-peak Generation (Generation end)	:	14251 MW, at =	19:30 hrs	Rajshahi	1474	1474	0	Rangpur	937	907	30
07.	Evening Peak Load-shed (Sub-station end)	:	95 MW, at =	19:30 hrs	Cumilla	1270	1270	0				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	11070 MW, at =	5:00 hrs								
09.	Generation shortfall at evening peak due to :	:										
	a) Gas/LF limitation	:	2293 MW									
	d) Coal supply Limitation	:	85 MW									
	b) Low water level in Kaptai lake	:	0 MW									
	c) Plants under shut down/ maintenance	:	2113 MW									
10.	Total Energy (Generation + India Import)	:	297.07 MMWh									
	By Gas = 139.593 MKWH	By Oil =	45.176 MKWh									
	By Coal = 81.811 MKWH	By Hydro =	4.904 MKWh									
	By Solar= 1.303 MKWH											
11.	Total Gas Supplied	:	1103.12 MMCFD									
(D) Forecast of 28.08.23 (Today) Monday :												
01.	Maximum Demand	:	14500 MW (Generation end)		04.	Maximum Load-shed	:	0 MW	At evening peak (Sub-station end)			
02.	Maximum Generation	:	15012 MW (Generation end)		05.	Total Generation	:	302.27 MKWh				
03.	Reserve / Shortage	:	512 MW (Generation end)		06.	Probable Max. Temperature in Dhaka :	:	34.7° C				

#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation