

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month August, 2023					Day : Wednesday					Date : 30.08.23					
Probable Maximum Demand :					15250 MW		Probable Maximum Generation :					15255 MW			
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 103.90 ft		Today = 104.34 ft		30.08.23		Rule Curve = 98.34 ft				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Dered/ Present Capacity (MW)	29.08.23 (Yesterday)		30.08.23 (Today)		29.08.23 (Yesterday)		Status of Machines under shut-down/ Maintenance		Probable start-up date		
					Actual Peak Generation (MW)	Probable Peak Generation (MW)	Probable Peak Generation (MW)	Gen. shortfall for : Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)	Description/ Remarks					
											Day	Evening		Day	Evening
(A) Plants in operation:															
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work			
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	140	130	130	130						
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180						
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0						
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108		Gas Shortage			
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage			
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0						
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	333	332	330	330						
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450						
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling			
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	400	393	400	412						
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	179	155	186	186						
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	319	325	330	330						
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0		115	Under maint.			
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	55	15	55						
15	Cagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	48	91	48	92						
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	16	18	18	18						
17	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	38	38	44	44						
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	30	30	30	30						
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	28	28	33	33						
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	25	8	25						
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	70	100	35	100						
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	64	145	48	149						
23	Kamalaghat 54 MW PP (Barco Energy)	HFO (IPP)	3x18.69	54	54	17	35	17	35						
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	225	132	130	195						
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	98	134	70	135						
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	0	0						
27	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	4	55	35	55						
28	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	35	35	35						
29	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	48	52	35	70						
30	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	54	108	54	108						
31	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	30	0	35	0						
32	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	34	17	17	17						
33	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	50	50	50	50						
34	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	49	49	50	64						
35	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	83	68	65	85						
36	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	34	34	0	45						
Dhaka Zone Total				5904	5722	3119	3264	2898	3458	213	490				
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	167	204	204	204						
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	119	110	110	110		180	Under maint.			
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0						
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	5	0	5	0						
40	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	8	8	25						
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	8	0	20	0						
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	11	50	50	50						
43	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	51	51	51	51						
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.			
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	201	206	205	205						
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	69	267	65	270						
47	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	12	12	12	12						
48	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	16	16	16	16						
49	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	40	69	34	65						
50	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	14	14	14	14						
*	Malancha, Cig EPZ (United)	Gas	5x8.73+3x9.34			6	26	5	25						
51	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	2	12	0	12						
52	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	17						
53	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	44	55	55	55						
54	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	12	12	12	12						
55	Juldah 100 MW Unit-1 (Acom)	HFO (QRRP)	8x13.45	100	100	12	12	12	12						
56	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	34	51	34	51						
57	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	52	141	17	141						
	SS Power Unit-1	Coal (IPP)				0	0	0	0						
	Matarbari 2*600 MW (CPGCL)	Coal				345	600	600	600			Test run			
	Cox's Bazar Wind PP	(Wind) (IPP)				0	0	10	10						
Chattogram Zone Total				2605	2545	1245	1933	1556	1957	0	330				
58	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	0	0	0	0	45		Gas Shortage			
59	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1*75	221	221	201	198	200	205						
60	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	250	250	240	240	110		Gas Shortage			
61	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	290	290	280	280	70		Gas Shortage			
62	Ashuganj 420 MW CCPP(East)	Gas (APSCL)	1x284+1x116	400	400	230	270	250	250	130		Gas Shortage			
63	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*116	195	195	0	0	0	0	195		Gas Shortage			
64	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51						
65	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	12	54	12	50						
66	Tilas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	24	47	47	47						
67	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0		163	Under maint.			
68	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	51	92	50	92						
69	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	15	17	16	16						
70	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11						
71	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33						
72	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	32	43	43	43						
73	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	11	20	20	20						
74	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	106	106	106	106						
75	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	28	29	9	28						
76	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	35	17	17	17						
77	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	72	93	72	115						
**	Importo (Tirupura)	India		160	160	128	144	149	165						
Cumilla Zone Total				2904	2896	1577	1765	1606	1769	550	163				
78	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	48	87	50	90	115		Gas Shortage			
79	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	17	16	16	16						
80	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	38	94	38	102						
81	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	116	154	115	152						
82	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0						
83	Sulakshai 50 MW Solar PP	Solar (IPP)	1x50	50	50	47	0	50	0						
84	Tangail 22 MW PP(PPLG)	HFO (IPP)	4x6.7	22	22	6	6	6	6						
Mymensingh Zone Total				622	614	274	357	277	366	115	0				

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	29.08.23 (Yesterday)		30.08.23 (Today)		29.08.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening				
85	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 Under maint.	
86	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	38	39	40	40		51	GT-4 Under maint.	
87	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)		19x2.90	51	51	47	47	50	50			
88	Kushiera 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	112	112	112	112		54	ST Under maint.	
89	Hobigani 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	5	5	5	11			
90	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	54	59	60	60				
91	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
92	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	75	84	86	86				
93	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	183	181	186	186				
94	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	17	17	17	17				
95	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	10	10	10				
96	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	0	16	16	16				
97	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	310	295	300	300				
98	Bibiyan-II 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	377	404	385	400				
99	Bibiyan South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	0	0	0	0		383	Under maint.	
100	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
101	Fenchugani 44MW (Energyprima)	Gas (NENP)	12*3.4+5*2	50	50	42	45	42	42				
Sylhet Zone Total						2472	2427	1318	1357	1352	1373	0	945
102	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
103	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0		410	Gas Shortage	
104	Fairdip 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	32	25	45				
105	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	15	35	40	52				
106	Khulna 225 MW CAPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0				
107	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	36	54	35	54				
108	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	15	15	15	15				
109	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	90	0	100	0				
110	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	46	48	16	48				
111	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	32	8	32				
112	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	421	421	400	400				
113	Khulna 330 MW CAPP (GT)	Gas/HSD (BPDF)	1x220	220	220	124	184	120	120				
**	Bheramara (HVDC)	India		1000	1000	918	795	937	937				
Khulna Zone Total						3125	3121	1665	1616	1696	1703	410	0
114	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	48	110	48	110				
115	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	23	31	20	30				
116	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	128	124	132	132				
117	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	1244	1244	1220	1220				
118	Potukhaili 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	35	150	35	150				
119	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	0	0	0	0		307	Coal Shortage	
120	Bhola 220MW CAPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	220	220	220				
Barishal Zone Total						2265	2265	1698	1879	1675	1862	307	0
121	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage	
122	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.	
123	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	28	0	35				
124	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0				
125	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	14	0	20				
126	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	0	50	92				
127	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	39	30	40				
128	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	42	42	42	42				
129	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	24	0	24				
130	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0		210	Gas Shortage	
131	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0		220	Gas Shortage	
132	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	185	211	210	210				
133	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	414	380	414	414				
134	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	0	0	0	0				
135	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8				
136	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	52	8	52				
137	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	35	55	35	55				
138	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	50	35	50				
139	Ammura 50 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	0	0	28	28				
139	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0				
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	1358	1465	1300	1367				
Rajshahi Zone Total						3675	3631	2090	2368	2166	2437	501	100
140	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Coal Shortage	
141	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
141	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	230	0	180	180				
142	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
143	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	34	83	34	56				
144	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
145	Majpara, Talsia 9 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 9	9	9	4	0	8	0				
146	Thakurgaon 119MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	94	0	94				
147	Lalmohini 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	22	0	30	0				
148	Teesa Solar Limited	Solar (IPP)	1 x 200	200	200	106	0	130	0				
Rangpur Zone Total						1030	950	396	177	382	330	85	85
Sub-total: Plants in operation						24602	24171	13382.0	14716	13608	15255	2181	2113
(B) Plants under long term maintenance/ contract expired													
149	Jamailpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
150	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
151	Bosilia 108MW PP(ELC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
152	Ashugani 55 MW PP (Precision)	Gas (RPP)	15*4	55	0	0	0	0	0				
Sub-Total: Plants under long term maintenance/ contract expired						309	0	0	0	0	0	0	0
Gross Total						24911	24171	13382	14716	13608	15255	2181	2113
(C) Actual data of 29.08.23 (Yesterday) Tuesday :													
01.	Max. Demand at eve. peak (Generation end)	:	15000 MW, at =	21:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	14397 MW, at =	21:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed	
03.	Highest Generation (Generation end)	:	14716 MW, at =	21:00 hrs	Dhaka	4940	4930	10	Mymensingh	1186	1135	51	
04.	Minimum Generation (Generation end)	:	11711 MW, at =	8:00 hrs	Chattogram	1499	1499	0	Sylhet	598	598	0	
05.	Day-peak Generation (Generation end)	:	13382 MW, at =	12:00 hrs	Khulna	1789	1789	0	Barishal	444	444	0	
06.	Evening-peak Generation (Generation end)	:	14716 MW, at =	21:00 hrs	Rajshahi	1567	1567	0	Rangpur	974	774	200	
07.	Evening Peak Load-shed (Sub-station end)	:	271 MW, at =	21:00 hrs	Cumilla	1400	1390	10					
08.	Minimum Generation Forecast up to 8:00 hrs.	:	12235 MW, at =	5:00 hrs									
09.	Generation shortfall at evening peak due to :	:											
a) Gas/LF limitation	:	2096 MW											
c) Coal supply Limitation	:	85 MW											
b) Low water level in Kaptai lake	:	0 MW											
c) Plants under shut down/ maintenance	:	2113 MW											
10.	Total Energy (Generation + India Import)	:	315.49 MKWh										
	By Gas =	141.676 MKWh	By Oil =	54.153 MKWh									
	By Coal =	87.464 MKWh	By Hydro =	4.901 MKWh									
	By Solar=	2.347 MKWh											
11.	Total Gas Supplied	:	1101.56 MMCFD										
(D) Forecast of 30.08.23 (Today) Wednesday :													
01.	Maximum Demand	:	15250 MW (Generation end)		04.	Maximum Load-shed	:	0 MW	At evening peak (Sub-station end)				
02.	Maximum Generation	:	15255 MW (Generation end)		05.	Total Generation	:	326.94 MKWh					
03.	Reserve / Shortage	:	5 MW (Generation end)		06.	Probable Max. Temperature in Dhaka :	:	34.4° C					

#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation