

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month September, 2023				Day : Saturday				Date : 02.09.23							
Probable Maximum Demand : 15000 MW				Probable Maximum Generation : 15730 MW											
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 104.89 ft		Today = 105.08 ft		Rule Curve = 92.23 ft							
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Dated/ Present Capacity (MW)	01.09.23 (Yesterday)		02.09.23 (Today)		01.09.23 (Yesterday)		02.09.23 (Today)		Status of Machines under shut-down/ Maintenance	Description/ Remarks	Probable start-up date
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Machines shut down (MW)				
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW						
(A) Plants in operation:															
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0			260	Under project work		
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	150	220	200	220						
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180						
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0						
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108			Gas Shortage		
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105			Gas Shortage		
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0						
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	331	327	330	330						
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	0	65	450	450						
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0			115	Under Overhauling		
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	403	403	412	412						
11	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	125	192	200	200						
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	310	320	330	330						
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0			115	Under maint.		
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	55	55	55						
15	Cagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	25	75	24	85						
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	14	16	18	18						
17	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	30	33	44	44						
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	30	30						
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	24	32	33	33						
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	24	8	25						
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	17	70	40	88						
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	64	133	48	150						
23	Kamalaghat 54 MW PP (Barco Energy)	HFO (IPP)	3x18.69	54	54	17	54	17	35						
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	32	47	32	48						
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	17	67	17	70						
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	0	0						
27	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	17	55	35	55						
28	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	35	35	35						
29	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	34	35	34	54						
30	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	54	108	54	108						
31	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	32	0	35	0						
32	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	17	17	17						
33	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	40	40	30	40						
34	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	17	49	70	74						
35	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	70	65	85	85						
36	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	22	45	24	60						
Dhaka Zone Total				5904	5722	2166	2787	2887	3331	213	490				
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	204	205	204	204						
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	116	117	120	120			180	Under maint.		
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0						
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	1	0	5	0						
40	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	17	8	25						
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	6	0	20	0						
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	6	50	50						
43	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	17	51	51			150	Under maint.		
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0						
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	144	151	150	150						
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	70	120	70	300						
47	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	25	25	25						
48	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	17	16	16	33						
49	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	32	64	34	65						
50	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	14	14	14	14						
*	Malancha, Clp EPZ (United)	Gas	5x8.73+3x9.34			21	36	20	35						
51	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	12	0	12						
52	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	54	17	54						
53	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	55	55	55	55						
54	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	25	25	25	25						
55	Juldah 100 MW Unit-1 (Acom)	HFO (QRRP)	8x13.45	100	100	25	25	25	25						
56	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	34	34	34	51						
57	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	52	160	17	160						
	SS Power Unit-1	Coal (IPP)				530	565	550	565						
	Matarbari 2*600 MW (CPGCL)	Coal				0	0	0	0				Test run		
	Cox's Bazar Wind PP	(Wind) (IPP)				0	0	10	10						
Chattogram Zone Total				2605	2545	1419	1718	1520	2029	0	330				
58	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	0	0	0	0	45			Gas Shortage		
59	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	197	204	200	205						
60	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	240	240	240	270	120			Gas Shortage		
61	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	320	280	300	300	80			Gas Shortage		
62	Ashuganj 420 MW CCPP(East)	Gas (APSCCL)	1x284+1x116	400	400	250	230	250	250	170			Gas Shortage		
63	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	0	0	187			Gas Shortage		
64	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51						
65	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	12	31	12	30						
66	Tilas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	23	39	47	47						
67	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0			163	Under maint.		
68	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	34	17	34						
69	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	17	16	16						
70	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11						
71	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	30	30	33	33						
72	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	43	43	43	43						
73	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	0	12	20	20						
74	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	106	106	106	106						
75	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	28	57	26	55						
76	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17						
77	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	72	93	72	115						
**	Importo (Tirupura)	India		160	160	130	158	149	165						
Cumilla Zone Total				2904	2896	1555	1661	1610	1768	602	163				
78	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	34	93	100	100	109			Gas Shortage		
79	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	16	16	16	16						
80	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	38	103	35	102						
81	Mymensingh 200 MW PP														

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	01.09.23 (Yesterday)		02.09.23 (Today)		01.09.23 (Yesterday)		Status of Machines under shut-down/ Maintenance		
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :				
						Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date	
85	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 Under maint.		
86	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	39	0	0	0		90	GT-4 Under maint.		
87	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	44	47	50	50					
88	Kushihara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	112	112	112	112		54	ST Under maint.		
89	Hobigunj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	5	5	11					
90	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	58	59	60	60					
91	Shajibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.		
92	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	78	84	86	86					
93	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	183	180	186	186					
94	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	17	17	17	17					
95	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10					
96	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16					
97	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	305	290	300	300					
98	Bibiyan-II 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	404	368	400	400					
99	Bibiyan South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	0	0	0	0		383	Under maint.		
100	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work		
101	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.4+5*2	50	50	44	45	42	45					
Sylhet Zone Total						2472	2427	1361	1276	1327	1336	0	984	
102	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0					
103	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0		410	Gas Shortage		
104	Fairdipor 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	10	30	25	45					
105	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	40	52					
106	Khulna 225 MW CCPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0					
107	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	17	35	36	36					
108	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	15	15					
109	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	84	0	100	0					
110	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	47	81	32	98					
111	Noapara 40 MW PP (Khanaihan Ali)	HFO (NENP)	5*8.5	40	40	0	16	8	32					
112	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	422	245	420	570					
113	Khulna 330 MW CCPP (GT)	Gas/HSD (BDFB)	1x220	220	220	121	358	120	120					
**	Bheramara (HVDC)	India		1000	1000	927	813	944	944					
Khulna Zone Total						3125	3121	1628	1578	1740	1912	410	0	
114	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	96	110	96	110					
115	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	20	31	23	30					
116	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	124	124	132	132					
117	Payra 1320 MW TTP	Coal (BCPCL)	2x622	1244	1244	1244	1244	1244	1244					
118	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	35	150	35	150					
119	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	0	0	0	0		307	Coal Shortage		
120	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	216	222	220	220					
Barishal Zone Total						2265	2265	1735	1881	1750	1886	307	0	
121	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage		
122	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.		
123	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	35	0	35					
124	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0					
125	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	20	0	20					
126	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	92	50	92					
127	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	39	30	40					
128	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	34	42	42					
129	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	24	0	24					
130	Sirajganj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	167	182	200	200					
131	Sirajganj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0		220	Gas Shortage		
132	Sirajganj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	142	160	180	200					
133	Sirajganj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	369	414	414	414					
134	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	0	0	0	0	0					
135	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8					
136	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	52	8	52					
137	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	35	75	35	74					
138	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	50	35	75					
139	Ammura 50 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	28	28	28	28					
139	Sirajganj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	2	0	6	0					
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	1105	1412	1400	1400					
Rajshahi Zone Total						3675	3631	1899	2625	2436	2704	291	100	
140	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Coal Shortage		
141	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling		
141	Barapukuria 275 MW TTP Unit-3	Coal (PDB)	1 x 274	274	274	200	190	200	200					
142	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
143	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	38	76	34	80					
144	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
145	Majma. Talsia 9 MW Solar PP (Syma Power)	Solar (IPP)	1 x 9	9	9	4	0	8	0					
146	Thakurgaon 119MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	94	0	115					
147	Lalmohiniat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	35	0	30	0					
148	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	146	0	130	0					
Rangpur Zone Total						1030	950	423	360	402	395	85	85	
Sub-total: Plants in operation						24602	24171	12420.0	14239	13996	15730	2017	2152	
(B) Plants under long term maintenance/ contract expired														
149	Jamailpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0					
150	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0					
151	Bosilia 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0					
152	Ashugani 55 MW PP (Precision)	Gas (RPP)	15*4	55	0	0	0	0	0					
Sub-Total: Plants under long term maintenance/ contract expired						309	0	0	0	0	0	0	0	
Gross Total						24911	24171	12420	14239	13996	15730	2017	2152	
(C) Actual data of 01.09.23 (Yesterday) Friday :														
01.	Max. Demand at eve. peak (Generation end)	:	14380	MW, at =	21:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	13704	MW, at =	21:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed	
03.	Highest Generation (Generation end)	:	14315	MW, at =	22:00 hrs		MW	MW	MW		MW	MW	MW	
04.	Minimum Generation (Generation end)	:	11318	MW, at =	8:00 hrs	Dhaka	4439	4439	0	Mymensingh	1253	1183	70	
05.	Day-peak Generation (Generation end)	:	12420	MW, at =	12:00 hrs	Chattogram	1359	1359	0	Sylhet	597	570	27	
06.	Evening-peak Generation (Generation end)	:	14239	MW, at =	21:00 hrs	Khulna	1711	1711	0	Barishal	446	446	0	
07.	Evening Peak Load-shed (Sub-station end)	:	135	MW, at =	21:00 hrs	Rajshahi	1539	1539	0	Rangpur	975	955	20	
08.	Minimum Generation Forecast up to 8:00 hrs.	:	11844	MW, at =	5:00 hrs	Cumilla	1385	1367	18					
09.	Generation shortfall at evening peak due to :	:				Total						13704	13569	135
a)	Gas/LF limitation	:	1932	MW		(a) Gas = 152417009 Taka						(c) Coal = 621281135	Taka	
b)	Coal supply Limitation	:	85	MW		(b) Oil = 565115816 Taka						Total = 1338813959	Taka	
c)	Low water level in Kaptai lake	:	0	MW										
d)	Plants under shut down/ maintenance	:	2152	MW										
10.	Total Energy (Generation + India Import)	:	300.98	MW										
	By Gas = 134.950 MKWH			By Oil =	48.722 MKWH									
	By Coal = 85.292 MKWH			By Hydro =	4.640 MKWH									
	By Solar= 2.219 MKWH													
11.	Total Gas Supplied	:	1076.80	MMCFD										
(D) Forecast of 02.09.23 (Today) Saturday :														
01.	Maximum Demand	:	15000	MW	(Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)			
02.	Maximum Generation	:	15730	MW	(Generation end)	05.	Total Generation	:	315.38	MW				
03.	Reserve / Shortage	:	730	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	:	35.4° C					

#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation