

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month September, 2023				Day : Sunday				Date : 03.09.23					
Probable Maximum Demand : 15000 MW				Probable Maximum Generation : 15710 MW									
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 105.08 ft		Today = 105.52 ft		Rule Curve = 99.46 ft.					
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Dered/ Present Capacity (MW)	02.09.23 (Yesterday)		03.09.23 (Today)		02.09.23 (Yesterday) Gen. shortfall for : Gas/Coal/oil/Water Limitation MW	Status of Machines under shut-down/ Maintenance	Description/ Remarks	Probable start-up date	
					Actual Peak Generation (MW)	Probable Peak Generation (MW)	Actual Peak Generation (MW)	Probable Peak Generation (MW)					
													Day
(A) Plants in operation:													
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work		
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	180	130	150	150				
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180				
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0				
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108	Gas Shortage		
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage		
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0				
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	332	332	330	330				
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450				
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling		
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	404	382	380	412				
11	Siddhirganj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	177	75	150	150	135	Gas Shortage		
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	315	310	330	330				
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0	115	Under maint.		
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	55	55	55				
15	Cagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	25	66	32	74				
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	10	19	18	18				
17	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	33	37	38	38				
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	33	33	33				
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	32	30	33	33				
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	24	8	25				
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	35	88	40	88				
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	82	148	48	150				
23	Kamalaghat 54 MW PP (Barco Energy)	HFO (IPP)	3x18.69	54	54	17	54	17	35				
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	97	95	32	95				
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	42	76	100	149				
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	0	0				
27	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	17	55	35	55				
28	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	35	35	35				
29	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	54	34	54				
30	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	0	126	72	108				
31	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	0	0	35	0				
32	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	17	17	17				
33	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	10	41	50	60				
34	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	24	65	82	82				
35	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	22	80	85	85				
36	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	44	36	36				
Dhaka Zone Total				5904	5722	2601	3101	2905	3327	348	490		
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	205	203	204	204				
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	115	115	115	115				
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.		
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	0	0	5	0				
40	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	17	8	25				
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	4	0	20	0				
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	6	50	50				
43	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	17	51	51				
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.		
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	150	151	150	150				
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	70	120	70	300				
47	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	25	25	25				
48	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	16	16	16	33				
49	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	23	70	34	70				
50	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	13	13	14	14				
*	Malancha, Clp EPZ (United)	Gas	5x8.73+3x9.34			8	37	20	35				
51	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	12	0	12				
52	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	53	17	54				
53	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	55	55	55	55				
54	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	25	25	25	25				
55	Juldah 100 MW Unit-1 (Acom)	HFO (QRRP)	8x13.45	100	100	25	25	25	25				
56	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	19	51	34	51				
57	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	50	141	17	160				
	SS Power Unit-1	Coal (IPP)				525	607	550	565				
	Matarbari 2*600 MW (CPGCL)	Coal				0	0	0	0		Test run		
	Cox's Bazar Wind PP	(Wind) (IPP)				0	0	10	10				
Chattogram Zone Total				2605	2545	1370	1759	1515	2029	0	330		
58	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	0	0	0	0	45	Gas Shortage		
59	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+1x75	221	221	187	177	200	205				
60	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	260	260	250	260	100	Gas Shortage		
61	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	300	280	300	300	80	Gas Shortage		
62	Ashuganj 420 MW CCPP(East)	Gas (APSCL)	1x284+1x116	400	400	240	260	280	280	140	Gas Shortage		
63	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*116	195	195	8	8	0	0	187	Gas Shortage		
64	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	51	51	51				
65	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	5	23	12	30				
66	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	38	43	47	47				
67	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163	Under maint.		
68	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	25	34	17	34				
69	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	15	17	16	16				
70	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	0	0	11	11				
71	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	25	25	33	33				
72	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	24	43	43	43				
73	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	12	12	20	20				
74	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	106	106	106				
75	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	37	57	26	55				
76	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17				
77	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	72	93	72	94				
**	Importo (Tirupura)	India		160	160	160	164	149	165				
Cumilla Zone Total				2904	2896	1485	1670	1650	1767	552	163		
78	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	95	86	100	100	116	Gas Shortage		
79	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	16	16	16				
80	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	37	93	35	102				
81	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	116	153	115	145				
82	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0				
83	Sulakhai 50 MW Solar PP	Solar (IPP)	1x50	50	50	24	0	50	0				
84	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	0	6	6	6				
Mymensingh Zone Total				622	614	273	354	324	369	116	0		

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	02.09.23 (Yesterday)		03.09.23 (Today)		02.09.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)		
85	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 Under maint.	
86	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	0	0	0	0		90	GT-4 Under maint.	
87	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	45	46	50	50				
88	Kushiera 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	112	112	112	112		54	ST Under maint.	
89	Hobigari 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	5	11	11				
90	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	57	58	60	60				
91	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
92	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	75	86	86	86				
93	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	182	182	186	186				
94	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	17	17	17	17				
95	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
96	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16				
97	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	280	300	300				
98	Bibiyana-II 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	403	320	400	400				
99	Bibiyana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	0	0	0	0		383	Under maint.	
100	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
101	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.4+5*2	50	50	43	45	42	45				
Sylhet Zone Total						2472	2427	1314	1220	1333	1336	0	984
102	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
103	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0		410	Gas Shortage	
104	Fairdipor 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	10	31	25	45				
105	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	40	52				
106	Khulna 225 MW CAPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0				
107	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	17	17	36	36				
108	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	15	15				
109	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	68	0	100	0				
110	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	22	80	32	98				
111	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	32	8	32				
112	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	420	562	420	570				
113	Khulna 330 MW CAPP (GT)	Gas/HSD (BDFB)	1x220	220	220	122	332	120	120				
**	Bheramara (HVDC)	India		1000	1000	925	812	928	928				
Khulna Zone Total						3125	3121	1584	1866	1724	1896	410	0
114	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	80	96	110				
115	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	23	33	23	30				
116	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	124	124	132	132				
117	Payra 1320 MW TTP	Coal (BCPCL)	2x622	1244	1244	1244	1244	1244	1244				
118	Potukhalhi 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	150	35	150				
119	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	0	0	0	0		307	Coal Shortage	
120	Bhola 220MW CAPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	215	180	220	220				
Barishal Zone Total						2265	2265	1639	1811	1750	1886	307	0
121	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage	
122	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.	
123	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	34	0	35				
124	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0				
125	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	20	0	20				
126	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	91	50	92				
127	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	30	40				
128	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	25	25	42	42				
129	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	24	0	24				
130	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	209	203	200	200				
131	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0		220	Gas Shortage	
132	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	199	174	180	200				
133	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	300	414	414	414				
134	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	0	0	0	0	0				
135	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	5	8	8	8				
136	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	52	8	52				
137	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	35	75	35	75				
138	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	65	35	75				
139	Ammura 50 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	28	28	28	28				
139	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	4	0	6	0				
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	1310	1405	1400	1400				
Rajshahi Zone Total						3675	3631	2158	2650	2436	2705	291	100
140	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Coal Shortage	
141	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
141	Barapukuria 275 MW TTP Unit-3	Coal (PDB)	1 x 274	274	274	190	190	200	200				
142	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
143	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	35	61	34	80				
144	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
145	Majma. Talsia 9 MW Solar PP (Syma Power)	Solar (IPP)	1 x 9	9	8	2	0	8	0				
146	Thakurgaon 119MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	75	0	115				
147	Lalmoharhat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	7	0	30	0				
148	Teesa Solar Limited	Solar (IPP)	1 x 200	200	200	106	0	130	0				
Rangpur Zone Total						1030	950	340	326	402	395	85	85
Sub-total: Plants in operation						24602	24171	12764.0	14757	14039	15710	2109	2152
(B) Plants under long term maintenance/ contract expired													
149	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
150	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
151	Bosilia 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
152	Ashugani 55 MW PP (Precision)	Gas (RPP)	15*4	55	0	0	0	0	0				
Sub-Total: Plants under long term maintenance/ contract expired						309	0	0	0	0	0	0	0
Gross Total						24911	24171	12764	14757	14039	15710	2109	2152
(C) Actual data of 02.09.23 (Yesterday) Saturday :													
01.	Max. Demand at eve. peak (Generation end)	:	15100 MW, at =	21:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	14215 MW, at =	21:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW	
03.	Highest Generation (Generation end)	:	14757 MW, at =	21:00 hrs	Dhaka	4997	4987	10	Mymensingh	1272	1147	125	
04.	Minimum Generation (Generation end)	:	11844 MW, at =	7:00 hrs	Chattogram	1082	1082	0	Sylhet	573	528	45	
05.	Day-peak Generation (Generation end)	:	12764 MW, at =	12:00 hrs	Khulna	1808	1808	0	Barishal	468	468	0	
06.	Evening-peak Generation (Generation end)	:	14757 MW, at =	21:00 hrs	Rajshahi	1585	1585	0	Rangpur	1003	900	103	
07.	Evening Peak Load-shed (Sub-station end)	:	328 MW, at =	21:00 hrs	Cumilla	1427	1382	45					
08.	Minimum Generation Forecast up to 8:00 hrs.	:	10304 MW, at =	5:00 hrs					Total	14215	13887	328	
09.	Generation shortfall at evening peak due to :	:			13.	Fuel cost :	(a) Gas = 162134329 Taka	(c) Coal = 624209943 Taka					
	a) Gas/LF limitation	:	2024 MW			(b) Oil = 591829371 Taka		Total = 1378173643 Taka					
	d) Coal supply Limitation	:	85 MW		14.	Maximum Temperature in Dhaka was :	32.6°C						
	b) Low water level in Kaptai lake	:	0 MW		15.	Export through East-West interconnections :							
	c) Plants under shut down/ maintenance	:	2152 MW			At evening peak-hour	:	12764 MW, at	21:00 hrs				
10.	Total Energy (Generation + India Import)	:	310.75 MKWh			Maximum	:	640 MW, at	5:00 hrs				
	By Gas = 144.112 MKWh	By Oil =	50.444 MKWh			Energy	:	0 MKWh					
	By Coal = 85.480 MKWh	By Hydro =	4.758 MKWh										
	By Solar= 0.627 MKWh												
11.	Total Gas Supplied	:	1095.87 MMCFD										
(D) Forecast of 03.09.23 (Today) Sunday :													
01.	Maximum Demand	:	15000 MW (Generation end)		04.	Maximum Load-shed	:	0 MW	At evening peak (Sub-station end)				
02.	Maximum Generation	:	15710 MW (Generation end)		05.	Total Generation	:	315.86 MKWh					
03.	Reserve / Shortage	:	710 MW (Generation end)		06.	Probable Max. Temperature in Dhaka :	32.6°C						