

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 3564667, 9551095

Month September, 2023					Day : Monday				Date : 04.09.23				
Probable Maximum Demand : 15300 MW					Probable Maximum Generation : 15300 MW								
Water Level of Kapitai Lake at 06:00 AM					Yesterday = 105.52 ft		Today = 105.86 ft		04.09.23		Rule Curve = 99.69 ft.		
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	03.09.23 (Yesterday)		04.09.23 (Today)		03.09.23 (Yesterday)		04.09.23 (Today)		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/Water Limitation MW		Machines shut down (MW)		
					Day	Evening	Day	Evening	Description/ Remarks		Probable start-up date		
(A) Plants in operation:													
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	150	130	130	130				
3	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	170	170	170				
4	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0				
5	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108		Gas Shortage	
6	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage	
7	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0				
8	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	331	331	330	330				
9	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450				
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	387	411	380	412				
11	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	180	58	150	180	152		Gas Shortage	
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	317	324	330	330				
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0		335	Under maint.	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	15	15	15				
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	33	66	32	66				
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	19	18	19				
17	Summit Power(Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	37	37	37	37				
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	33	33	33				
19	Rugganji 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	0	0	22	22				
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	24	8	25				
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	47	88	40	88				
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	64	146	48	150				
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	35	17	35				
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	210	47	32	130				
25	Kodda 140 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	83	149	100	149				
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	25x11.4	300	300	0	0	0	0				
27	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	17	55	35	55				
28	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	35	35	35				
29	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	53	34	53				
30	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	72	108	72	108				
31	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	32	0	35	0				
32	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	17	17	17				
33	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	42	57	50	60				
34	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	25	50	50	50				
35	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	81	80	80	80				
36	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	2	56	36	55				
	Meghnaghat Unique Power	Gas				0	150	0	0				
Dhaka Zone Total					5904	5722	2914	3194	2786	3284	365	710	
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	204	203	203	203				
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	116	115	115	115				
39	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Under maint.	
40	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	6	0	5	0				
41	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	17	8	17				
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	20	0	20	0				
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	50	50	50				
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	51	51	51	51				
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150		Under maint.	
46	Sikalbaha 225 MW CAPP	Gas (PDB)	1 x 150+1 x 75	225	225	144	150	150	150	75		ST Under maint.	
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	70	284	70	285				
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	25	25	25				
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	16	16	16	16				
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	32	47	34	50				
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	14	13	14	14				
*	Malancha, Ctg.EPZ (United)	Gas	5x8.73+3x9.34			5	35	20	30				
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	12	0	12				
53	Sikalbaha 54 MW PP (Jodiad Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	54	17	54				
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	55	55	55	55				
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	33	25	25	25				
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	25	25	25	25				
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	34	51	34	51				
58	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	89	159	17	150				
	SS Power Unit-1	Coal (IPP)				622	481	600	360				
	Matarbari 2*600 MW (CPGCL)	Coal				0	0	0	0			Test run	
	Cox's Bazar Wind PP	(Wind) (IPP)				0	0	10	10				
Chattogram Zone Total					2605	2545	1592	1868	1564	1748	0	405	
58	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	0	0	0	0	45		Gas Shortage	
59	Ashuganj 225 MW CAPP	Gas (APSCCL)	1x142+1*75	221	221	200	186	200	200				
60	Ashuganj 450 MW CAPP(South)	Gas (APSCCL)	1x360	360	360	240	260	250	260	100		Gas Shortage	
61	Ashuganj 450 MW CAPP(North)	Gas (APSCCL)	1x361	360	360	315	280	280	280	80		Gas Shortage	
62	Ashuganj 420 MW CAPP(East)	Gas (APSCCL)	1x284+1x116	400	400	270	240	240	240	160		Gas Shortage	
63	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*116	195	195	0	0	0	0	195		Gas Shortage	
64	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	51	51	51				
65	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	5	23	12	30				
66	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	47	47				
67	Chandpur 150 MW CAPP	Gas (PDB)	1x106+1x57	163	163	0	0	0	0	163		Under maint.	
68	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	48	36	17	36				
69	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	15	15	16	16				
70	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	0	11	11	11				
71	Jangalia 33 MW PP (Summit))	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33				
72	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	34	34	34	34				
73	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	10	11	11	11				
74	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	52	106	106	106				
75	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	38	57	26	55				
76	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17				
77	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	72	93	72	93				
**	Importo (Tripura)	India		160	160	118	142	149	165				
Cumilla Zone Total					2904	2896	1510	1595	1572	1685	580	163	
78	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	62	81	80	85	121		Gas Shortage	
79	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	14	16	16	16				
80	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	38	94	35	80				
81	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	115	146	115	145				
82	Sarishabani 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0				
83	Sutiakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	51	0	50	0				
84	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	6	6	6	6				
Mymensingh Zone Total					622	614	288	337	304	332	121	0	

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	03.09.23 (Yesterday)		04.09.23 (Today)		03.09.23 (Yesterday)		Status of Machines under shut-down/ Maintenance								
						Actual Peak Generation (MW)	Probable Peak Generation (MW)	Gen. shortfall for : Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date									
												Day	Evening	Day	Evening					
85	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	39	43	43	43		27	GT-1 Under maint.								
86	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	0	0	0	0		90	GT-4 Under maint.								
87	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	47	50	50	50											
88	Kushiana 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	112	112	112	112		54	ST Under maint.								
89	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	5	5	5											
90	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	53	55	60	60											
91	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.								
92	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	73	86	86	86											
93	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	182	181	180	181											
94	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	17	17	17	17											
95	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	10	10	10											
96	Shahjibazar 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16											
97	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	275	300	300											
98	Bibiya-II 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	160	80	400	400											
99	Bibiya South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	0	0	0	0		383	Was Under maint.								
100	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work								
101	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	38	40	40	40											
Sylhet Zone Total						2472	2427	1057	970	1319	1320	0	984							
102	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0											
103	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0		410	Gas Shortage								
104	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	31	25	40											
105	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	25	40	50											
106	Khulna 225 MW CCPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0											
107	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	17	17	17	17											
108	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	0											
109	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	79	0	100	0											
110	Khulna 115 MW PP (KPCCL-2)	HFO (NENP)	7x17	115	115	16	85	32	98											
111	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	8	32	8	32											
112	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	497	567	420	570											
113	Khulna 330 MW CCPP (GT)	Gas/HSD (BDFB)	1x220	220	220	123	122	330	330											
**	Bheramara (HVD)	India		1000	1000	927	812	928	928											
Khulna Zone Total						3125	3121	1667	1671	1900	2065	410	0							
114	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	48	96	110											
115	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	23	33	23	33											
116	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	130	130	132	132											
117	Payra 1320 MW TPP	Coal (BCPL)	2x622	1244	1244	1244	1244	1244	1244											
118	Potukhalhi 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	150	35	150											
119	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	0	0	0	0		307	Coal Shortage								
120	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	220	220	220											
Barishal Zone Total						2265	2265	1617	1825	1750	1889	307	0							
121	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage								
122	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.								
123	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	35	0	35											
124	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0											
125	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	21	0	21											
126	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	12	91	50	91											
127	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	39	30	40											
128	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	34	34	34											
129	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	24	0	24											
129	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	150	201	200	200											
130	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0		220	Gas Shortage								
131	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	130	177	180	180											
132	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	414	414	414	414											
133	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	5	8	8	8											
134	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	52	8	52											
135	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	35	75	35	75											
136	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	68	35	70											
137	Ammura 50 MW PPS(Sinha)	HFO (NENP)	7x7.79	50	28	0	28	28	28											
138	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	4	0	6	0											
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	1312	1464	1400	1400											
Rajshahi Zone Total						3653	3631	2097	2731	2428	2672	291	100							
139	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Coal Shortage								
140	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling								
140	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	200	180	180	180											
141	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0											
142	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	31	52	34	50											
143	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0											
144	Majpara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	5	0	8	0											
145	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	36	75	0	75											
146	Lalmohona 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	28	0	30	0											
147	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	172	0	130	0											
Rangpur Zone Total						1030	950	472	307	382	305	85	85							
Sub-total: Plants in operation						24580	24171	13214.0	14498	14005	15300	2159	2447							
(B) Plants under long term maintenance/ contract expired																				
148	Jamalpur 95 MW PPI(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0											
149	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0											
150	Bosilla 108MW PPI(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0											
151	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	0	0	0	0	0											
152	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	0	0	0	0	0											
Sub-Total: Plants under long term maintenance/ contract expired						331	0	0	0	0	0	0	0							
Gross Total						24911	24171	13214	14498	14005	15300	2159	2447							
(C) Actual data of 03.09.23 (Yesterday) Sunday :																				
01.	Max. Demand at eve. peak (Generation end)	:	15100 MW, at =	21:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end):															
02.	Max. Demand at eve. peak (Sub-station end)	:	14399 MW, at =	21:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW								
03.	Highest Generation (Generation end)	:	14498 MW, at =	21:00 hrs	Dhaka	4976	4896	80	Mymensingh	1230	1130	100								
04.	Minimum Generation (Generation end)	:	10304 MW, at =	6:00 hrs	Chattogram	1311	1311	0	Sylhet	639	544	95								
05.	Day-peak Generation (Generation end)	:	13214 MW, at =	12:00 hrs	Khulna	1738	1738	0	Barishal	478	478	0								
06.	Evening-peak Generation (Generation end)	:	14498 MW, at =	21:00 hrs	Rajshahi	1603	1503	100	Rangpur	1040	910	130								
07.	Evening Peak Load-shed (Sub-station end)	:	575 MW, at =	21:00 hrs	Cumilla	1384	1314	70												
08.	Minimum Generation Forecast up to 8:00 hrs.	:	11369 MW, at =	5:00 hrs					Total	14399	13824	575								
09.	Generation shortfall at evening peak due to :	:			13.	Fuel cost :	(c) Coal = 674371175 Taka													
a) Gas/LF limitation	:	2074 MW				(a) Gas = 151173291 Taka	(b) Oil = 548444954 Taka													
d) Coal supply Limitation	:	85 MW					Total = 1373989421 Taka													
b) Low water level in Kaptai lake	:	0 MW																		
c) Plants under shut down/ maintenance	:	2447 MW																		
10.	Total Energy (Generation + India Import)	:	304.18 MKWh		14.	Maximum Temperature in Dhaka was :	35.4°C													
	By Gas = 133.978 MKWH			46.046 MKWH	15.	Export through East-West interconnections :														
	By Coal = 92.031 MKWH			4.710 MKWH		At evening peak-hour	:	13214 MW, at	21:00 hrs											
	By Solar= 2.831 MKWH					Maximum	:	760 MW, at	4:00 hrs											
11.	Total Gas Supplied	:	1118.59 MMCFD			Energy	:	0 MKWh												
(D) Forecast of 04.09.23 (Today) Monday :																				
01.	Maximum Demand	:	15300 MW (Generation end)		04.	Maximum Load-shed	:	0 MW					At evening peak (Sub-station end)							
02.	Maximum Generation	:	15300 MW (Generation end)		05.	Total Generation	:	321.84 MKWh												
03.	Reserve / Shortage	:	0 MW (Generation end)		06.	Probable Max. Temperature in Dhaka :	35.4° C													
* Coactive Power ** Imported Power																				
#Remarks: Highest Generation 15648 MW on 19-04-2023																				