

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

| Date :  |                                         | 4-Sep-23       |                     | Page -2          |                      |                  |                        |
|---------|-----------------------------------------|----------------|---------------------|------------------|----------------------|------------------|------------------------|
| Sl. No. | Name of the Power Stations              | Producer       | Installed Capacity  | Present Capacity | Peak Hour Generation | Enerov Generated | Remarks                |
|         |                                         |                | Unit No. X Capacity | MW               | MW                   | KWH              |                        |
| 1       | Ghorasal Repowered CCPP-Unit-3 (GT      | PDB            | 1*280               | 280              | 0                    | 0                | Under maint.           |
| 2       | Ghorasal Repowered CCPP Unit-4          | PDB            | 1*210               | 180              | 110                  | 2800125          | Gas shortage           |
| 3       | Ghorasal 365 MW CCPP Unit-7             | PDB            | 1*243+1*122         | 365              | 0                    | 0                | Air Compressor problem |
| 4       | Ghorasal 78.5 MW PP (MAX)               | QRPP           | 2*40                | 0                | 0                    | 0                | Contract Expired       |
| 5       | Ghorasal 108 MW PP (Regent)             | IPP            | 3*4*35              | 108              | 0                    | 0                | Gas shortage           |
| 6       | Haripur GTPP                            | SBU, PDB       | 2*32                | 20               | 0                    | 0                | Under maint.           |
| 7       | Haripur 412 MW CCPP                     | EGCB           | 1*273+1*139         | 412              | 407                  | 9521160          |                        |
| 8       | Haripur 360 MW CCPP(HPL)                | IPP            | 1*235+1*125         | 360              | 327                  | 7470000          |                        |
| 9       | Meghnaghat 450 MW CCPP(MPL)             | IPP            | 2*150+1*150         | 450              | 450                  | 9821000          |                        |
| 10      | Meghnaghat 100 MW PP (Summit)           | NECP           | 1*210               | 100              | 49                   | 966720           | Fuel shortage          |
| 11      | Madanganj 102 PP(Summit)                | IPP            | 2*110+1*110         | 335              | 0                    | 0                | Under maint.           |
| 12      | Madanganj-55 MW PP(Summit)              | IPP            | 6*17                | 102              | 95                   | 1551999          | Engine problem         |
| 13      | Keraniganj 100 MW PP (Powerpac)         | NENP           | 3*17.08+1*11.3      | 55               | 15                   | 366182           | Fuel shortage          |
| 14      | Narsingdi 22 MW PP (Doreen)             | SIPP, PDB      | 8*13.45             | 75               | 56                   | 741164           | Fuel shortage          |
| 15      | 210 MW Siddhirganj TPP                  | PDB            | 8*2.90              | 22               | 16                   | 409988           |                        |
| 16      | Siddhirganj 2*120 MW GTPP               | EGCB           | 1*210               | 115              | 0                    | 0                | Under maint.           |
| 17      | Siddhirganj 100 PP(Dutch Bangla)        | NENP           | 2*105               | 210              | 182                  | 2954000          | Gas shortage           |
| 18      | Siddhirganj 335 MW CCPP                 | EGCB           | 12*8.9              | 100              | 41                   | 635126           | Fuel shortage          |
| 19      | Gazipur 102 MW PP (Digital Power)       | IPP            | 1*217+1*118         | 335              | 318                  | 7079403          |                        |
| 20      | Katpotti 52 MW PP (Sinha)               | IPP            | 12*3.924            | 102              | 74                   | 782940           | Engine problem         |
| 21      | Karnalaghat 54 MW PP (Banco Energy)     | IPP            | 7*7.9               | 0                | 0                    | 0                | Fuel shortage          |
| 22      | Kodda 150 MW PP                         | IPP            | 3*18                | 54               | 35                   | 388800           | Engine problem         |
| 23      | Manikganj 55 MW PP (Northern)           | BPDB-RPCL      | 9*17.06             | 149              | 145                  | 1483200          | Engine problem         |
| 24      | Nababganj 55 MW PP (Southern power)     | IPP            | 3*19.3              | 55               | 35                   | 444436           | Engine problem         |
| 25      | Bosila 108 MW PP(CLC)                   | IPP            | 3*19.3              | 35               | 35                   | 477151           | Fuel shortage          |
| 26      | Summit Power (Madhabdi+Ashulia)         | SIPP, REB      | 12*8.735+1*3.5      | 0                | 0                    | 0                |                        |
| 27      | Maona 33 MW PP(Summit)                  | SIPP, REB      | 3*3.67+4*8.73       | 80               | 36                   | 859920           | Engine problem         |
| 28      | Rupganj 33 MW PP(Summit)                | SIPP, REB      | 4*8.73              | 33               | 33                   | 730200           |                        |
| 29      | Gazipur 52 MW PP                        | SIPP, REB      | 4*8.73              | 33               | 21                   | 463700           |                        |
| 30      | Tongi 80 MW GTTP                        | PDB            | 8*9.9               | 80               | 24                   | 268400           | Fuel shortage          |
| 31      | Kodda 300 MW PP Unit-2 (Summit)         | PDB            | 1*105               | 105              | 0                    | 0                |                        |
| 32      | Keraniganj 300 MW PP (APR)              | IPP            | 18*17.076           | 300              | 47                   | 1525527          | Fuel shortage          |
| 33      | Bramhangano 100 MW PP (Aggreko)         | IPP            | 256*1.4             | 300              | 0                    | 0                | Contract Expired       |
| 34      | Auraha 100MW PP (Aggreko)               | IPP            | 11*10.959           | 0                | 0                    | 0                | Contract Expired       |
| 35      | Kodda 149 MW PP Unit-1 (Summit)         | IPP            | 0.85*2+0.36*91      | 0                | 0                    | 0                | Contract Expired       |
| 36      | Gazipur 100 MW PP                       | IPP            | 8*18.45+8.97        | 149              | 149                  | 1328544          |                        |
| 37      | Meghnaghat 104 MW PP (OPCL)             | RPCL           | 6*17.5              | 105              | 88                   | 1115520          | Engine problem         |
| 38      | Manikganj 162MW PP(MPL)                 | IPP            | 18.5*6              | 104              | 53                   | 819840           | Fuel shortage          |
| 39      | Spectra Solar Plant Ltd                 | IPP            | 9*18                | 162              | 72                   | 1157760          | Fuel shortage          |
| 40      | Kanchan Purbanchal Power Generation Ltd | IPP            | 35                  | 35               | 0                    | 0                |                        |
|         | Meghnaghat Unique power                 | IPP            | 18.4*3              | 55               | 17                   | 457590           | Fuel shortage          |
|         | Dhaka area Total                        |                |                     | 5722             | 3410                 | 61234844         |                        |
| 41      | Chattogram TPP-1                        | PDB            | 1*210               | 180              | 115                  | 2700000          | Gas shortage           |
| 42      | Chattogram TPP-2                        | PDB            | 1*210               | 180              | 0                    | 0                | Gas shortage           |
| 43      | Razcar 25 MW PP (SolarTech)             | RPCL           | 2*9.9               | 25               | 17                   | 240552           | Engine problem         |
| 44      | Teknaf 20MW PP (SolarTech)              | IPP            | 20                  | 20               | 0                    | 108540           |                        |
| 45      | Palenga 50MW PP (Baraka)                | IPP            | 8*6.98              | 50               | 45                   | 296160           |                        |
| 46      | Kaptai Hydro: Unit-1,2,3,4, 5           | PDB            | 2*40+3*50           | 230              | 203                  | 4998953          |                        |
| 47      | Sikalbaha 225MW                         | PDB            | 1*150+1*75          | 225              | 147                  | 3429978          |                        |
| 48      | Sikalbaha Peaking GT                    | PDB            | 1*150               | 150              | 0                    | 0                | Under maint.           |
| 49      | Sikalbaha 105 MW PP (Baraka Sikalbaha)  | IPP            | 6*17.5              | 105              | 51                   | 1273781          | Fuel shortage          |
| 50      | Halhazari 100 MW peaking PP             | PDB            | 11*8.9              | 98               | 59                   | 871104           | Engine problem         |
| 51      | Dohazari -Kalaish 100 MW Peaking        | PDB            | 6*17                | 102              | 17                   | 415224           | Engine problem         |
| 52      | Julaha 100 MW Unit-1 (Acom)             | NENP           | 8*13.45             | 100              | 25                   | 509640           | Fuel shortage          |
| 53      | Julaha 100 MW PP Unit-3 (Acom)          | IPP            | 8*13.5              | 100              | 25                   | 509760           | Fuel shortage          |
| 54      | Barabkunda 22 MW PP (Regent)            | SIPP, PDB      | 8*2.90              | 22               | 13                   | 314256           | Engine problem         |
| 55      | Malancha, Ctg. EPZ (United)             |                | 5*8.73+3*9.34       | 0                | 18                   | 573600           |                        |
| 56      | Chattogram 108 MW PP (ECPV)             | IPP            | 16*7                | 108              | 0                    | 0                | Fuel shortage          |
| 57      | Kaptai 7 MW Solar PP                    | PDB            | 7.4 MW              | 7                | 0                    | 27360            |                        |
| 58      | Anwara 300 MW PP (United)               | IPP            | 17*17+24            | 300              | 257                  | 2436327          | Fuel shortage          |
| 59      | Jodice Power                            | IPP            | 3*18.55+1*3.6       | 54               | 54                   | 468079           |                        |
| 60      | Karnaphuli Power Ltd.                   | IPP            | 18.415*6+5.1        | 110              | 55                   | 1352390          | Fuel shortage          |
| 61      | Julaha unit-2 (Acom)                    | IPP            | 8*13.6              | 100              | 25                   | 584640           | Fuel shortage          |
| 62      | Anilma Energy Ltd.                      | IPP            | 6*21.2              | 116              | 51                   | 775309           | Fuel shortage          |
|         | Mirshana 150 MW                         | BPDB-RPCL      | 18.5*9              | 163              | 122                  | 1087272          | Fuel shortage          |
|         | SS Power 1                              | SS Power       | 0                   | 0                | 0                    | 8492726          | On test.               |
|         | Cor's Bazar Wind                        | IPP            | 66                  | 0                | 0                    | 12000            | On test.               |
|         | Matarbari 2*600 MW (CPGCL)              | CPGCL          | 0                   | 0                | 0                    | 0                | On test.               |
|         | Chattogram area Total                   |                |                     | 2545             | 1299                 | 31597651         |                        |
| 63      | Ashuganj TPP Unit- 3                    | APSCL          | 1*150               | 0                | 0                    | 0                | Contract Expired       |
| 64      | Ashuganj TPP Unit- 4                    | APSCL          | 1*150               | 0                | 0                    | 0                | Contract Expired       |
| 65      | Ashuganj TPP Unit- 5                    | APSCL          | 1*150               | 0                | 0                    | 0                | Contract Expired       |
| 66      | Ashuganj 225 MW CCPP                    | APSCL          | 1*142+1*75          | 221              | 183                  | 4352000          | Gas shortage           |
| 67      | Ashuganj 450 MW CCPP(North)             | APSCL          | 1*360               | 360              | 270                  | 7201000          | Gas shortage           |
| 68      | Ashuganj 450 MW CCPP(South)             | APSCL          | 1*360               | 360              | 240                  | 6262000          | Gas shortage           |
| 69      | Ashuganj 420 MW CCPP(East)              | APSCL          | 28*1+1*16*1         | 400              | 240                  | 5954100          | Gas shortage           |
| 70      | Ashuganj 50 MW PP                       | APSCL          | 14*3.968            | 45               | 0                    | 0                | Gas shortage           |
| 71      | Ashuganj 55 MW PP (Precision)           | QRPP           | 15*4                | 0                | 0                    | 0                | Contract Expired       |
| 72      | Ashuganj 195 MW PP (APSCL-United)       | IPP            | 20*9.73+1*16        | 195              | 0                    | 0                | Gas shortage           |
| 73      | Ashuganj 51 MW PP (Midland)             | IPP            | 6*9.34              | 51               | 51                   | 1121684          |                        |
| 74      | Ashuganj 150 MW PP (Midland)            | IPP            | 23*7.015            | 150              | 16                   | 205090           | Fuel shortage          |
| 75      | Titas 50 MW Peaking PP                  | PDB            | 6*8.92              | 50               | 0                    | 0                | Fuel shortage          |
| 76      | Chandpur 150 MW CCPP                    | PDB            | 1*106+1*57          | 163              | 0                    | 0                | Under maint.           |
| 77      | Chandpur 200 MW (Desh energy)           | IPP            | 12*18.4             | 200              | 0                    | 589920           | Fuel shortage          |
| 78      | Feni 22 MW PP (Doreen)                  | SIPP, PDB      | 8*2.90              | 22               | 15                   | 348408           | Engine problem         |
| 79      | Feni 11 MW PP (Doreen)                  | SIPP, REB      | 4*2.90              | 11               | 0                    | 193860           | Engine problem         |
| 80      | Import (Tijara)                         | Imported power | 0                   | 160              | 110                  | 2785760          |                        |
| 81      | Jangalia 33 MW PP (Summit)              | SIPP, PDB      | 4*8.73              | 33               | 32                   | 414600           | Engine problem         |
| 82      | Jangalia 52 MW PP (Lakdanari)           | IPP            | 6*8.92              | 52               | 34                   | 554602           | Engine problem         |
| 83      | Cumilla 25 MW PP (Summit)               | SIPP, REB      | 3*3.67+2*6.97       | 25               | 11                   | 230100           | Engine problem         |
| 84      | Daudkandi 200 MW PP (B.Trac)            | IPP            | 15*41.4             | 0                | 0                    | 0                | Contract Expired       |
| 85      | Feni Lanka Power                        | IPP            | 7*18.415+1*3.78     | 114              | 104                  | 2310780          | Engine problem         |
| 86      | Chowmuhan 113 MW                        | IPP            | 12*9.78+2*3.1       | 113              | 77                   | 829080           | Fuel shortage          |
| 87      | Bhairab 54.5 MW                         | IPP            | 3*18.2              | 54               | 17                   | 442800           | Fuel shortage          |
| 88      | Chandpur 115(Doreen)                    | IPP            | 4*18.5+2*22.5       | 115              | 0                    | 935040           | Fuel shortage          |
|         | Cumilla Area Total                      |                |                     | 2896             | 1400                 | 34714824         |                        |
| 89      | RPCL 210MW CCPP                         | IPP            | 4*36+1*70           | 228              | 34                   | 1025280          | Gas shortage           |
| 90      | Tangail 22 MW PP (Doreen)               | SIPP, PDB      | 8*2.90              | 22               | 16                   | 357372           | Engine problem         |
| 91      | Jamalpur 95 MW PP(Powerpac)             | IPP            | 12*8.924            | 0                | 0                    | 0                | Under maint.           |
| 92      | Sanishabari 3 MW Solar Plant            | IPP            | 1*3                 | 3                | 0                    | 11450            |                        |
| 93      | Mymensingh 200 MW PP (United)           | IPP            | 9*78*21             | 200              | 162                  | 2283200          | Fuel shortage          |
| 94      | Jamalpur 115 MW PP (United)             | IPP            | 9*78*12             | 84               | 115                  | 804040           | Fuel shortage          |
| 95      | Sulakhali 50 MW Solar PP                | IPP            | 50                  | 50               | 0                    | 320250           |                        |
| 96      | Tangail Palli Power Gen 22 MW           | IPP            | 4*8.7               | 22               | 6                    | 148320           | Fuel shortage          |
|         | Mymensingh Area Total                   |                |                     | 614              | 302                  | 4926272          |                        |
| 97      | Fenchugonj CCPP Phase-1                 | PDB            | 2*32+1*33           | 70               | 43                   | 974000           | Machine problem        |
| 98      | Fenchugonj CCPP Phase-2                 | PDB            | 2*35+1*35           | 90               | 0                    | 0                | Machine problem        |
| 99      | Kushara 163 MW CCPP (RPP)               | IPP            | 1*108+1*54          | 163              | 112                  | 2297700          | ST Under maint.        |
| 100     | Shahbazar 330 MW CCPP                   | PDB            | 3*110               | 330              | 0                    | 0                | Under maint.           |
| 101     | Fenchugonj 51 MW PP (Barakatullah)      | RPP            | 19*2.90             | 51               | 50                   | 1146000          |                        |
| 102     | Fenchugonj 44 MW (Energyprima)          | NENP           | 12*3.3+5*2          | 50               | 41                   | 968760           |                        |
| 103     | Hobdiganj 11 MW PP (Collidence-E)       | SIPP, REB      | 4*2.90              | 11               | 5                    | 178176           | Engine problem         |
| 104     | Shahjibazar GTTP Unit- 8 & 9            | PDB            | 2*35                | 66               | 58                   | 1350144          |                        |
| 105     | Shahjibazar 86 MW PP (Shahjibazar)      | RPP            | 32*2.90             | 86               | 86                   | 1896000          |                        |
| 106     | Shahjibazar 100 MW GTTP                 | PDB            | 1*100               | 100              | 0                    | 0                |                        |
| 107     | Sylhet 225 MW CCPP                      | PDB            | 1*142+1*89          | 231              | 179                  | 4689440          | Machine problem        |
| 108     | Sylhet 20 MW GTTP(E)                    | PDB            | 1*20                | 20               | 17                   | 385000           | Machine problem        |
| 109     | Sylhet 50 MW PP (EPL)                   | NENP           | 2*72                | 0                | 0                    | 0                | Contract Expired       |
| 110     | Shahjahanulla 25 MW PP                  | SIPP, REB      | 3*9.34              | 25               | 16                   | 353184           | Engine problem         |
| 111     | Bibiana-II 341 MW CCPP (Summit)         | IPP            | 1*222+1*119         | 341              | 300                  | 7023500          | FGMO                   |
| 112     | Bibiyana-III 400 MW CCPP                | PDB            | 285*1+134*1         | 400              | 367                  | 9146000          |                        |
| 113     | Sylhet 10MW PP (Desh)                   | RPP            | 6*1.95              | 10               | 10                   | 230580           |                        |
| 114     | Bibiyana South 400 MW                   | PDB            | 400 MW              | 363              | 265                  | 5951900          |                        |
|         | Sylhet Area Total                       |                |                     | 2427             | 1539                 | 36580384         |                        |
| 115     | Bheramara GTTP Unit-3                   | PDB            | 1*20                | 16               | 0                    | 0                |                        |
| 116     | Bheramara (HVDC )                       | Imported power | 2*500               | 1000             | 923                  | 21680000         |                        |
| 117     | Khulna 115 PP MW (KPCL-2)               | NENP           | 7*17                | 115              | 51                   | 895680           | Fuel shortage          |
| 118     | Fatipur 50 MW Peaking PP                | PDB            | 6*6.89              | 54               | 39                   | 216980           | Engine problem         |
| 119     | Khulna 225 MW CCPP                      | NWPGCL         | 1*150+1*75          | 230              | 0                    | 0                | Reserved               |
| 120     | Gopalganj 100 MW Peaking PP             | PDB            | 16*6.98             | 109              | 33                   | 227456           | Fuel shortage          |
| 121     | Bheramara 410 MW CCPP                   | NWPGCL         | 1*278+1*132         | 410              | 0                    | 0                | Gas shortage           |
| 122     | Noapara 40 MW PP (Khanjahan Ali)        | NENP           | 5*8.5               | 40               | 40                   | 591375           | Fuel shortage          |
| 123     | Noapara 100 MW PP (Bangla Trac)         | IPP            | 0                   | 0                | 0                    | 0                | Contract Expired       |
| 124     | Rupsha 105 MW PP (Orion rupsha)         | IPP            | 6*18.445            | 105              | 17                   | 413280           | Fuel shortage          |
| 125     | Madhumati 100 MW PP                     | NWPGCL         | 6*18                | 105              | 0                    | 0                | Fuel shortage          |
| 126     | Mongla Orion 100 MW Solar PP            | IPP            | 100                 | 100              | 0                    | 456480           |                        |
| 127     | Khulna 330 MW CCPP (OL)                 | BPDB           | 1*220+1*110         | 220              | 355                  | 8087636          |                        |
| 128     | Rampal 1320 MW (BFPCL)                  | NTPCB&PDB      | 660*2               | 617              | 571                  | 12538180         |                        |
| 129     | Kolna 225 MW CCPP (GAS)                 | NWPGCL         | 0                   | 0                | 0                    | 0                | On test.               |
|         | Khulna Area Total                       |                |                     | 3121             | 2029                 | 45507047         |                        |
| 130     | Barisal 110 MW PP (Summit )             | IPP            | 7*17.076            | 110              | 48                   | 473088           | Fuel shortage          |
| 131     | Bhola 33 MW PP (Venture)                | NENP           | 1*34.50             | 40               | 29                   | 641155           | Engine problem         |
| 132     | Bhola 225 MW CCPP                       | PDB            | 2*63+1*68           | 194              | 130                  | 2987000          | ST Under maint.        |
| 133     | Bhola 65 MW PP (Aggreko)                | QRPP           | 96*1.10             | 0                | 0                    | 0                | Contract Expired       |
| 134     | Payra 1320 MW                           | BCPCL          | 2*622               | 1244             | 1244                 | 29142200         |                        |
| 135     | Bhola Nutan Biddut BD LTD               | IPP            | 220                 | 220              | 219                  | 5062718          |                        |
| 136     | United Payra Power Ltd.                 | IPP            | 8*18.5+1*9.5        | 150              | 150                  | 1513200          |                        |
| 137     | Barisal 307 MW                          | IPP            | 307*1               | 307              | 0                    | 0                | Coal shortage.         |
|         | Barisal Area Total                      |                |                     | 2265             | 1620                 | 39819361         |                        |
| 138     | Baghabari 71 MW GTTP                    | PDB            | 1*71                | 71               | 0                    | 0                | Gas shortage           |
| 139     | Baghabari 100 MW GTTP                   | PDB            | 1*100               | 100              | 0                    | 0                | Gas shortage           |
| 140     | Baghabari 50 MW Peaking PP              | PDB            | 6*8.9               | 52               | 35                   | 161472           | Engine problem         |
| 141     | Bera 70 MW Peaking PP                   | PDB            | 9*8.29              | 71               | 14                   | 63526            | Engine problem         |
| 142     | Amnura 50 MW PP(Sinha)                  | NENP           | 7*7.79              | 28               | 28                   | 587790           |                        |
| 143     | Katalkhati 50 MW PP (Northern)          | QRPP           | 8*8.9               | 50               | 42                   | 636645           | Engine problem         |
| 144     | Katalkhati 50 MW Peaking PP             | PDB            | 6*8.7               | 50               | 39                   | 218305           | Engine problem         |
| 145     | Sirajgonj Unit-1 225MW                  | NWPGCL         | 1*150+1*75          | 220              | 144                  | 4004873          | Gas shortage           |
| 146     | Sirajgonj Unit-2 225MW                  | NWPGCL         | 1*150+1*75          | 220              | 0                    | 0                |                        |
| 147     | Sirajgonj Unit-3 225MW                  | NWPGCL         | 1*141               | 220              | 122                  | 3537927          | Gas shortage           |
| 148     | Sirajgonj 400 MW CCPP Unit-4            | SNWPGCL        | 1*282+1*132         | 414              | 236                  | 7020436          | Gas shortage           |
| 149     | Sanlahar 50 MW Peaking PP               | PDB            | 6*8.7               | 50               | 24                   | 107920           | Engine problem         |
| 150     | Bogra 22 MW PP (GBB)                    | RPP            | 6*4                 | 0                | 0                    | 0                | Contract               |