

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 3564667, 9551095

Month September, 2023					Day : Wednesday				Date : 06.09.23				
Probable Maximum Demand : 14500 MW					Probable Maximum Generation : 15445 MW								
Water Level of Kapitai Lake at 06:00 AM					Yesterday = 106.07 ft				Today = 106.11 ft				
					Rule Curve = 100.15 ft								
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	05.09.23 (Yesterday)		06.09.23 (Today)		05.09.23 (Yesterday)		06.09.23 (Today)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/Water Limitation MW		Machines shut down (MW)		
					Day	Evening	Day	Evening			Description/ Remarks	Probable start-up date	
(A) Plants in operation:													
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260		Under project work
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	110	110	180	180				
3	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	170	170	0	0				
4	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0				
5	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	40	40	108			Gas Shortage
6	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105			Gas Shortage
7	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0				
8	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	320	326	330	330				
9	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450				
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115		Under Overhauling
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	403	407	412	412				
11	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	116	184	150	180				
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	308	317	330	330				
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	10	330		335		Under maint.
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	24	15	15	15				
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	50	42	32	64				
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	19	18	19				
17	Summit Power(Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	19	37	37	37				
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33				
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	26	29	30	30				
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	25	8	25				
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	70	88	70	100				
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	82	147	48	150				
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	35	17	35				
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	135	97	80	130				
25	Kodda 140 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	105	105	17	149				
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	25x11.4	300	300	0	0	0	0				
27	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	55	35	55				
28	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	35	35	35				
29	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	35	53	34	53				
30	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	108	72	54	108				
31	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	34	0	35	0				
32	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	15	17	17	17				
33	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	33	33	32	40				
34	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	48	48	50	50				
35	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	95	80	95	95				
36	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	34	56	55	55				
	Meghnaghat Unique Power	Gas				0	0	0	0				
Dhaka Zone Total				5904	5722	2918	3085	2749	3547	213	710		
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	205	205	203	203				
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	110	115	115	115				
39	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180		Under maint.
40	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	2	0	5	0				
40	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	17	8	17				
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	16	0	20	0				
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	45	50	50				
43	Sikalbaha 105 MW PP (Baraka Sikabaha)	HFO (IPP)	6x18.415	105	105	51	51	51	51				
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150		Under maint.
45	Sikalbaha 225 MW CAPP	Gas (PDB)	1 x 150+1 x 75	225	225	107	224	220	220				
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	105	264	70	265				
47	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	25	25	25				
48	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	17	17	17	17				
49	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	37	72	40	70				
50	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	11	13	14	14				
*	Malancha, Ctg.EPZ (United)	Gas	5x8.73+3x9.34			3	33	25	35				
51	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	12	0	12				
52	Sikalbaha 54 MW PP (Jodiac Power)	HFO (IPP)	3x18.5+1x3.6	54	54	17	54	17	54				
53	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	55	63	55	55				
54	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	25	25	25	25				
55	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	25	25	25	25				
56	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	34	51	34	51				
57	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	53	159	17	150				
	SS Power Unit-1	Coal (IPP)				626	0	0	0				
	Matarbari 2*600 MW (CPGCL)	Coal				0	0	0	0				Test run
	Cox's Bazar Wind PP	(Wind) (IPP)				0	3	10	10				
Chattogram Zone Total				2605	2545	1538	1473	1046	1464	0	330		
58	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	0	25	25	25	20			Gas Shortage
59	Ashuganj 225 MW CAPP	Gas (APSCCL)	1x142+1*75	221	221	194	203	200	200				
60	Ashuganj 450 MW CAPP(South)	Gas (APSCCL)	1x360	360	360	240	305	280	300	55			Gas Shortage
61	Ashuganj 450 MW CAPP(North)	Gas (APSCCL)	1x361	360	360	270	0	0	0		360		Under maint.
62	Ashuganj 420 MW CAPP(East)	Gas (APSCCL)	1x284+1x116	400	400	240	401	400	400				
63	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*116	195	195	0	16	16	80	179			Gas Shortage
64	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51				
65	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	5	35	6	30				
66	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	0				
67	Chandpur 150 MW CAPP	Gas (PDB)	1x106+1x57	163	163	0	0	0	0		163		Under maint.
68	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	72	48	17	34				
69	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	15	17	16	16				
70	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
71	Jangalia 33 MW PP (Summit))	Gas (SIPP, PDB)	4x8.73	33	33	32	33	33	33				
72	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	32	34	43	43				
73	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	11	11	11	11				
74	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	105	17	106				
75	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	59	57	26	65				
76	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17				
77	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	0	0	0	0				
**	Imphort (Tripura)	India		160	160	110	120	149	165				
Cumilla Zone Total				2904	2896	1376	1489	1318	1587	254	523		
78	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	25	75	35	85	127			Gas Shortage
79	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	16	16	16	16				
80	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	36	84	37	95				
81	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	114	160	115	145				
82	Sarishabani 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0				
83	Sutiakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	0	0	50	0				
84	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	6	6	6	6				
Mymensingh Zone Total				622	614	249	341	261	347	127	0		

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	05.09.23 (Yesterday)		06.09.23 (Today)		05.09.23 (Yesterday)		Status of Machines under shut-down/ Maintenance						
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation		Description/ Remarks	Probable start-up date					
						Day	Evening	Day	Evening	MW	Machines shut down (MW)							
85	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	24	0	0	0		70	GT-1 Under maint.						
86	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	0	30	30	30		60	GT-4 Under maint.						
87	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	45	50	50	50									
88	Kushlari 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	112	112	112	112		54	ST Under maint.						
89	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	5	11	11									
90	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	49	56	60	60									
91	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.						
92	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	77	86	86	86									
93	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	181	178	180	181									
94	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	16	17	17	17									
95	Sylhet 10MW PP (Desht)	Gas (RPP)	6x1.95	10	10	10	10	10	10									
96	Shahjibazurulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	16	16	16									
97	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	270	290	300	300									
98	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	366	368	400	400									
99	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	252	256	255	255									
100	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work						
101	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	36	41	40	40									
Sylhet Zone Total						2472	2427	1457	1515	1567	1568	0	614					
102	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0									
103	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0		410	Gas Shortage						
104	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	9	25	25	40									
105	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	16	40	50									
106	Khulna 225 MW CCPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0									
107	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	17	17	17	17									
108	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	0									
109	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	48	0	100	0									
110	Khulna 115 MW PP (KPCCL-2)	HFO (NENP)	7x17	115	115	61	80	66	98									
111	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	32	40	40	40									
112	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	521	571	520	570									
113	Khulna 330 MW CCPP (GT)	Gas/HSD (PDB)	1x220	220	220	361	355	330	330									
**	Bheramara (HVDG)	India		1000	1000	927	804	943	943									
Khulna Zone Total						3125	3121	1976	1908	2081	2088	410	0					
114	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	48	96	110									
115	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	22	34	23	33									
116	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	124	126	132	132									
117	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	1244	1244	1244	1244									
118	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	35	150	35	150									
119	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	0	0	0	0		307	Coal Shortage						
120	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	220	220	220									
Barishal Zone Total						2265	2265	1661	1822	1750	1889	307	0					
121	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage						
122	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.						
123	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	35	0	35									
124	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0									
124	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	11	0	21									
125	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	46	91	50	91									
126	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	39	30	40									
127	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	8	42	34	42									
128	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	24	0	24									
129	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	148	158	160	160		52	Gas Shortage						
130	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0		220	Gas Shortage						
131	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	125	134	180	180		86	Gas Shortage						
132	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	253	312	414	414		102	Gas Shortage						
133	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8									
134	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	52	8	52									
135	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	35	75	35	75									
136	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	68	35	70									
137	Ammura 50 MW PPI(Sinha)	HFO (NENP)	7x7.79	50	50	28	28	28	28									
138	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0									
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	1361	1462	950	1400									
Rajshahi Zone Total						3653	3631	2060	2539	1938	2640	531	100					
139	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Coal Shortage						
140	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0									
140	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	180	180	180	180									
141	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0									
142	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x2*3	113	113	39	62	34	60									
143	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0									
144	Maipara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	7	0	8	0									
145	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	36	75	35	75									
146	Lalmoharhat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	36	0	30	0									
147	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	178	0	130	0									
Rangpur Zone Total						1030	950	476	317	417	315	85	85					
Sub-total: Plants in operation						24500	24171	13711.0	14489	13127	15445	1927	2362					
(B) Plants under long term maintenance/ contract expired																		
148	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0									
149	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0									
150	Bosilla 108MW PPI(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0									
151	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	0	0	0	0	0									
152	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	0	0	0	0	0									
Sub-total: Plants under long term maintenance/ contract expired						331	0	0	0	0	0	0	0					
Gross Total						24911	24171	13711.0	14489	13127	15445	1927	2362					
(C) Actual data of 05.09.23 (Yesterday) Tuesday :																		
01.	Max. Demand at eve. peak (Generation end)	:	15350 MW, at =	21:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end):												
02.	Max. Demand at eve. peak (Sub-station end)	:	14500 MW, at =	21:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed						
03.	Highest Generation (Generation end)	:	14489 MW, at =	21:00 hrs	MW	MW	MW	MW	MW	MW	MW	MW						
04.	Minimum Generation (Generation end)	:	12081 MW, at =	7:00 hrs	Dhaka	5117	5075	42	Mymensingh	1229	1084	145						
05.	Day-peak Generation (Generation end)	:	13711 MW, at =	12:00 hrs	Chattogram	1316	1131	185	Sylhet	619	554	65						
06.	Evening-peak Generation (Generation end)	:	14489 MW, at =	21:00 hrs	Khulna	1787	1675	112	Barishal	487	487	0						
07.	Evening Peak Load-shed (Sub-station end)	:	822 MW, at =	21:00 hrs	Rajshahi	1647	1617	30	Rangpur	1001	877	124						
08.	Minimum Generation Forecast up to 8:00 hrs.	:	11652 MW, at =	5:00 hrs	Cumilla	1298	1179	119										
09.	Generation shortfall at evening peak due to :	:			Total				14500									
a) Gas/LF limitation	:	1842 MW			Fuel cost :				(c) Coal = 69591292 Taka									
d) Coal supply Limitation	:	85 MW			(a) Gas = 153331060 Taka				Total = 1442116384 Taka									
b) Low water level in Kaptai lake	:	0 MW			(b) Oil = 590194032 Taka													
c) Plants under shut down/ maintenance	:	2362 MW			Maximum Temperature in Dhaka was : 37.3°C													
10.	Total Energy (Generation + India Import)	:	314.24 MKWh		Export through East-West interconnections :													
	By Gas = 139.044 MKWh		By Oil = 55.125 MKWh		At evening peak-hour :													
	By Coal = 87.906 MKWh		By Hydro = 4.810 MKWh		Maximum :													
	By Solar = 2.934 MKWh				Energy :													
11.	Total Gas Supplied	:	1114.73 MMCFD		Maximum Temperature in Dhaka : 37.3°C													
(D) Forecast of 06.09.23 (Today) Wednesday :																		
01.	Maximum Demand	:	14500 MW	(Generation end)	04.	Maximum Load-shed : 0 MW At evening peak (Sub-station end)												
02.	Maximum Generation	:	15445 MW	(Generation end)	05.	Total Generation : 314.48 MKWh												
03.	Reserve / Shortage	:	945 MW	(Generation end)	06.	Probable Max. Temperature in Dhaka : 37.3°C												