

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 3564667, 9551095

Month September, 2023					Day : Thursday				Date : 07.09.23				
Probable Maximum Demand : 15000 MW					Probable Maximum Generation : 14840 MW								
Water Level of Kapitai Lake at 06:00 AM					Yesterday = 106.11 ft		Today = 106.10 ft		07.09.23		Rule Curve = 100.38 ft.		
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	06.09.23 (Yesterday)		07.09.23 (Today)		06.09.23 (Yesterday)		07.09.23 (Today)		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/Water Limitation MW		Machines shut down (MW)		
					Day	Evening	Day	Evening			Description/ Remarks	Probable start-up date	
(A) Plants in operation:													
1	Ghorasal Repowered CAPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work	
2	a) Ghorasal Repowered CAPP Unit-4	Gas (PDB)	1 x 210	210	180	210	210	210	210				
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0				
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0				
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	58	74	75	75	34	Gas Shortage		
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage		
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0				
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	328	332	330	330				
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450				
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	403	405	412	412				
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	153	149	100	100				
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	321	328	330	330				
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	60	94	0	0		241	Under maint.	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	15	55	15				
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	33	74	33	74				
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	0	18	19				
17	Summit Power(Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	38	19	37	37				
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33				
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	28	32	30	30				
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	25	8	25				
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	35	88	70	100				
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	82	149	64	150				
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	35	17	35				
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	87	145	145	98				
25	Kodda 140 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	17	135	17	149				
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	25x11.4	300	300	0	0	0	0				
27	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	17	55	55	55				
28	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	35	35	35				
29	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	45	53	34	53				
30	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	54	144	54	108				
31	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	36	0	35	0				
32	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	17	17	17				
33	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	25	34	16	24				
34	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	48	49	32	32				
35	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	80	82	80	80				
36	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	44	45	55	55				
	Meghnaghat Unique Power	Gas				0	0	0	0				
Dhaka Zone Total					5904	5722	2796	3306	2847	3131	139	616	
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	203	202	203	203				
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	115	115	115	115				
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.	
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	3	0	5	0				
40	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	16	8	17				
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	7	0	20	0				
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	50	6	50				
43	Sikalbaha 105 MW PP (Baraka Sikabaha)	HFO (IPP)	6x18.415	105	105	17	34	34	34				
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.	
45	Sikalbaha 225 MW CAPP	Gas (PDB)	1 x 150+1 x 75	225	225	218	225	220	220				
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	70	267	70	265				
47	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	38	25	25				
48	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	17	17	17	17				
49	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	31	70	32	70				
50	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	11	13	14	14				
*	Malancha, Ctg.EPZ (United)	Gas	5x8.73+3x9.34			10	24	5	25				
51	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	12				
52	Sikalbaha 54 MW PP (Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	54	17	54				
53	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	55	55	55	55				
54	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	25	25	25	25				
55	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	25	35	25	25				
56	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	34	34	34	51				
57	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	17	158	17	150				
	SS Power Unit-1	Coal (IPP)				0	0	0	0				
	Matarbari 2*600 MW (CPGCL)	Coal				0	0	0	0			Test run	
	Cox's Bazar Wind PP	(Wind) (IPP)				12	14	10	10				
Chattogram Zone Total					2605	2545	926	1446	957	1437	0	330	
58	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	38	46	49	49				
59	Ashuganj 225 MW CAPP	Gas (APSCL)	1x142+1*75	221	221	198	0	200	200				
60	Ashuganj 450 MW CAPP(South)	Gas (APSCL)	1x360	360	360	290	305	300	300	55	Gas Shortage		
61	Ashuganj 450 MW CAPP(North)	Gas (APSCL)	1x361	360	360	0	0	0	0		360	Under maint.	
62	Ashuganj 420 MW CAPP(East)	Gas (APSCL)	1x284+1x116	400	400	401	0	0	0				
63	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*116	195	195	36	185	190	190				
64	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51				
65	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	5	31	6	30				
66	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	0				
67	Chandpur 150 MW CAPP	Gas (PDB)	1x106+1x57	163	163	0	0	0	0		163	Under maint.	
68	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	70	102	68	100				
69	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	17	18	16	16				
70	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
71	Jangalia 33 MW PP (Summit))	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33				
72	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	42	51	51	51				
73	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	11	11	11	11				
74	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	88	34	106				
75	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	27	62	28	65				
76	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	10	17	17				
77	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	0	0	0	0				
**	Imphort (Tripura)	India		160	160	138	156	149	165				
Cumilla Zone Total					2904	2896	1402	1160	1214	1395	55	523	
78	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	28	50	35	85	152	Gas Shortage		
79	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	17	16	16	16				
80	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	37	85	37	95				
81	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	114	162	115	145				
82	Sarishabani 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0				
83	Sutiakhali 50 MW Solar PP	Solar (IPP)	1x50	50	50	51	0	50	0				
84	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	6	6	6	6				
Mymensingh Zone Total					622	614	255	319	261	347	152	0	

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	06.09.23 (Yesterday)		07.09.23 (Today)		06.09.23 (Yesterday)		Status of Machines under shut-down/ Maintenance				
						Actual Peak Generation (MW)	Probable Peak Generation (MW)	Gen. shortfall for : Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date					
												Day	Evening	Day	Evening	
85	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	20	30	30	30		40	GT-1 Under maint.				
86	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	30	30	30	30		60	GT-4 Under maint.				
87	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	50	50	50	50							
88	Kushiana 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	112	112	112	112		54	ST Under maint.				
89	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	5	11	11							
90	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	54	56	60	60							
91	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.				
92	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	78	84	86	86							
93	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	182	181	180	181							
94	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	16	17	17	17							
95	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10							
96	Shahjibazar 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16							
97	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	305	265	300	300							
98	Bibiana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	369	368	400	400							
99	Bibiana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	247	260	255	255							
100	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work				
101	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	37	41	40	40							
Sylhet Zone Total						2472	2427	1531	1525	1597	1598	0	584			
102	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0							
103	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0		410	Gas Shortage				
104	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	10	30	25	40							
105	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	40	40	50							
106	Khulna 225 MW CCPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0							
107	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	17	17	17	17							
108	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	0							
109	Mongla Orion 100 MW Solar PP	Solar (IPP)	100	100	51	0	100	0	0							
110	Khulna 115 MW PP (KPCCL-2)	HFO (NENP)	7x17	115	115	63	79	66	98							
111	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	40	40	40	40							
112	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	520	573	520	570							
113	Khulna 330 MW CCPP (GT)	Gas/HSD (BDFB)	1x220	220	220	350	350	330	330							
**	Bheramara (HVDG)	India		1000	1000	924	820	943	943							
Khulna Zone Total						3125	3121	1975	1949	2081	2088	410	0			
114	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	64	96	110							
115	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	25	32	23	33							
116	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	124	120	132	132							
117	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	1244	1244	1244	1244							
118	Potukhal 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	35	150	35	150							
119	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	0	0	0	0		307	Coal Shortage				
120	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	190	220	220	220							
Barishal Zone Total						2265	2265	1634	1830	1750	1889	307	0			
121	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage				
122	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.				
123	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	35	0	35							
124	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0							
125	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	17	0	21							
126	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	41	81	50	91							
127	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	39	30	40							
128	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	34	42							
129	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	24	24	24	24							
130	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	153	155	160	160		55	Gas Shortage				
131	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0		220	Gas Shortage				
132	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	127	131	180	180		89	Gas Shortage				
133	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	270	298	414	414		116	Gas Shortage				
134	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	0	8	8	8							
135	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	52	8	52							
136	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	35	75	35	75							
137	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	50	35	70							
138	Ammura 50 MW PPS(Sinha)	HFO (NENP)	7x7.79	50	28	21	28	28	28							
139	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	3	0	6	0							
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	961	1322	1300	1400							
Rajshahi Zone Total						3653	3631	1678	2315	2312	2640	551	100			
139	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Coal Shortage				
140	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling				
140	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	180	200	180	180							
141	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0							
142	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	30	56	34	60							
143	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0							
144	Maipara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	6	0	8	0							
145	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	74	35	75							
146	Lalmohith 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	35	0	30	0							
147	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	173	0	130	0							
Rangpur Zone Total						1030	950	424	330	417	315	85	85			
Sub-total: Plants in operation						24580	24171	12621.0	14180	13436	14840	1699	2238			
(B) Plants under long term maintenance/ contract expired																
148	Jamalpur 95 MW PPI(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0							
149	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0							
150	Bosilla 108MW PPI(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0							
151	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	0	0	0	0	0							
152	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	0	0	0	0	0							
Sub-total: Plants under long term maintenance/ contract expired						331	0	0	0	0	0	0	0			
Gross Total						24911	24171	12621	14180	13436	14840	1699	2238			
(C) Actual data of 06.09.23 (Yesterday) Wednesday :																
01.	Max. Demand at eve. peak (Generation end)	:	14700 MW, at =	21:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end):											
02.	Max. Demand at eve. peak (Sub-station end)	:	13965 MW, at =	21:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed				
03.	Highest Generation (Generation end)	:	14180 MW, at =	21:00 hrs	MW	MW	MW	MW	MW	MW	MW	MW				
04.	Minimum Generation (Generation end)	:	11652 MW, at =	6:00 hrs	Dhaka	4731	4681	50	Mymensingh	1177	955	222				
05.	Day-peak Generation (Generation end)	:	12621 MW, at =	12:00 hrs	Chattogram	1308	1308	0	Sylhet	638	533	105				
06.	Evening-peak Generation (Generation end)	:	14180 MW, at =	21:00 hrs	Khulna	1792	1792	0	Barishal	471	471	0				
07.	Evening Peak Load-shed (Sub-station end)	:	497 MW, at =	21:00 hrs	Rajshahi	1583	1563	20	Rangpur	871	871	0				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	11403 MW, at =	5:00 hrs	Cumilla	1394	1294	100								
09.	Generation shortfall at evening peak due to :	:			Total				13965	13468	497					
a)	Gas/LF limitation	:	1614 MW		Fuel cost :				(c) Coal = 664453568 Taka							
d)	Coal supply Limitation	:	85 MW		(a) Gas = 156528776 Taka				Total = 1386599915 Taka							
b)	Low water level in Kaptai lake	:	0 MW		(b) Oil = 565617571 Taka											
c)	Plants under shut down/ maintenance	:	2238 MW		14. Maximum Temperature in Dhaka was : 36°C											
10.	Total Energy (Generation + India Import)	:	304.49 MKWh		15. Export through East-West interconnections :											
	By Gas = 140.810 MKWH		By Oil = 53.267 MKWh		At evening peak-hour				: 12621 MW, at 21:00 hrs							
	By Coal = 77.852 MKWH		By Hydro = 4.769 MKWh		Maximum				: 920 MW, at 21:00 hrs							
	By Solar = 2.638 MKWH				Energy				: 0 MKWh							
11.	Total Gas Supplied	:	1102.90 MMCFD													
(D) Forecast of 07.09.23 (Today) Thursday :																
01.	Maximum Demand	:	15000 MW (Generation end)		04.	Maximum Load-shed	:	147 MW	At evening peak (Sub-station end)							
02.	Maximum Generation	:	14840 MW (Generation end)		05.	Total Generation	:	322.10 MKWh								
03.	Reserve / Shortage	:	-160 MW (Generation end)		06.	Probable Max. Temperature in Dhaka :	37.3									