

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 3564667, 9551095

Month September, 2023					Day : Friday				Date : 08.09.23				
Probable Maximum Demand : 13000 MW					Probable Maximum Generation : 14876 MW								
Water Level of Kapitai Lake at 06:00 AM					Yesterday = 106.10 ft		Today = 106.10 ft		08.09.23 (Today)		Rule Curve = 100.38 ft		
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	07.09.23 (Yesterday)		08.09.23 (Today)		07.09.23 (Yesterday)		08.09.23 (Today)		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/Water Limitation MW		Machines shut down (MW)		
					Day	Evening	Day	Evening	Description/ Remarks		Probable start-up date		
(A) Plants in operation:													
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	170	210	180	180				
3	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0		190	Under maint.	
4	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0				
5	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	75	75	75	75	33		Gas Shortage	
6	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage	
7	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0				
8	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	333	327	330	330				
9	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450				
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	402	412	412	412				
11	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	91	95	100	100				
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	318	328	330	330				
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	7	0	0		328	was under maint.	
14	Madangan-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	15	15	15				
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	24	41	33	74				
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	10	17	19	19				
17	Summit Power(Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	38	38	38	38				
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	30	33	33	33				
19	Rugganji 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	30	32	33	33				
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	25	8	25				
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	52	105	70	105				
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	64	150	64	150				
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	35	17	35				
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	150	95	84	95				
25	Kodda 140 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	112	149	17	149				
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	25x11.4	300	300	0	0	0	0				
27	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	55	55	55				
28	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	35	35	35				
29	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	20	72	34	70				
30	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	54	108	54	108				
31	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	21	0	35	0				
32	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	17	17	17				
33	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	17	24	16	24				
34	Meghnaghat 100 MW(IE)	HFO (NENP)	12x8.9	100	100	32	33	32	32				
35	Madangan 102 PP(Summit)	HFO (NENP)	6x17	102	102	80	82	80	80				
36	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	36	33	55	55				
	Meghnaghat Unique Power	Gas				0	0	0	0				
Dhaka Zone Total					5904	5722	2776	3098	2721	3124	138	893	
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	203	202	203	203				
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	115	105	115	115				
39	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.	
40	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	6	0	5	0				
41	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	16	8	17				
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	5	0	20	0				
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	25	50	6	50				
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	34	51	34	51				
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.	
46	Sikalbaha 225 MW CAPP	Gas (PDB)	1 x 150+1 x 75	225	225	218	222	225	225				
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	70	264	70	265				
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	25	25	25				
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	0	17	17				
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	23	65	32	70				
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	13	13	14	14				
*	Malancha, Ctg.EPZ (United)	Gas	5x8.73+3x9.34			3	33	30	30				
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	12	0	12				
53	Sikalbaha 54 MW PP (Jodiad Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	54				
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	55	55	55	55				
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	25	25	25	25				
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	25	25	25	25				
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	51	51	34	51				
58	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	35	158	17	158				
	SS Power Unit-1	Coal (IPP)				0	0	0	0			Test run	
	Matarbari 2*600 MW (CPGCL)	Coal				0	0	0	0			Test run	
	Cox's Bazar Wind PP	(Wind) (IPP)				24	19	10	10				
Chattogram Zone Total					2605	2545	980	1408	987	1472	0	330	
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	45	49	49	49				
60	Ashuganj 225 MW CAPP	Gas (APSCCL)	1x142+1*75	221	221	198	179	200	200				
61	Ashuganj 450 MW CAPP(South)	Gas (APSCCL)	1x360	360	360	330	270	300	300				
62	Ashuganj 450 MW CAPP(North)	Gas (APSCCL)	1x361	360	360	0	0	0	0		360	Under maint.	
63	Ashuganj 420 MW CAPP(East)	Gas (APSCCL)	1x284+1x116	400	400	0	0	0	0		400	Under maint.	
64	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*116	195	195	199	199	190	190				
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	51	51	51				
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	12	120	13	150				
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	0				
68	Chandpur 150 MW CAPP	Gas (PDB)	1x106+1x57	163	163	0	0	0	0		163	Under maint.	
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	68	102	68	100				
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	15	17	16	16				
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
72	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33				
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	40	51	51	51				
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	12	12	12	12				
75	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	34	88	34	106				
76	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	28	74	28	75				
77	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17				
78	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	0	0	0	0				
**	Import (Tirupura)	India		160	160	154	140	149	165				
Cumilla Zone Total					2904	2896	1239	1413	1222	1526	0	923	
79	RPCL 210MW CAPP	Gas (IPP)	4x35+1x70	210	202	30	51	35	85		151	Gas Shortage	
80	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	16	16	16	16				
81	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	0	104	37	95				
82	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	145	144	115	145				
83	Sarishabani 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0				
84	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	52	0	50	0				
85	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	6	6	6	6				
Mymensingh Zone Total					622	614	251	321	261	347	151	0	

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	07.09.23 (Yesterday)		08.09.23 (Today)		07.09.23 (Yesterday)		Status of Machines under shut-down/ Maintenance				
						Actual Peak Generation (MW)	Probable Peak Generation (MW)	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date					
												Day	Evening	Day	Evening	
85	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	30	30	30		40	GT-1 Under maint.				
86	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	30	39	39	39		51	GT-4 Under maint.				
87	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	44	50	50	50							
88	Kushlari 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	112	112	112	112		54	ST Under maint.				
89	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	8	11	11							
90	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	58	56	60	60							
91	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.				
92	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	78	86	86	86							
93	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	181	180	185	185							
94	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	16	17	17	17							
95	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10							
96	Shahjibazar 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16							
97	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	305	300	300	300							
98	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	404	366	400	400							
99	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	252	260	50	400							
100	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work				
101	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	42	43	43	43							
Sylhet Zone Total						2472	2427	1589	1573	1409	1759	0	575			
102	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0							
103	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0		410	Gas Shortage				
104	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	10	35	25	40							
105	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	41	40	50							
106	Khulna 225 MW CCPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0							
107	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	17	53	17	17							
108	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	0							
109	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	69	0	100	0							
110	Khulna 115 MW PP (KPCCL-2)	HFO (NENP)	7x17	115	115	31	80	66	81							
111	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	16	16	24	40							
112	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	519	573	520	570							
113	Khulna 330 MW CCPP (GT)	Gas/HSD (BDFB)	1x220	220	220	156	119	330	330							
**	Bheramara (HVDG)	India		1000	1000	919	788	938	938							
Khulna Zone Total						3125	3121	1737	1705	2060	2066	410	0			
114	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	48	16	48							
115	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	21	29	23	33							
116	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	124	130	132	132							
117	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	1244	1220	1244	1244							
118	Potukhalhi 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	35	150	35	150							
119	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	0	0	0	0		307	Coal Shortage				
120	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	220	0	0							
Barishal Zone Total						2265	2265	1660	1797	1450	1607	307	0			
121	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage				
122	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.				
123	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	35	0	35							
124	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0							
124	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	17	0	21							
125	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	91	50	91							
126	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	39	30	40							
127	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	34	34	42							
128	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	24	24	24	24							
129	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	154	153	160	160		57	Gas Shortage				
130	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0		220	Gas Shortage				
131	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	130	138	140	180		82	Gas Shortage				
132	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	266	334	414	414		80	Gas Shortage				
133	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8							
134	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	52	8	52							
135	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	35	75	35	75							
136	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	70	35	70							
137	Ammura 50 MW PPS(Sinha)	HFO (NENP)	7x7.79	50	50	28	28	28	28							
138	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0							
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	1313	1417	1300	1400							
Rajshahi Zone Total						3653	3631	2006	2515	2272	2640	510	100			
139	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Coal Shortage				
140	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling				
140	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	180	180	180	180							
141	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0							
142	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x2*3	113	113	34	41	34	80							
143	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0							
144	Maipara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	6	0	8	0							
145	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	74	35	75							
146	Lalmohona 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	15	0	30	0							
147	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	121	0	130	0							
Rangpur Zone Total						1030	950	356	295	417	335	85	85			
Sub-total: Plants in operation						24500	24171	12594.0	14125	12799	14876	1601	2906			
(B) Plants under long term maintenance/ contract expired																
148	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0							
149	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0							
150	Bosilla 108MW PP(PLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0							
151	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	0	0	0	0	0							
152	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	0	0	0	0	0							
Sub-total: Plants under long term maintenance/ contract expired						331	0	0	0	0	0	0	0			
Gross Total						24911	24171	12594	14125	12799	14876	1601	2906			
(C) Actual data of 07.09.23 (Yesterday) Thursday :																
01.	Max. Demand at eve. peak (Generation end)	:	14500 MW, at =	21:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end):											
02.	Max. Demand at eve. peak (Sub-station end)	:	13875 MW, at =	21:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed				
03.	Highest Generation (Generation end)	:	14125 MW, at =	21:00 hrs	MW	MW	MW	MW	MW	MW	MW	MW				
04.	Minimum Generation (Generation end)	:	11403 MW, at =	8:00 hrs	Dhaka	4903	4903	0	Myrmersingh	1064	1054	10				
05.	Day-peak Generation (Generation end)	:	12594 MW, at =	12:00 hrs	Chattogram	1365	1365	0	Sylhet	648	598	50				
06.	Evening-peak Generation (Generation end)	:	14125 MW, at =	21:00 hrs	Khulna	1651	1641	10	Barishal	428	428	0				
07.	Evening Peak Load-shed (Sub-station end)	:	358 MW, at =	21:00 hrs	Rajshahi	1378	1378	0	Rangpur	1017	909	108				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	10465 MW, at =	5:00 hrs	Cumilla	1422	1242	180								
09.	Generation shortfall at evening peak due to :	:			Total				13875	13517	358					
a)	Gas/LF limitation	:	1516 MW		Fuel cost :				(c) Coal = 693828730 Taka							
d)	Coal supply Limitation	:	85 MW		(a) Gas = 159402535 Taka				Total = 1420647336 Taka							
b)	Low water level in Kaptai lake	:	0 MW		(b) Oil = 567416071 Taka											
c)	Plants under shut down/ maintenance	:	2906 MW		14. Maximum Temperature in Dhaka was : 33.5°C											
10.	Total Energy (Generation + India Import)	:	301.05 MKWh		15. Export through East-West interconnections :											
	By Gas = 138.433 MKWh		By Oil = 49.078 MKWh		At evening peak-hour				12594 MW, at	21:00 hrs						
	By Coal = 81.350 MKWh		By Hydro = 4.877 MKWh		Maximum				1246 MW, at	22:00 hrs						
	By Solar= 2.364 MKWh				Energy				0 MKWh							
11.	Total Gas Supplied	:	1076.60 MMCFD													
(D) Forecast of 08.09.23 (Today) Friday :																
01.	Maximum Demand	:	13000 MW (Generation end)		04.	Maximum Load-shed	:	0 MW	At evening peak (Sub-station end)							
02.	Maximum Generation	:	14876 MW (Generation end)		05.	Total Generation	:	277.07 MKWh								
03.	Reserve / Shortage	:	1876 MW (Generation end)		06.	Probable Max. Temperature in Dhaka :	33.5°C									