

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 3564667, 9551095

Month September, 2023					Day : Saturday				Date : 09.09.23				
Probable Maximum Demand : 14300 MW					Probable Maximum Generation : 14857 MW								
Water Level of Kapitai Lake at 06:00 AM					Yesterday = 106.17 ft		Today = 106.36 ft		Rule Curve = 10084.00 ft.				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	08.09.23 (Yesterday)		09.09.23 (Today)		08.09.23 (Yesterday)		09.09.23 (Today)		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Status of Machines under shut-down/ Maintenance		
					Day	Evening	Day	Evening	Gas/Coal/Water Limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date	
(A) Plants in operation:													
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	130	200	200	200				
3	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0		190	Under maint.	
4	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0				
5	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	80	77	75	77	31		Gas Shortage	
6	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage	
7	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0				
8	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	290	343	330	330				
9	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	370	450	450	450				
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	323	396	412	412				
11	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	39	97	100	100				
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	322	328	330	330				
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	5	0	0		330	was under maint.	
14	Madangan-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	15	15	15				
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	8	8	8	16				
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	16	19	19				
17	Summit Power(Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	29	38	38	38				
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	25	25				
19	Rugganji 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	32	32	33	33				
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	25	8	25				
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	17	70	70	105				
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	48	82	64	150				
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	54	17	35				
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	15	63	84	130				
25	Kodda 140 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	17	145	17	149				
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	25x11.4	300	300	0	9	0	0				
27	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	17	35	55	55				
28	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	35	35	35				
29	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	17	17	17				
30	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	17	54	54	108				
31	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	12	0	35	0				
32	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	17	17	17				
33	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	9	20	16	20				
34	Meghnaghat 100 MW(IE)	HFO (NENP)	12x8.9	100	100	8	66	32	33				
35	Madangan 102 PP(Summit)	HFO (NENP)	6x17	102	102	17	26	80	80				
36	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	20	40	45				
	Meghnaghat Unique Power	Gas				0	0	0	0				
Dhaka Zone Total													
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	202	199	195	199				
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	110	105	110	110				
39	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.	
40	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0				
41	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	17	8	17				
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	2	0	20	0				
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	6	6	50				
44	Sikalbaha 105 MW PP (Baraka Sikabaha)	HFO (IPP)	6x18.415	105	105	17	17	17	17				
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.	
46	Sikalbaha 225 MW CAPP	Gas (PDB)	1 x 150+1 x 75	225	225	224	225	225	225				
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	30	264	70	265				
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	25	25	25				
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	0	0	0				
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	30	49	32	60				
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	13	12	12	12				
*	Malancha, Ctg.EPZ (United)	Gas	5x8.73+3x9.34			32	42	10	30				
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0				
53	Sikalbaha 54 MW PP (Jodiad Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	54	17	54				
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	55	66	55	55				
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	25	25	25	25				
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	25	25	25	25				
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	34	34	34	34				
58	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	0	160	17	158				
	SS Power Unit-1	Coal (IPP)				557	0	0	0			Test run	
	Matarbari 2*600 MW (CPGCL)	Coal				0	0	0	0			Test run	
	Cox's Bazar Wind PP	(Wind) (IPP)				1	4	10	10				
Chattogram Zone Total													
58	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	45	49	49	49				
59	Ashuganj 225 MW CAPP	Gas (APSCL)	1x142+1*75	221	221	197	204	200	200				
60	Ashuganj 450 MW CAPP(South)	Gas (APSCL)	1x360	360	360	310	305	300	300				
61	Ashuganj 450 MW CAPP(North)	Gas (APSCL)	1x361	360	360	0	165	320	360		195	was under maint.	
62	Ashuganj 420 MW CAPP(East)	Gas (APSCL)	1x284+1x116	400	400	0	0	0	0		400	Under maint.	
63	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*116	195	195	158	197	190	195				
64	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51				
65	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	20	150	13	150				
66	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	0				
67	Chandpur 150 MW CAPP	Gas (PDB)	1x106+1x57	163	163	0	0	0	0		163	Under maint.	
68	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	72	104	68	100				
69	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	18	16	18				
70	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
71	Jangalia 33 MW PP (Summit))	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33				
72	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	46	51	51				
73	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	12	12	12	12				
74	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	17	34	70				
75	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	27	78	28	75				
76	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17				
77	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	0	0	0	0				
**	Impoport (Tripura)	India		160	160	128	160	149	165				
Cumilla Zone Total													
78	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	35	99	70	100		103	Gas Shortage	
79	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	16	16	16	16				
80	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	0	85	37	95				
81	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	87	163	115	150				
82	Sarishabani 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0				
83	Sutiakahi 50 MW Solar PP	Solar (IPP)	1x50	50	50	36	0	50	0				
84	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	6	6	6	6				
Mymensingh Zone Total													
				622	614	181	369	296	367		103	0	

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	08.09.23 (Yesterday)		09.09.23 (Today)		08.09.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening				
85	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	30	30	30		40	GT-1 Under maint.	
86	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	40	40	40	40		50	GT-4 Under maint.	
87	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	22	50	50	50				
88	Kushiara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	80	112	112	112		54	ST Under maint.	
89	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	5	11	11				
90	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	60	59	60	60				
91	Shajibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
92	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	78	86	86	86				
93	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	185	184	185	185				
94	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	16	17	17	17				
95	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
96	Shahjibazar 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16				
97	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	280	290	300	300				
98	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	317	369	400	400				
99	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	50	143	50	400				
100	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
101	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	42	40	40	40				
Sylhet Zone Total						2472	2427	1237	1451	1407	1757	0	574
102	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
103	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0	410		Gas Shortage	
104	Fairdipur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	10	25	40				
105	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	10	40	50				
106	Khulna 225 MW CCPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0				
107	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	35	17	51				
108	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	0				
109	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	33	0	100	0				
110	Khulna 115 MW PP (KPCCL-2)	HFO (NENP)	7x17	115	115	16	16	66	98				
111	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	8	24	40				
112	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFCL)	1x617	617	617	517	402	400	450				
113	Khulna 330 MW CCPP (GT)	Gas/HSD (PDB)	1x220	220	220	128	122	120	120				
**	Bheramara (HVDG)	India		1000	1000	920	778	938	938				
Khulna Zone Total						3125	3121	1614	1381	1730	1787	410	0
114	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	16	48				
115	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	19	27	23	30				
116	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	80	130	132	132				
117	Payra 1320 MW TTP	Coal (BCPCL)	2x622	1244	1244	1000	1244	1244	1244				
118	Potukhalhi 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	72	35	150				
119	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	0	0	0	0	307		Coal Shortage	
120	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	180	110	110	110				
Barishal Zone Total						2265	2265	1296	1583	1560	1714	307	0
121	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.	
122	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	35	0	35				
123	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0				
124	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	21	0	21				
125	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	34	50	91				
126	Katakhalhi 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	31	30	40				
127	Katakhalhi 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	8	34	42				
128	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	24	24	24				
129	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	161	164	160	160	46		Gas Shortage	
130	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage	
131	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	140	156	140	160	64		Gas Shortage	
132	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	300	387	414	414	27		Gas Shortage	
133	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8				
134	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	8	8	52				
135	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	35	75	35	75				
136	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	70	35	70				
137	Ammura 50 MW PPI(Sinha)	HFO (NENP)	7x7.79	50	28	0	0	28	28				
138	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	0	0	6	0				
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	919	1362	1300	1400				
Rajshahi Zone Total						3653	3631	1598	2383	2272	2620	428	100
139	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
140	Barapukuria 275 MW TTP Unit-3	Coal (PDB)	1 x 274	274	274	180	180	180	180				
141	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
142	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	0	94	34	80				
143	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
144	Maipara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	4	0	8	0				
145	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	113	35	75				
146	Lalmohithat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	1.1	0	30	0				
147	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	15	0	130	0				
Rangpur Zone Total						1030	950	210	387	417	335	85	85
Sub-total: Plants in operation						24500	24171	10585.0	13259	12818	14857	1469	2742
(B) Plants under long term maintenance/ contract expired													
148	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
149	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
150	Bosilla 108MW PPI(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
151	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	0	0	0	0	0				
152	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	0	0	0	0	0				
Sub-total: Plants under long term maintenance/ contract expired						331	0	0	0	0	0	0	0
Gross Total						24911	24171	10585	13259	12818	14857	1469	2742
(C) Actual data of 08.09.23 (Yesterday) Friday :													
01.	Max. Demand at eve. peak (Generation end)	:	13300 MW, at =	21:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	12680 MW, at =	21:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed	
03.	Highest Generation (Generation end)	:	13259 MW, at =	21:00 hrs	MW	MW	MW	MW	MW	MW	MW	MW	
04.	Minimum Generation (Generation end)	:	10221 MW, at =	9:00 hrs	Dhaka	4265	4265	0	Mymensingh	1143	1104	39	
05.	Day-peak Generation (Generation end)	:	10585 MW, at =	12:00 hrs	Chattogram	1295	1295	0	Sylhet	549	549	0	
06.	Evening-peak Generation (Generation end)	:	13259 MW, at =	21:00 hrs	Khulna	1581	1581	0	Barishal	397	397	0	
07.	Evening Peak Load-shed (Sub-station end)	:	39 MW, at =	21:00 hrs	Rajshahi	1323	1323	0	Rangpur	873	873	0	
08.	Minimum Generation Forecast up to 8:00 hrs.	:	10895 MW, at =	5:00 hrs	Cumilla	1253	1253	0					
09.	Generation shortfall at evening peak due to :	:							Total	12680	12641	39	
a)	Gas/LF limitation	:	1384 MW										
d)	Coal supply Limitation	:	85 MW										
b)	Low water level in Kaptai lake	:	0 MW										
c)	Plants under shut down/ maintenance	:	2742 MW										
10.	Total Energy (Generation + India Import)	:	278.05 MKWh										
	By Gas = 130.803 MKWH		By Oil = 37.538 MKWh										
	By Coal = 78.886 MKWH		By Hydro = 4.361 MKWh										
	By Solar = 1.207 MKWH												
11.	Total Gas Supplied	:	1070.15 MMCFD										
(D) Forecast of 09.09.23 (Today) Saturday :													
01.	Maximum Demand	:	14300 MW	(Generation end)	04.	Maximum Load-shed : 0 MW At evening peak (Sub-station end)							
02.	Maximum Generation	:	14857 MW	(Generation end)	05.	Total Generation : 299.89 MKWh							
03.	Reserve / Shortage	:	557 MW	(Generation end)	06.	Probable Max. Temperature in Dhaka : 32.5°C							