

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month September, 2023					Day : Sunday				Date : 17.09.23					
Probable Maximum Demand : 15400 MW					Probable Maximum Generation : 15453 MW				Rule Curve = 10245 ft.					
Water Level of Kapitla Lake at 06:00 AM					Yesterday = 107.89 ft. Today = 107.89 ft.									
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	16.09.23 (Yesterday)		17.09.23 (Today)		16.09.23 (Yesterday)		17.09.23 (Today)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/Water Limitation MW		Machines shut down (MW)		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening						
(A) Plants in operation:														
1	Ghorasal Repowered CAPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260		Under project work	
2	a) Ghorasal Repowered CAPP Unit-4 b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	180	210	220	220	220		190		Under maint.	
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0					
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	76	86	82	85					
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105			Gas Shortage	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0					
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	322	321	330	330					
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450					
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115		Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	51	403	400	400					
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	121	0	0	0		210		Gas Shortage	
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	313	314	330	330					
13	Meghnaghat 335MW CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	288	295	300	300					
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	55	55	15					
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	25	91	24	92					
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	16	19	19	19					
17	Summit Power(Madhabadi+Ashulia)	Gas (SIPP, REB)	6x3.07+7x8.73	80	80	37	38	38	38					
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	33	25	25					
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	23	28	33	33					
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	24	8	25					
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	35	105	35	105					
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	48	148	48	149					
23	Kamalaghat 54 MW PP (Barco Energy)	HFO (IPP)	3x18.69	54	54	17	35	17	35					
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	16x17.076	300	300	75	130	147	97					
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	17	117	100	149					
26	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	2	55	55	55					
27	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	35	35	35					
28	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	54	72	53	72					
29	Manikganj 162MW PP(MPL)	HFO (IPP)	9x18	162	162	54	108	54	108					
30	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	35	0	35	0					
31	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	17	17	17					
32	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	0	82	40	75					
33	Meghnaghat 100 MW(EL)	HFO (NENP)	12x8.9	100	100	32	72	41	64					
34	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	62	64	85	85					
35	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	18	39	55	55					
	Meghnaghat Unique Power	Gas				0	0	0	0					
	Meghnaghat 589 MW CCPP(Summit)	Gas				0	0	0	0					
Dhaka Zone Total			5604	5422	2481	3456	3131	3463	105	775				
36	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	166	199	202	203					
37	a) Chattogram TPP-1 b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180		Under maint.	
38	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	5	0	5	0		180		Under maint.	
39	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	17	8	17					
40	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	20	0	20	0					
41	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	13	0	30	50					
42	Sikalbaha 105 MW PP (Baraka Sikabaha)	HFO (IPP)	6x18.415	105	105	17	17	17	17					
43	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150		Under maint.	
44	Sikalbaha 225 MW CAPP	Gas (PDB)	1 x 150+1 x 75	225	225	217	220	225	225					
45	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	69	266	70	280					
46	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	10	10	10	10					
47	Dohazari -Kalash 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	0	0	0					
48	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	24	70	32	65					
49	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	9	9	12	12					
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			3	29	5	25					
50	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0					
51	Sikalbaha 54 MW PP (Jodiad Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	54	17	54					
52	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	55	55	55	55					
53	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	10	10	10	10					
54	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	12	12	12	12					
55	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	32	32	34	51					
56	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	161	159	54	160					
	SS Power Unit-1	Coal (IPP)				619	620	620	620				Test run	
	Matarbari 2'600 MW (CPGCL)	Coal				0	0	0	0				Test run	
	Cox's Bazar Wind PP	(Wind) (IPP)				0	0	10	25					
Chattogram Zone Total			2605	2545	1467	1779	1448	1891	0	510				
57	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	44	46	43	48					
58	Ashuganj 225 MW CAPP	Gas (APSCCL)	1x142+1'75	221	221	194	206	200	200					
59	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	330	310	310	310					
60	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	325	305	310	310					
61	Ashuganj 420 MW CCPP(East)	Gas (APSCCL)	1x284+1x116	400	400	0	0	0	0		400		Under maint.	
62	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20'9.73+1'116	195	195	127	107	108	108					
63	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51					
64	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	18	118	18	145					
65	Titag 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	23	0	23					
66	Chandpur 150 MW CAPP	Gas (PDB)	1x106+1x57	163	163	0	0	0	0		163		Under maint.	
67	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	71	104	68	100					
68	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	18	16	17					
69	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	10	10	10					
70	Jangalia 33 MW PP (Summit))	Gas (SIPP, PDB)	4x8.73	33	33	25	33	33	33					
71	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	25	52	25	52					
72	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	12	12	12	12					
73	Feni 114 MW (Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	105	105	105	105					
74	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	27	77	28	78					
75	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17					
76	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	0	0	0	115					
**	Impoport (Tripura)	India		160	160	136	152	149	165					
Cumilla Zone Total			2904	2896	1533	1746	1503	1899	0	563				
77	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	30	78	32	50	124			Gas Shortage	
78	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	13	17	18	18					
79	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	37	103	47	105					
80	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	114	134	114	150					
81	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0					
82	Sutiakehi 50 MW Solar PP	Solar (IPP)	1x50	50	50	53	0	50	0					
83	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	6	6	6	6					
Mymensingh Zone Total			622	614	255	338	269	329	124	0				

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	16.09.23 (Yesterday)		17.09.23 (Today)		16.09.23 (Yesterday)		Status of Machines under shut-down/ Maintenance								
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date							
						Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)									
84	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	42	43	43		28	GT-1 Under maint.								
85	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	40	40	40	40		50	GT-4 Under maint.								
86	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	31	50	50	50											
87	Kushihara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	112	112	112	112		54	ST Under maint.								
88	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	3	11	11											
89	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	0	0	0	0											
90	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.								
91	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	78	86	86	86											
92	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	183	180	185	185											
93	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	16	17	17	17											
94	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10											
95	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16											
96	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	310	280	310	310											
97	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	388	368	400	400											
98	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	376	390	400	400											
99	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work								
100	Fenchuganj 44MW (Energyprime)	Gas (NENP)	12*3.3+5*2	50	50	31	39	40	42											
Sylhet Zone Total						2472	2427	1645	1633	1720	1722	0	562							
101	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0											
102	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0	410	Gas Shortage									
103	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	35	25	40											
104	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	40	0	40											
105	Khulna 225 MW CCPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	80	120	120											
106	Rupsha 105 MW PP (Orion rupsha)	HFO (iPP)	6x18.445	105	105	38	54	54	72											
107	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	50	85	15	50											
108	Mongla Orion 100 MW Solar PP	Solar (iPP)		100	100	100	0	100	0											
109	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	47	63	49	49											
110	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	16	0	0											
111	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	0	0	0	0											
112	Khulna 330 MW CCPP (GT)	Gas/HSD (BPDB)	1x220	220	220	0	0	0	0											
**	Bheramara (HVDC)	India		1000	1000	925	827	938	938											
Khulna Zone Total						3125	3121	1160	1200	1301	1309	410	0							
113	Barisal 110 MW PP (Summit)	HFO (iPP)	7 x 17.076	110	110	16	110	16	110											
114	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	21	31	23	31											
115	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	124	130	130	130											
116	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	1170	1244	1244	1244											
117	Potukhali 150MW PP (UPPL)	HFO (iPP)	8x18.415+1x9.78	150	150	19	54	35	150											
118	Barisal Electric 307 MW	Coal (iPP)	1x307	307	307	0	0	0	0	307	Coal Shortage									
119	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (iPP)	2x75+1x70	220	220	220	220	220	220											
Barishal Zone Total						2265	2265	1570	1789	1668	1885	307	0							
120	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71	Gas Shortage									
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100	Under maint.									
121	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	27	0	35											
122	Baghabari 200 MW PP (Paramount)	HSD (iPP)	135x1.6	200	200	0	0	0	0											
123	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	15	0	21											
124	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	92	50	91											
125	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	39	30	40											
126	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	8	34	34	42											
127	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	24	24	32											
128	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	180	205	180	185											
129	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220	Gas Shortage									
130	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	150	181	170	190											
131	Sirajgonj 400 MW CCPP Unit-4	Gas (iPP)	1x282+1x132	414	414	370	414	380	414											
132	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8											
133	Natore 52 MW PP (Rajlanka)	HFO (iPP)	6x8.92	52	52	0	8	0	8											
134	Bagura 113 MW (Confidence) U-1	HFO (iPP)	6*18.55	113	113	35	75	35	75											
135	Bagura 113 MW PP (Confidence) U-2	HFO (iPP)	6x18.55	113	113	35	65	35	70											
136	Ammura 50 MW PPS(Sinha)	HFO (NENP)	7x7.79	50	28	6	28	28	28											
137	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0											
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	1258	1464	1300	1400											
Raishahi Zone Total						3653	3631	2055	2679	2280	2639	291	100							
138	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Coal Shortage									
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Under Overhauling									
139	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	180	180	180	180											
140	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0											
141	Rangpur 113 MW PP (Confidence)	HFO (iPP)	7*16x 2*3	113	113	33	63	34	64											
142	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0											
143	Majpara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (iPP)	1 x 8	8	8	0	0	8	0											
144	Thakurgaon 119MW PP (Energypac)	HFO (iPP)	6*20	115	115	0	75	0	72											
145	Lalmohithai 30 MW Solar (Intraco)	Solar (iPP)	1*30	30	30	34	0	30	0											
146	Teesha Solar Limited	Solar (iPP)	1 x 200	200	200	192	0	130	0											
Rangpur Zone Total						1030	950	439	318	382	316	85	85							
Sub-total: Plants in operation						24280	23871	12605.0	14938	13702	15453	1322	2595							
(B) Plants under long term maintenance/ contract expired																				
147	Jamalganj 95 MW PP(Powerpac)	HFO (iPP)	12x8.924	95	0	0	0	0	0											
148	Katpotti 52 MW PP (Sinha)	HFO (iPP)	7x7.90	51	0	0	0	0	0											
149	Bosila 108MW PP(CLC)	HFO (iPP)	12x8.775+1x3.5	108	0	0	0	0	0											
150	Keraniganj 300 MW PP (APR)	HSD (iPP)	256x1.4	300	300	0	0	0	0											
151	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	0	0	0	0	0											
152	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	0	0	0	0	0											
Sub-Total: Plants under long term maintenance/ contract expired						631	300	0	0	0	0	0	0							
Gross Total						24911	24171	12605	14938	13702	15453	1322	2595							
(C) Actual data of 16.09.23 (Yesterday) Saturday :																				
01.	Max. Demand at eve. peak (Generation end)	:	15350	MW, at =	21:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :														
02.	Max. Demand at eve. peak (Sub-station end)	:	14674	MW, at =	21:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed							
03.	Highest Generation (Generation end)	:	14938	MW, at =	21:00 hrs		MW	MW	MW		MW	MW	MW							
04.	Minimum Generation (Generation end)	:	11548	MW, at =	6:00 hrs	Dhaka	5091	5091	0	Mymensingh	1299	1161	138							
05.	Day-peak Generation (Generation end)	:	12605	MW, at =	12:00 hrs	Chattogram	1395	1395	0	Sylhet	620	540	80							
06.	Evening-peak Generation (Generation end)	:	14938	MW, at =	21:00 hrs	Khulna	1841	1841	0	Barishal	464	464	0							
07.	Evening Peak Load-shed (Sub-station end)	:	393	MW, at =	21:00 hrs	Rajshahi	1535	1528	7	Rangpur	994	906	88							
08.	Minimum Generation Forecast up to 8:00 hrs.	:	12330	MW, at =	5:00 hrs	Cumilla	1436	1356	80											
09.	Generation shortfall at evening peak due to :	:								Total	14674	14281	393							
	a) Gas/LF limitation	:	1237	MW		13. Fuel cost :				(a) Gas =	169128529	Taka	(c) Coal =	575176408	Taka					
	d) Coal supply Limitation	:	85	MW						(b) Oil =	716099635	Taka	Total =	1460404572	Taka					
	b) Low water level in Kaptai lake	:	0	MW		14. Maximum Temperature in Dhaka was :														
	c) Plants under shut down/ maintenance	:	2595	MW		15. Export through East-West interconnections :														
10.	Total Energy (Generation + India Import)	:	321.51	MKWh		At evening peak-hour														
	By Gas =	150.787	/MKWh	By Oil =	55.725	MKWh	: 12605													
	By Coal =	83.160	MKWh	By Hydro =	4.664	MKWh	: 760													
	By Solar =	1.859	MKWh				: 0													
11.	Total Gas Supplied	:	1128.56	MMCFD		Energy : 0														
(D) Forecast of 17.09.23 (Today) Sunday :																				
01.	Maximum Demand	:	15400	MW	(Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)									
02.	Maximum Generation	:	15453	MW	(Generation end)	05.	Total Generation	:	331.45	MKWh										
03.	Reserve / Shortage	:	53	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	:	36°C											