

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 954667, 9551095

Month September, 2023					Day : Tuesday				Date : 19.09.23					
Probable Maximum Demand : 14900 MW					Probable Maximum Generation : 15935 MW									
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 107.90 ft		Today = 108.19 ft		Rule Curve = 102.91 ft.					
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	18.09.23 (Yesterday)		19.09.23 (Today)		18.09.23 (Yesterday)		19.09.23 (Today)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/Water Limitation MW		Machines shut down (MW)		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening						
(A) Plants in operation:														
1	Ghorasal Repowered CAPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260		Under project work	
2	a) Ghorasal Repowered CAPP Unit-4 b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	180	130	140	200	200				Under maint.	
3	Ghorasal 365 MW CAPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0					
4	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	80	86	78	85					
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105			Gas Shortage	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0					
7	Haripur 360MW CAPP(HPL)	Gas (IPP)	1x235+1x125	360	360	332	271	330	330					
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	320	450	450					
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115		Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	396	356	400	400					
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0		210		Gas Shortage	
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	321	260	330	330					
13	Meghnaghat 335MW CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	266	272	280	300					
14	Madangan-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	50	15	55	15					
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	25	91	24	92					
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	19	19	19					
17	Summit Power(Madhabadi+Ashulia)	Gas (SIPP, REB)	6x3.07+7x8.73	80	80	31	31	38	38					
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	25	25					
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	28	28	28	28					
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	16	25	8	25					
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	50	105	35	105					
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	47	149	48	149					
23	Kamalaghat 54 MW PP (Barico Energy)	HFO (IPP)	3x18.69	54	54	17	35	17	35					
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	16x17.076	300	300	95	47	140	190					
25	Kodda 140 MW PP Unit-1 (Summit)	HFO (IPP)	8x14.15+1x8.97	149	149	95	105	100	100					
26	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	5	55	55	55					
27	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	35	35	35					
28	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	53	53	53	60					
29	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	54	108	54	108					
30	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	31	0	35	0					
31	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	34	34	17	34					
32	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	73	45	85	85					
33	Meghnaghat 100 MW(EL)	HFO (NENP)	12x8.9	100	100	24	8	41	70					
34	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	80	80	85	85					
35	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	0	55	55					
	Meghnaghat Unique Power	Gas				400	300	0	0					
	Meghnaghat 589 MW CCPP(Summit)	Gas				0	415	0	0					
Dhaka Zone Total				5604	5422	3262	3513	3120	3503	105	775			
36	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	198	197	197	197					
37	a) Chattogram TPP-1 b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180		Under maint.	
	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0				Under maint.	
39	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	17	8	17					
40	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	8	0	20	0					
41	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	0	30	50					
42	Sikalbaha 105 MW PP (Baraka Sikabaha)	HFO (IPP)	6x18.415	105	105	34	34	34	34					
43	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150		Under maint.	
44	Sikalbaha 225 MW CAPP	Gas (PDB)	1 x 150+1 x 75	225	225	221	225	225	225					
45	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	73	285	70	285					
46	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	38	10	38					
47	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	0	0	0					
48	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	31	70	32	70					
49	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	9	9	9	9					
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			7	25	10	20					
50	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0					
51	Sikalbaha 54 MW PP (Jodiad Power)	HFO (IPP)	3x18.5+1x3.6	54	54	17	54	17	54					
52	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	55	55	55	55					
53	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	25	38	10	38					
54	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	25	25	12	38					
55	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	34	68	34	51					
56	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	17	34	54	160					
	SS Power Unit-1	Coal (IPP)				532	618	620	620				Test run	
	Matarbari 2'600 MW (CPGCL)	Coal				0	0	0	0				Test run	
	Cox's Bazar Wind PP	(Wind) (IPP)				14	6	10	20					
Chattogram Zone Total				2605	2545	1343	1798	1462	1981	0	510			
57	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	24	48	43	48					
58	Ashuganj 225 MW CAPP	Gas (APSCCL)	1x142+1'75	221	221	179	178	200	200					
59	Ashuganj 450 MW CAPP(South)	Gas (APSCCL)	1x360	360	360	270	270	300	300					
60	Ashuganj 450 MW CAPP(North)	Gas (APSCCL)	1x361	360	360	280	280	290	310					
61	Ashuganj 420 MW CAPP(East)	Gas (APSCCL)	1x284+1x116	400	400	0	0	0	0		400		Under maint.	
62	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20'9.73+1'116	195	195	88	88	78	88					
63	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51					
64	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	18	90	18	145					
65	Titag 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	15	21	25	25					
66	Chandpur 150 MW CAPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0		163		Under maint.	
67	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	51	102	68	100					
68	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	15	15	15	15					
69	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	10	10	10					
70	Jangalia 33 MW PP (Summit))	Gas (SIPP, PDB)	4x8.73	33	33	32	33	33	33					
71	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	25	52	25	52					
72	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	0	12	12	12					
73	Feni 114 MW (Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	17	52	105	105					
74	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	28	77	28	78					
75	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	35	54	17	34					
76	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	0	0	0	0					
**	Impport (Tripura)	India		160	160	146	162	149	165					
Cumilla Zone Total				2904	2896	1282	1595	1467	1771	0	563			
77	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	26	45	32	50	157			Gas Shortage	
78	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	17	17	18	18					
79	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	93	103	70	90					
80	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	66	142	114	142					
81	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0					
82	Sutiakehi 50 MW Solar PP	Solar (IPP)	1x50	50	50	54	0	50	0					
83	Tangail 22 MW PP(PPLGL)	HFO (IPP)	4x6.7	22	22	15	18	14	18					
Mymensingh Zone Total				622	614	273	325	300	318	157	0			

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	18.09.23 (Yesterday)		19.09.23 (Today)		18.09.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)		
84	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 Under maint.	
85	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	30	30	30	30		60	GT-4 Under maint.	
86	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	50	50	50	50				
87	Kushnara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	112	112	112	112		54	ST Under maint.	
88	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	5	5	5				
89	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	0	0	0	0		66	Under maint.	
90	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
91	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	78	86	85	86				
92	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	182	180	185	185				
93	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	16	17	17	17				
94	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
95	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	8	8	8				
96	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	285	260	290	300				
97	Bibiyan-II 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	342	368	400	400				
98	Bibiyan South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	385	400	400	400				
99	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
100	Fenchugonj 44MW (Energyprime)	Gas (NENP)	12*3.3+5*2	50	50	35	39	40	40				
Sylhet Zone Total						2472	2427	1587	1608	1675	1686	0	637
101	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
102	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0	410		Gas Shortage	
103	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	37	25	40				
104	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	32	0	40				
105	Khulna 225 MW CCPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	115	114	115	115				
106	Rupsha 105 MW PP (Orion rupsha)	HFO (iPP)	6x18.445	105	105	54	35	54	72				
107	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	15	0	0	0				
108	Mongla Orion 100 MW Solar PP	Solar (iPP)	100	100	100	67	0	100	0				
109	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	32	64	32	66				
110	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	24	0	16				
111	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	0	233	520	570				
112	Khulna 330 MW CCPP (GT)	Gas/HSD (BPDB)	1x220	220	220	0	0	0	0				
**	Bheramara (HVDC)	India		1000	1000	929	909	938	938				
Khulna Zone Total						3125	3121	1212	1448	1784	1857	410	0
113	Barisal 110 MW PP (Summit)	HFO (iPP)	7 x 17.076	110	110	16	32	16	110				
114	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	21	25	23	25				
115	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	80	80	130	130				
116	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	1244	1244	1244	1244				
117	Potukhali 150MW PP (UPPL)	HFO (iPP)	8x18.415+1x9.78	150	150	35	35	35	150				
118	Barisal Electric 307 MW	Coal (iPP)	1x307	307	307	0	0	0	0	307		Coal Shortage	
119	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (iPP)	2x75+1x70	220	220	180	180	220	220				
Barishal Zone Total						2265	2265	1576	1596	1668	1879	307	0
120	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.	
121	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	14	0	30				
122	Baghabari 200 MW PP (Paramount)	HSD (iPP)	135x1.6	200	200	0	0	0	0				
123	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	5	0	20				
124	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	47	91	50	91				
125	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	39	30	40				
126	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	8	34	42				
127	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	24	32				
128	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	140	140	150	160				
129	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage	
130	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	154	130	170	190				
131	Sirajgonj 400 MW CCPP Unit-4	Gas (iPP)	1x282+1x132	414	414	300	270	380	414				
132	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8				
133	Natore 52 MW PP (Rajlanka)	HFO (iPP)	6x8.92	52	52	0	8	0	8				
134	Bagura 113 MW (Confidence) U-1	HFO (iPP)	6*18.55	113	113	35	57	35	75				
135	Bagura 113 MW PP (Confidence) U-2	HFO (iPP)	6x18.55	113	113	35	50	35	70				
136	Ammura 50 MW PPS(Sinha)	HFO (NENP)	7x7.79	50	28	0	0	28	28				
137	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	4	0	6	0				
**	Adani Power Jharkhand Ltd	(Import)	2x748	1496	1496	1302	1359	1300	1400				
Rajshahi Zone Total						3653	3631	2025	2211	2250	2608	291	100
138	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
139	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	180	180	180	180				
140	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
141	Rangpur 113 MW PP (Confidence)	HFO (iPP)	7*16x 2*3	113	113	33	76	34	76				
142	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
143	Maipara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (iPP)	1 x 8	8	8	7	0	8	0				
144	Thakurgaon 119MW PP (Energypac)	HFO (iPP)	6*20	115	115	55	115	0	76				
145	Lalmohithal 30 MW Solar (Intraco)	Solar (iPP)	1*30	30	30	35	0	30	0				
146	Teesha Solar Limited	Solar (iPP)	1 x 200	200	200	128	0	130	0				
Rangpur Zone Total						1030	950	438	371	382	332	85	85
Sub-total: Plants in operation						24280	23871	12998.0	14465	14108	15935	1355	2670
(B) Plants under long term maintenance/ contract expired													
147	Jamalganj 95 MW PP(Powerpac)	HFO (iPP)	12x8.924	95	0	0	0	0	0				
148	Katpottli 52 MW PP (Sinha)	HFO (iPP)	7x7.90	51	0	0	0	0	0				
149	Bosila 108MW PP(CLC)	HFO (iPP)	12x8.775+1x3.5	108	0	0	0	0	0				
150	Keraniganj 300 MW PP (APR)	HSD (iPP)	256x1.4	300	300	0	0	0	0				
151	Boogra 22 MW PP (GGB)	Gas (RPP)	6x4.0	22	0	0	0	0	0				
152	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	0	0	0	0	0				
Sub-total: Plants under long term maintenance/ contract expired						631	300	0	0	0	0	0	0
Gross Total						24911	24171	12998	14465	14108	15935	1355	2670
(C) Actual data of 18.09.23 (Yesterday) Monday :													
01.	Max. Demand at eve. peak (Generation end)	:	14650	MW, at =	19:30 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	14022	MW, at =	19:30 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed
03.	Highest Generation (Generation end)	:	14465	MW, at =	19:30 hrs	Dhaka	5146	5146	0	Mymensingh	1221	1099	122
04.	Minimum Generation (Generation end)	:	11514	MW, at =	8:00 hrs	Chattogram	1293	1293	0	Sylhet	633	603	30
05.	Day-peak Generation (Generation end)	:	12998	MW, at =	12:00 hrs	Khulna	1625	1625	0	Barishal	380	380	0
06.	Evening-peak Generation (Generation end)	:	14465	MW, at =	19:30 hrs	Rajshahi	1488	1488	0	Rangpur	964	964	0
07.	Evening Peak Load-shed (Sub-station end)	:	177	MW, at =	19:30 hrs	Cumilla	1272	1247	25				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	10881	MW, at =	5:00 hrs					Total	14022	13845	177
09.	Generation shortfall at evening peak due to :	:											
	a) Gas/LF limitation	:	1270	MW									
	d) Coal supply Limitation	:	85	MW									
	b) Low water level in Kaptai lake	:	0	MW									
	c) Plants under shut down/ maintenance	:	2670	MW									
10.	Total Energy (Generation + India Import)	:	311.74	MKWh									
	By Gas = 152.755 /MKWH			By Oil = 44.575 MKWh									
	By Coal = 81.820 MKWH			By Hydro = 4.752 MKWh									
	By Solar = 2.318 /MKWH												
11.	Total Gas Supplied	:	1147.90	MMCFD									
(D) Forecast of 19.09.23 (Today) Tuesday :													
01.	Maximum Demand	:	14900	MW (Generation end)		04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)		
02.	Maximum Generation	:	15935	MW (Generation end)		05.	Total Generation	:	321.11	MKWh			
03.	Reserve / Shortage	:	1035	MW (Generation end)		06.	Probable Max. Temperature in Dhaka :		32.5°C				