

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month September, 2023					Day : Wednesday				Date : 20.09.23					
Probable Maximum Demand : 15000 MW					Probable Maximum Generation : 15985 MW				Rule Curve = 108.46 ft.					
Water Level of Kaptai Lake at 06:00 AM					Today = 108.46 ft.									
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	19.09.23 (Yesterday)		20.09.23 (Today)		19.09.23 (Yesterday)		20.09.23 (Today)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/Water Limitation MW		Machines shut down (MW)		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening						
(A) Plants in operation:														
1	Ghorasal Repowered CAPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260		Under project work	
2	a) Ghorasal Repowered CAPP Unit-4 b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	180	130	130	180	180		190		Under maint.	
3	Ghorasal 365 MW CAPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0					
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	70	86	78	85					
5	Tong 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105			Gas Shortage	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0					
7	Haripur 360MW CAPP(HPL)	Gas (IPP)	1x235+1x125	360	360	332	331	330	330					
8	Meghnaghat 450 MW CAPP(MPL)	Gas (IPP)	2x140+1x170	450	450	340	420	450	450					
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115		Under Overhauling	
10	Haripur 412 MW CAPP	Gas (EGCB)	1x273+1x139	412	412	380	394	400	400					
11	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0		210		Gas Shortage	
12	Siddhirgonj 335 MW CAPP	Gas (EGCB)	1 x 217+1x118	335	335	310	330	330	330					
13	Meghnaghat 335MW CAPP(Summit)	Gas (IPP)	2x110+1x110	335	335	266	276	280	300					
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	7	15	15	55					
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	58	102	24	102					
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	16	19	19	19					
17	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.07+7x8.73	80	80	31	19	38	38					
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	25	25					
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	26	31	31	31					
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	25	8	25					
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	35	50	35	105					
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	48	149	48	149					
23	Kamalaghat 54 MW PP (Barico Energy)	HFO (IPP)	3x18.69	54	54	15	17	17	35					
24	Kodda 300 MW PP Unit-2 (Sumit)	HFO (IPP)	16x17.076	300	300	48	0	85	145					
25	Kodda 149 MW PP Unit-1 (Sumit)	HFO (IPP)	8x18.415+1x8.97	149	149	108	70	17	149					
26	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	17	17	55	55					
27	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	17	35	35					
28	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	35	54	72					
29	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	54	17	54	108					
30	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	16	0	35	0					
31	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	34	34	17	34					
32	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	2	0	85	85					
33	Meghnaghat 100 MW(EL)	HFO (NENP)	12x8.9	100	100	0	0	41	70					
34	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	10	15	85	85					
35	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	0	55	55					
	Meghnaghat Unique Power	Gas				0	0	0	0					
	Meghnaghat 589 MW CAPP(Summit)	Gas				420	0	0	0					
Dhaka Zone Total				5604	5422	2858	2624	2926	3552	105	775			
36	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	200	200	200	200					
37	a) Chattogram TPP-1 b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	80	105	105		100		Under maint.	
38	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0		180		Under maint.	
39	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	17	8	17					
40	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	0	0	20	0					
41	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	39	6	50					
42	Sikalbaha 105 MW PP (Baraka Sikabaha)	HFO (IPP)	6x18.415	105	105	34	51	34	51					
43	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150		Under maint.	
44	Sikalbaha 225 MW CAPP	Gas (PDB)	1 x 150+1 x 75	225	225	221	223	225	225					
45	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	70	282	70	285					
46	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	38	25	38					
47	Dohazari-Kalash 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	0	0	0					
48	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	24	62	32	70					
49	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	11	11	11	11					
	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			5	27	10	10					
50	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0					
51	Sikalbaha 54 MW PP (Jodiad Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	54	17	54					
52	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	110	55	55	55					
53	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	25	38	25	38					
54	Juldah 100 MW Unit-1 (Acom)	HFO (ORPP)	8x13.45	100	100	35	35	35	45					
55	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	34	51	34	51					
56	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	0	0	54	160					
	SS Power Unit-1	Coal (IPP)				563	544	500	550				Test run	
	Matarbari 2'600 MW (CPGCL)	Coal				0	0	0	0				Test run	
	Cox's Bazar Wind PP	(Wind) (IPP)				19	29	10	20					
Chattogram Zone Total				2605	2545	1431	1836	1481	2035	0	430			
57	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	48	50	49	50					
58	Ashuganj 225 MW CAPP	Gas (APSCCL)	1x142+1'75	221	221	204	211	200	200					
59	Ashuganj 450 MW CAPP(South)	Gas (APSCCL)	1x360	360	360	305	275	300	300					
60	Ashuganj 450 MW CAPP(North)	Gas (APSCCL)	1x361	360	360	310	280	300	310					
61	Ashuganj 420 MW CAPP(East)	Gas (APSCCL)	1x284+1x116	400	400	0	0	0	0		400		Under maint.	
62	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20'9.73+1'116	195	195	45	135	108	108					
63	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	5	5					
64	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	13	33	18	145					
65	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	8	15	25					
66	Chandpur 150 MW CAPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0		163		Under maint.	
67	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	68	103	68	100					
68	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	18	18	18					
69	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	10	10	10	10					
70	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33					
71	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	52	25	52					
72	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	12	12	12	12					
73	Feni 114 MW (Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	34	52	105	105					
74	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	37	76	38	78					
75	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	35	35	17	34					
76	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	0	0	0	0					
**	Import (Tijpura)	India		160	160	150	126	149	165					
Cumilla Zone Total				2904	2896	1381	1560	1470	1750	0	563			
77	RPCL 210MW CAPP	Gas (IPP)	4x35+1x70	210	202	26	38	30	50		164		Gas Shortage	
78	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	18	19	19					
79	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	38	104	37	104					
80	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	116	112	115	142					
81	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0					
82	Sutiakali 50 MW Solar PP	Solar (IPP)	1x50	50	50	39	0	50	0					
83	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	18	9	14	18					
Mymensingh Zone Total				622	614	256	281	267	333	164	0			

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	19.09.23 (Yesterday)		20.09.23 (Today)		19.09.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Machines shut down (MW)			
84	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 Under maint.	
85	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	30	40	40	40		50	GT-4 Under maint.	
86	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	22	50	50	50				
87	Kushiera 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	80	80	112	112		54	ST Under maint.	
88	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	5	11	11				
89	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	0	0	0	0		66	Under maint.	
90	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
91	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	78	86	85	86				
92	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	185	184	185	185				
93	Sylhet 20 MW GTTP	Gas (PDB)	1x2.20	20	20	16	17	17	17				
94	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
95	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	8	8	8				
96	Bibiiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	290	290	290	300				
97	Bibiiana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	367	367	400	400				
98	Bibiiana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	390	400	400	400				
99	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
100	Fenchugonj 44MW (Energyprime)	Gas (NENP)	12*3.3+5*2	50	50	35	39	40	40				
Sylhet Zone Total						2472	2427	1565	1609	1691	1702	0	627
101	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
102	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0	410		Gas Shortage	
103	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	36	25	40				
104	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	30	0	40				
105	Khulna 225 MW CCPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	241	120	120	120				
106	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	35	54	72				
107	Machumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	0				
108	Mongla Orion 100 MW Solar PP	Solar (IPP)	100	100	103	0	100	0	100				
109	Khulna 115 MW PP (KPL-2)	HFO (NENP)	7x17	115	115	0	16	32	66				
110	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	0	0	16				
111	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	440	566	520	565				
112	Khulna 330 MW CCPP (GT)	Gas/HSD (BPDB)	1x220	220	220	0	0	0	0				
**	Bheramara (HVDC)	India		1000	1000	905	905	938	938				
Khulna Zone Total						3125	3121	1689	1708	1789	1857	410	0
113	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	16	16	110				
114	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	17	29	23	25				
115	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	80	72	130	130				
116	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	900	1244	1244	1244				
117	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	35	150				
118	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	0	0	0	0	307		Coal Shortage	
119	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	180	45	110	110				
Barishal Zone Total						2265	2265	1177	1406	1558	1769	307	0
120	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.	
121	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	35	0	30				
122	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0				
123	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	7	0	20				
124	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	55	50	91				
125	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	40	30	40				
126	Katakhali 50 MW PP (Northern)	HFO (ORPP)	6x8.9	50	50	0	0	34	42				
127	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	24	32				
128	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	140	170	180	180				
129	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150+ 1x75	220	220	0	0	0	0	220		Gas Shortage	
130	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	130	160	170	190	60		Gas Shortage	
131	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	280	350	380	414	64		Gas Shortage	
132	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8				
133	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	0	0	8				
134	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	0	35	75				
135	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	35	35	70				
136	Ammura 50 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	0	0	28	28				
137	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0				
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	1211	1427	1300	1400				
Rajshahi Zone Total						3653	3631	1774	2319	2280	2628	415	100
138	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
139	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	180	180	180	180				
140	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
141	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	34	56	35	64				
142	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
143	Majpara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	5	0	8	0				
144	Thakurgaon 119MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	115	35	115				
145	Lalmohith 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	5	0	30	0				
146	Teesha Solar Limited	Solar (IPP)	1 x 200	200	200	204	0	130	0				
Rangpur Zone Total						1030	950	428	351	418	359	85	85
Sub-total: Plants in operation						24280	23871	12559.0	13694	13880	15985	1486	2580
(B) Plants under long term maintenance/ contract expired													
147	Jamalganj 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
148	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
149	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
150	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	0	0				
151	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	0	0	0	0	0				
152	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	0	0	0	0	0				
Sub-Total: Plants under long term maintenance/ contract expired						631	300	0	0	0	0	0	0
Gross Total						24911	24171	12559	13694	13880	15985	1486	2580
(C) Actual data of 19.09.23 (Yesterday) Tuesday :													
01.	Max. Demand at eve. peak (Generation end)	:	13890	MW, at =	20:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	13242	MW, at =	20:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed
03.	Highest Generation (Generation end)	:	13694	MW, at =	20:00 hrs		MW	MW	MW		MW	MW	MW
04.	Minimum Generation (Generation end)	:	10881	MW, at =	8:00 hrs	Dhaka	4721	4721	0	Mymensingh	1138	1006	132
05.	Day-peak Generation (Generation end)	:	12559	MW, at =	12:00 hrs	Chattogram	1313	1313	0	Sylhet	602	572	30
06.	Evening-peak Generation (Generation end)	:	13694	MW, at =	20:00 hrs	Khulna	1596	1596	0	Barishal	353	353	0
07.	Evening Peak Load-shed (Sub-station end)	:	187	MW, at =	20:00 hrs	Rajshahi	1328	1328	0	Rangpur	934	934	0
08.	Minimum Generation Forecast up to 8:00 hrs.	:	10628	MW, at =	5:00 hrs	Cumilla	1258	1233	25				
09.	Generation shortfall at evening peak due to :	:				Total				13242	13055	187	
	a) Gas/LF limitation	:	1401	MW		Fuel cost : (a) Gas = 155856055 Taka (c) Coal = 616395301 Taka				Total = 1241908285 Taka			
	d) Coal supply Limitation	:	85	MW		(b) Oil = 469656929 Taka							
	b) Low water level in Kaptai lake	:	0	MW									
	c) Plants under shut down/ maintenance	:	2580	MW									
10.	Total Energy (Generation + India Import)	:	297.95	MKWh		14. Maximum Temperature in Dhaka was : 32.4°C							
	By Gas = 146.074 MKWh			By Oil = 34.610 MKWh		15. Export through East-West interconnections :							
	By Coal = 85.555 MKWh			By Hydro = 4.330 MKWh		At evening peak-hour : 12559 MW, at 20:00 hrs							
	By Solar = 2.371 MKWh					Maximum : 890 MW, at 19:00 hrs							
						Energy : 0 MKWh							