

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month September, 2023					Day : Thursday					Date : 21.09.23				
Probable Maximum Demand : 14500 MW					Probable Maximum Generation : 16140 MW					Rule Curve = 108.46 ft.				
Water Level of Kaptai Lake at 06:00 AM					Today = 108.61 ft.									
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	20.09.23 (Yesterday)		21.09.23 (Today)		20.09.23 (Yesterday)		21.09.23 (Today)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/Water Limitation MW		Machines shut down (MW)		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening						
(A) Plants in operation:														
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260		Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	130	160	160	160					
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0		190		Under maint.	
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0					
4	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	75	82	78	85					
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105			Gas Shortage	
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0					
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	326	336	330	330					
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	320	370	450	450					
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115		Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	374	393	400	400					
11	Siddhirganj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0		210		Gas Shortage	
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	250	300	330	330					
13	Meghnaghat 335MW CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	108	293	300	300					
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	15	15	40					
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	24	40	102	102					
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	12	17	19	19					
17	Summit Power(Madhabadi+Ashulia)	Gas (SIPP, REB)	6x3.07+7x8.73	80	80	38	38	38	38					
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	25	25					
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	28	26	31	31					
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	25	8	25					
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	52	105	35	105					
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	48	98	48	149					
23	Kamalaghat 54 MW PP (Barico Energy)	HFO (IPP)	3x18.69	54	54	17	0	17	35					
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	16x17.076	300	300	0	45	145	145					
25	Kodda 140 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.15+1x8.97	149	149	17	102	108	100					
26	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	17	35	55	55					
27	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	17	35	35					
28	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	25	43	54	72					
29	Manikganj 162MW PP(MPL)	HFO (IPP)	9x18	162	162	17	17	54	108					
30	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	3	0	35	0					
31	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	34	54	17	54					
32	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	0	0	92	92					
33	Meghnaghat 100 MW(EL)	HFO (NENP)	12x8.9	100	100	0	0	65	85					
34	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	43	85	85					
35	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	0	55	55					
	Meghnaghat Unique Power	Gas				0	0	0	0					
	Meghnaghat 589 MW CCPP(Summit)	Gas				420	0	0	0					
Dhaka Zone Total			5604	5422	2403	2679	3186	3510	105	775				
36	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	201	157	200	200					
37	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	105	102	105	105		78		Under maint.	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180		Under maint.	
38	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0					
39	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	17	8	17					
40	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	12	0	20	0					
41	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	36	6	50					
42	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	51	51	51	51					
43	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150		Under maint.	
44	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	219	223	225	225					
45	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	30	174	120	285					
46	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	12	12	25	50					
47	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	0	0	0					
48	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	40	70					
49	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	9	11	11	11					
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			6	25	7	25					
50	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0					
51	Sikalbaha 54 MW PP (Jodiad Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	54					
52	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	51	64	110	55					
53	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	12	12	25	38					
54	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	0	12	35	50					
55	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	34	34	34	51					
56	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	0	0	54	160					
	SS Power Unit-1	Coal (IPP)				525	612	600	600				Test run	
	Matarbari 2'600 MW (CPGCL)	Coal				0	0	0	0				Test run	
	Cox's Bazar Wind PP	(Wind) (IPP)				20	8	10	20					
Chattogram Zone Total			2605	2545	1314	1567	1708	2117	0	408				
57	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	45	49	50	50					
58	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1'75	221	221	207	200	200	200					
59	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	295	310	330	330					
60	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	345	280	330	330					
61	Ashuganj 420 MW CCPP(East)	Gas (APSCCL)	1x284+1x116	400	400	0	0	0	0		400		Under maint.	
62	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20'9.73+1'116	195	195	108	108	108	108					
63	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	9	51	10	50					
64	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	10	46	50	145					
65	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	8	0	15	25					
66	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0		163		Under maint.	
67	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	68	100	68	100					
68	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	18	18	18					
69	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	10	10	10	10					
70	Jangalia 33 MW PP (Summit))	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33					
71	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	52	25	52					
72	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	12	12	12	12					
73	Feni 114 MW (Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	0	17	105	105					
74	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	28	75	26	78					
75	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	34					
76	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	0	0	0	0					
**	Import (Tripura)	India		160	160	138	164	149	165					
Cumilla Zone Total			2904	2896	1351	1542	1556	1845	0	563				
77	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	27	34	30	50		168		Gas Shortage	
78	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	19	19					
79	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	37	104	37	104					
80	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	116	142	115	142					
81	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0					
82	Sutiakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	27	0	50	0					
83	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	18	18	14	18					
Mymensing Zone Total			622	614	246	317	267	333	168	0				

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	20.09.23 (Yesterday)		21.09.23 (Today)		20.09.23 (Yesterday)		Status of Machines under shut-down/ Maintenance					
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date				
						Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)						
84	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 Under maint.					
85	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	40	40	40	40		50	GT-4 Under maint.					
86	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	22	45	50	50								
87	Kushnara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	112	112	112	112		54	ST Under maint.					
88	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	8	11	11								
89	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	0	0	0	0	66		Gas Shortage					
90	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0	330		Under maint.					
91	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	40	81	85	86								
92	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	183	183	185	185								
93	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	16	17	17	17								
94	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10								
95	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	8	8	8								
96	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	280	260	300	300								
97	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	377	400	400	400								
98	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	384	400	400	400								
99	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0	100		Under project work					
100	Fenchuganj 44MW (Energyprime)	Gas (NENP)	12*3.3+5*2	50	50	28	34	40	40								
Sylhet Zone Total						2472	2427	1554	1641	1701	1702	66	561				
101	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0								
102	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0	410		Gas Shortage					
103	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	37	25	40								
104	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	40								
105	Khulna 225 MW CCPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	120	120	120	120								
106	Rupsha 105 MW PP (Orion rupsha)	HFO (iPP)	6x18.445	105	105	0	0	54	72								
107	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	0								
108	Mongla Orion 100 MW Solar PP	Solar (iPP)	100	100	100	62	0	100	0								
109	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	32	32	66								
110	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	8	0	16								
111	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFCL)	1x617	617	617	521	572	520	565								
112	Khulna 330 MW CCPP (GT)	Gas/HSD (BPDB)	1x220	220	220	0	0	0	0								
**	Bheramara (HVDC)	India		1000	1000	903	904	938	938								
Khulna Zone Total						3125	3121	1606	1673	1789	1857	410	0				
113	Barisal 110 MW PP (Summit)	HFO (iPP)	7 x 17.076	110	110	0	16	16	110								
114	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	13	26	23	25								
115	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	80	130	130	130								
116	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	980	1210	1244	1244								
117	Potukhali 150MW PP (UPPL)	HFO (iPP)	8x18.415+1x9.78	150	150	0	17	35	150								
118	Barisal Electric 307 MW	Coal (iPP)	1x307	307	307	0	0	0	0	307		Coal Shortage					
119	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (iPP)	2x75+1x70	220	220	109	109	110	110								
Barishal Zone Total						2265	2265	1182	1508	1558	1769	307	0				
120	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage					
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Under maint.					
121	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	0	30								
122	Baghabari 200 MW PP (Paramount)	HSD (iPP)	135x1.6	200	200	0	0	0	0								
123	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	20								
124	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	25	50	91								
125	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	30	40								
126	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	34	42								
127	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	24	32								
128	Sirajganj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	140	170	180	180								
129	Sirajganj 225MW CCPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	0	0	0	0	220		Gas Shortage					
130	Sirajganj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	130	146	170	190	74		Gas Shortage					
131	Sirajganj 400 MW CCPP Unit-4	Gas (iPP)	1x282+1x132	414	414	250	350	380	414	64		Gas Shortage					
132	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8								
133	Natore 52 MW PP (Rajlanka)	HFO (iPP)	6x8.92	52	52	0	0	0	8								
134	Bagura 113 MW (Confidence) U-1	HFO (iPP)	6*18.55	113	113	0	35	55	75								
135	Bagura 113 MW PP (Confidence) U-2	HFO (iPP)	6x18.55	113	113	0	0	35	70								
136	Ammura 50 MW PPS(Sinha)	HFO (NENP)	7x7.79	50	28	0	0	28	28								
137	Sirajganj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	3	0	6	0								
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	1219	1253	1300	1400								
Rajshahi Zone Total						3653	3631	1750	1987	2300	2628	429	100				
138	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage					
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Under Overhauling					
139	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	180	180	180	180								
140	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0								
141	Rangpur 113 MW PP (Confidence)	HFO (iPP)	7*16x 2*3	113	113	28	70	42	84								
142	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0								
143	Majpara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (iPP)	1 x 8	8	8	6	0	8	0								
144	Thakurgaon 119MW PP (Energypac)	HFO (iPP)	6*20	115	115	37	40	35	115								
145	Lalmohini 30 MW Solar (Intraco)	Solar (iPP)	1*30	30	30	25	0	30	0								
146	Teesha Solar Limited	Solar (iPP)	1 x 200	200	200	183	0	130	0								
Rangpur Zone Total						1030	950	459	290	425	379	85	85				
Sub-total: Plants in operation						24280	23871	11865.0	13204	14490	16140	1570	2492				
(B) Plants under long term maintenance/ contract expired																	
147	Jamalganj 95 MW PP(Powerpac)	HFO (iPP)	12x8.924	95	0	0	0	0	0								
148	Katpotti 52 MW PP (Sinha)	HFO (iPP)	7x7.90	51	0	0	0	0	0								
149	Bosila 108MW PP(CLC)	HFO (iPP)	12x8.775+1x3.5	108	0	0	0	0	0								
150	Keraniganj 300 MW PP (APR)	HSD (iPP)	256x1.4	300	300	0	0	0	0								
151	Boogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	0	0	0	0	0								
152	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	0	0	0	0	0								
Sub-total: Plants under long term maintenance/ contract expired						631	300	0	0	0	0	0	0				
Gross Total						24911	24171	11865	13204	14490	16140	1570	2492				
(C) Actual data of 20.09.23 (Yesterday) Wednesday :																	
01.	Max. Demand at eve. peak (Generation end)	:	13250	MW, at =	19:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :											
02.	Max. Demand at eve. peak (Sub-station end)	:	12742	MW, at =	19:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed				
03.	Highest Generation (Generation end)	:	13204	MW, at =	19:00 hrs		MW	MW	MW		MW	MW	MW				
04.	Minimum Generation (Generation end)	:	10628	MW, at =	8:00 hrs	Dhaka	4764	4764	0	Mymensingh	1092	1048	44				
05.	Day-peak Generation (Generation end)	:	11865	MW, at =	12:00 hrs	Chattogram	1242	1242	0	Sylhet	448	448	0				
06.	Evening-peak Generation (Generation end)	:	13204	MW, at =	19:00 hrs	Khulna	1495	1495	0	Barishal	360	360	0				
07.	Evening Peak Load-shed (Sub-station end)	:	44	MW, at =	19:00 hrs	Rajshahi	1300	1300	0	Rangpur	842	842	0				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	10455	MW, at =	5:00 hrs	Cumilla	1200	1200	0								
09.	Generation shortfall at evening peak due to :	:				Total				12742	12698	44					
	a) Gas/LF limitation	:	1485	MW		Fuel cost :				(c) Coal = 636826630 Taka							
	d) Coal supply Limitation	:	85	MW		(a) Gas = 155298113 Taka				(b) Oil = 366824744 Taka							
	b) Low water level in Kaptai lake	:	0	MW		Total = 1158949687 Taka											
	c) Plants under shut down/ maintenance	:	2492	MW		14. Maximum Temperature in Dhaka was : 31.4°C											
10.	Total Energy (Generation + India Import)	:	287.80	MKWh		15. Export through East-West interconnections :											
	By Gas = 144.264 MKWh			By Oil = 27.296 MKWh		At evening peak-hour :											
	By Coal = 87.128 MKWh			By Hydro = 4.244 MKWh		Maximum :											
	By Solar = 1.836 MKWh					Energy :											
11.	Total Gas Supplied	:	1082.16	MMCFD		0 MKWh											

(D) Forecast of 21.09.23 (Today) Thursday :				04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)
01.	Maximum Demand	:	14500	MW	(Generation end)				
02.	Maximum Generation	:	16140	MW	(Generation end)				
03.	Reserve / Shortage	:	1640	MW	(Generation end)				
				05.	Total Generation	:	316.05	MKWh	
				06.	Probable Max. Temperature in Dhaka :		31.4°C		