

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 3564667, 9551095

Month September, 2023					Day : Tuesday				Date : 26.09.23					
Probable Maximum Demand : 14500 MW					Probable Maximum Generation : 16581 MW									
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 107.94 ft		Today = 107.83 ft		Rule Curve = 104.80 ft					
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	25.09.23 (Yesterday)		26.09.23 (Today)		25.09.23 (Yesterday)		26.09.23 (Today)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Machines shut down (MW)		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	Gas/Coal/Water Limitation MW					
(A) Plants in operation:														
1	Ghorasal Repowered CAPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260		Under project work	
2	a) Ghorasal Repowered CAPP Unit-4	Gas (PDB)	1 x 210	210	180	130	150	130	150					
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0		190		Under maint.	
3	Ghorasal 365 MW CAPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0					
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	52	53	53	53					
5	Tong 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105			Gas Shortage	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0					
7	Haripur 360MW CAPP(HPL)	Gas (IPP)	1x235+1x125	360	360	332	331	330	330					
8	Meghnaghat 450 MW CAPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450					
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115		Under Overhauling	
10	Haripur 412 MW CAPP	Gas (EGCB)	1x273+1x139	412	412	407	407	412	412					
11	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0		210		Gas Shortage	
12	Siddhirgonj 335 MW CAPP	Gas (EGCB)	1 x 217+1x118	335	335	280	290	330	330					
13	Meghnaghat 335MW CAPP(Summit)	Gas (IPP)	2x110+1x110	335	335	312	279	310	310					
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	40	15	15	55					
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	50	83	102	102					
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	17	10	20	20					
17	Summit Power(Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	24	35	38	38					
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	17	17	25	25					
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	30	28	30	30					
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	25	8	25					
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	52	70	35	105					
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	16	138	48	149					
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	35	17	35					
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	95	95	300	300					
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	108	80	17	149					
26	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	55	55	55					
27	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	35	35	35					
28	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	54	72	54	72					
29	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	54	126	54	108					
30	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	22	0	35	0					
31	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	54	17	54					
32	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	17	35	92	92					
33	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	0	0	72	82					
34	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	17	51	85	85					
35	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	0	55	55					
	Meghnaghat Unique Power	Gas				0	0	0	0					
	Meghnaghat 589 MW CAPP(Summit)	Gas				0	0	0	0					
Dhaka Zone Total			5604	5422	2671	3019	3224	3706	105	775				
36	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	202	203	196	196					
37	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	100	95	100	100					
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180		Under maint.	
38	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	5	0	5	0					
39	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	0	8	17					
40	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	20	0	20	0					
41	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	30	39	6	40					
42	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	40	51	51	51					
43	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150		Under maint.	
44	Sikalbaha 225 MW CAPP	Gas (PDB)	1 x 150+1 x 75	225	225	218	224	225	225					
45	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	70	200	120	285					
46	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	50	25	50					
47	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	0	0	0					
48	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	40	40	64					
49	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	9	9	11	11					
*	Malancha, Ctg.EPZ (United)	Gas	5x8.73+3x9.34			5	26	7	25					
50	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0					
51	Sikalbaha 54 MW PP (Jodiach Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	25	17	54					
52	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	55	55	55	55					
53	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	38	38	38	63					
54	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	12	70	70	70					
55	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	34	51	34	51					
56	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	0	17	54	150					
	SS Power Unit-1	Coal (IPP)				300	300	600	600				Test run	
	Matarbari 2*600 MW (CPGCL)	Coal				0	0	0	0				Test run	
	Cox's Bazar Wind PP	(Wind) (IPP)				1	0	10	20					
Chattogram Zone Total			2605	2545	1189	1493	1692	2127	0	330				
57	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	47	46	50	50					
58	Ashuganj 225 MW CAPP	Gas (APSCCL)	1x142+1*75	221	221	204	211	200	200					
59	Ashuganj 450 MW CAPP(South)	Gas (APSCCL)	1x360	360	360	300	275	330	330					
60	Ashuganj 450 MW CAPP(North)	Gas (APSCCL)	1x361	360	360	305	310	330	330					
61	Ashuganj 420 MW CAPP(East)	Gas (APSCCL)	1x284+1x116	400	400	0	0	0	0		400		Under maint.	
62	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*116	195	195	107	88	78	78					
63	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	10	50					
64	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	46	71	50	150					
65	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	15	31					
66	Chandpur 150 MW CAPP	Gas (PDB)	1x106+1x57	163	163	0	0	0	0		163		Under maint.	
67	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	69	103	68	100					
68	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	17	18	18	18					
69	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	10	10	10					
70	Jangalia 33 MW PP (Summit))	Gas (SIPP, PDB)	4x8.73	33	33	33	30	33	33					
71	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	25	40	52	52					
72	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	12	12	12	12					
73	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	70	105	105					
74	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	37	85	27	85					
75	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	18	35	17	34					
76	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	53	52	34	50					
**	Import (Tirupura)	India		160	160	142	152	149	165					
Cumilla Zone Total			2904	2896	1491	1659	1588	1883	0	563				
77	RPCL 210MW CAPP	Gas (IPP)	4x35+1x70	210	202	26	32	43	43	170			Gas Shortage	
78	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	18	18	18					
79	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	75	104	37	104					
80	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	68	142	115	159					
81	Sarishabani 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0					
82	Sutiakahi 50 MW Solar PP	Solar (IPP)	1x50	50	50	39	0	50	0					
83	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	18	18	18	18					
Mymensingh Zone Total			622	614	246	314	283	342	170	0				

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	25.09.23 (Yesterday)		26.09.23 (Today)		25.09.23 (Yesterday)		Status of Machines under shut-down/ Maintenance					
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date				
						Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)						
84	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 Under maint.					
85	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	0	30	40	40		60	GT-4 Under maint.					
86	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	50	50	50	50								
87	Kushiana 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	112	112	112	112		54	ST Under maint.					
88	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11								
89	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	0	0	0	0	66		Gas Shortage Under maint.					
90	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330						
91	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	78	86	86	86								
92	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	184	183	185	185								
93	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	16	17	17	17								
94	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	10	10	10								
95	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	8	8	8								
96	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	290	280	300	300								
97	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	404	403	400	400								
98	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	380	380	400	400								
99	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work					
100	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12'3.3-5'2	50	50	44	48	40	46								
Sylhet Zone Total						2472	2427	1629	1661	1702	1708	66	571				
101	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0								
102	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0	410		Gas Shortage					
103	Fairdipor 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	40	25	40								
104	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	4	0	40								
105	Khulna 225 MW CCPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0								
106	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	17	54	72								
107	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	15	100	100								
108	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	9	0	100	0								
109	Khulna 115 MW PP (KPCCL-2)	HFO (NENP)	7x17	115	115	0	48	32	66								
110	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5'8.5	40	40	0	0	16	40								
111	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIPCL)	1x617	617	617	516	520	520	520								
112	Khulna 330 MW CCPP (GT)	Gas/HSD (BPDB)	1x220	220	220	0	0	0	0								
**	Bheramara (H/DC)	India		1000	1000	907	886	938	938								
Khulna Zone Total						3125	3121	1432	1530	1769	1792	410	0				
113	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	16	16	110								
114	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	23	28	23	25								
115	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	0	64	65	65								
116	Payra 1320 MW TTP	Coal (BCPCL)	2x622	1244	1244	980	1190	1244	1244								
117	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	35	35	150								
118	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	200	297	300	300								
119	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	220	220	220								
Barishal Zone Total						2265	2265	1423	1850	1903	2114	0	0				
120	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage					
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.					
121	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	0	30								
122	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0								
123	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	25								
124	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	25	50	91								
125	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	24	30	40								
126	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	34	42								
127	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	25	24	32								
128	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	140	197	140	140								
129	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage					
130	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	140	193	140	140								
131	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	300	370	380	414	44		Gas Shortage					
132	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8								
133	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	0	0	8								
134	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6'18.55	113	113	0	0	35	76								
135	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	15	35	70								
136	Amnara 50 MW PPS(Sinha)	HFO (NENP)	7x7.79	50	28	0	0	28	28								
137	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0								
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	1160	1317	1300	1400								
Rajshahi Zone Total						3653	3631	1753	2174	2210	2544	335	100				
138	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage					
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling					
139	Barapukuria 275 MW TTP Unit-3	Coal (PDB)	1 x 274	274	274	180	180	180	180								
140	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0								
141	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	34	70	35	70								
142	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0								
143	Maipara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	1	0	8	0								
144	Thakurgaon 115MW PP (Energygap)	HFO (IPP)	6'20	115	115	0	72	35	115								
145	Lalmohithai 30 MW Solar (Intraco)	Solar (IPP)	1'30	30	30	24	0	30	0								
146	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	189	0	130	0								
Rangpur Zone Total						1030	950	428	322	418	365	85	85				
Sub-total: Plants in operation						24280	23871	12262.0	14022	14789	16581	1171	2424				
(B) Plants under long term maintenance/ contract expired																	
147	Jamalpur 95 MW PPI(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0								
148	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0								
149	Bosilla 108MW PPI(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0								
150	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	0	0	0	0	0								
151	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	0	0	0	0	0								
Sub-total: Plants under long term maintenance/ contract expired						351	0	0	0	0	0	0	0				
Gross Total						24611	23871	12262	14022	14789	16581	1171	2424				
(C) Actual data of 25.09.23 (Yesterday) Monday :																	
01.	Max. Demand at eve. peak (Generation end)	:	14120	MW, at =	19:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :											
02.	Max. Demand at eve. peak (Sub-station end)	:	13436	MW, at =	19:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed				
03.	Highest Generation (Generation end)	:	14022	MW, at =	19:00 hrs		MW	MW	MW		MW	MW	MW				
04.	Minimum Generation (Generation end)	:	10389	MW, at =	6:00 hrs	Dhaka	4927	4927	0	Mymensingh	1162	1098	64				
05.	Day-peak Generation (Generation end)	:	12262	MW, at =	12:00 hrs	Chattogram	1328	1328	0	Sylhet	579	549	30				
06.	Evening-peak Generation (Generation end)	:	14022	MW, at =	19:00 hrs	Khulna	1616	1616	0	Barishal	417	417	0				
07.	Evening Peak Load-shed (Sub-station end)	:	94	MW, at =	19:00 hrs	Rajshahi	1248	1248	0	Rangpur	827	827	0				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	10877	MW, at =	5:00 hrs	Cumilla	1332	1332	0								
09.	Generation shortfall at evening peak due to :	:								Total	13436	13342	94				
	a) Gas/LF limitation	:	1086	MW						(a) Gas =	161847659 Taka	(c) Coal =	677643749 Taka				
	d) Coal supply Limitation	:	85	MW						(b) Oil =	411951688 Taka	Total =	1251443095 Taka				
	b) Low water level in Kaptai lake	:	0	MW													
	c) Plants under shut down/ maintenance	:	2424	MW													
10.	Total Energy (Generation + India Import)	:	292.69	MKWh													
	By Gas =	143.981	MKWh	By Oil =	31.383												
	By Coal =	85.381	MKWh	By Hydro =	4.757												
	By Solar =	2.139	MKWh														
11.	Total Gas Supplied	:	1073.00	MMCFD													
(D) Forecast of 26.09.23 (Today) Tuesday :																	
01.	Maximum Demand	:	14500	MW	(Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)						
02.	Maximum Generation	:	16581	MW	(Generation end)	05.	Total Generation	:	302.67	MKWh							
03.	Reserve / Shortage	:	2081	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	:	34.4°C								