

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date : 26-Sep-23		Page - 2					
Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Enerov Generated	Remarks
			Unit No. X Capacity	MW	MW	KWH	
1	Ghorasal Repowered CCPP-Unit-3 (GT	PDB	1*260	260	0	0	Under maint.
2	Ghorasal Repowered CCPP Unit-4	PDB	1*210	180	150	3391469	
3	Ghorasal TPP Unit-5	PDB	1*210	190	0	0	Under maint.
3	Ghorasal 365 MW CCPP Unit-7	PDB	1*243+1*122	365	0	0	Air Compressor problem
4	Ghorasal 78.5 MW PP (PMAx)	QRPP	0	240	0	0	Contract Expired
4	Ghorasal 108 MW PP (Regent)	IPP	3*43.35	108	52	928363	Gas shortage
5	Haripur GTPP	SBU, PDB	2*32	20	0	0	Under maint.
6	Haripur 412 MW CCPP	EGCB	1*273+1*139	412	414	9132030	
7	Haripur 360 MW CCPP(HPL)	IPP	1*235+1*125	360	332	7248000	Gas shortage
8	Meghnaghat 450 MW CCPP(MPL)	IPP	2*150+1*150	450	450	9538000	
9	Meghnaghat 100 MW(EL)	NENP	12*8.9	100	0	43200	Low demand
10	Meghnaghat CCPP(Summit)	IPP	2*110+1*110	335	289	7000029	FGMO
11	Madanganj 102 PP(Summit)	NENP	6*17	102	85	453233	Engine problem
12	Madanganj-55 MW PP(Summit)	IPP	3*17.08+1*11.3	55	30	255387	Fuel shortage
13	Keraniganj 100 MW PP (Powerpac)	PDB	8*13.45	75	0	0	Low demand
14	Narshingdi 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	20	425124	Engine problem
15	210 MW Siddhirganj TPP	PDB	1*210	115	0	0	Under maint.
16	Siddhirganj 2*120 MW GTPP	EGCB	2*105	210	0	0	Gas shortage
17	Siddhirganj 100 PP(Dutch Bangla)	NENP	12*8.9	100	8	109997	Low demand
18	Siddhirganj 335 MW CCPP	EGCB	1*217+118	335	160	5852457	Frequency control
19	Gagnagar 102 MW PP (Digital Power)	IPP	12*8.924	102	91	968616	Engine problem
20	Kalpotti 52 MW PP (Siraha)	IPP	7*7.9	0	0	0	Fuel shortage
21	Kamalaghat 54 MW PP(Banco Energy)	IPP	3*18	54	35	383040	Fuel shortage
22	Kodda 150 MW PP	BPDB-RPCL	9*17.06	149	142	1190400	
23	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	35	518765	Fuel shortage
24	Nababganj 55 MW PP (Southern power)	IPP	3*19.3	55	35	513214	Fuel shortage
25	Bosila 108 MW PP(CLCC)	IPP	12*8.775+1*3.5	0	0	0	
26	Summit Power, (Madhabdi+Ashulia)	SIPP, REB	3*3.67+4*8.73	80	35	854880	Engine problem
27	Maona 33 MW PP(Summit)	SIPP, REB	4*8.73	33	25	574020	Engine problem
28	Manikgonj 162MW PP(MPGL)	SIPP, REB	8*13.45	33	14	531000	Engine problem
29	Gazipur 52 MW PP	RPCL	6*8.9	52	25	288480	Fuel shortage
30	Tongi 80 MW GTPP	PDB	1*105	105	0	0	Gas shortage
31	Kodda 300 MW PP Unit-2 (Summit)	IPP	18*17.076	300	145	848073	Low demand
33	Bramhangaoan 100 MW PP (Aggreko)	IPP	11*10.959	0	0	0	Contract Expired
34	Aurahat 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	0	0	0	Contract Expired
35	Kodda 149 MW PP Unit-1 (Summit)	IPP	8*18.45+8.97	149	120	1087632	Low demand
36	Gazipur 100 MW PP	RPCL	6*17.5	105	88	1074240	Low demand
37	Meghnaghat 104 MW PP (OPCL)	IPP	18.5*6	104	72	1102080	Fuel shortage
38	Manikgonj 162MW PP(MPGL)	IPP	9*18	162	90	1166400	Low demand
39	Spectra Solar Plant Ltd	IPP	35	35	0	233995	
40	Kanchan Purbasudha Power Generation Ltd.	IPP	18.4*3	55	54	831960	
	Meghnaghat Unique power	IPP	589	0	0	0	On test.
	Summit Meghanghat-2 589 MW(Gas)	IPP	589	0	0	0	On test.
Dhaka area Total				5422	2996	56542284	
41	Chattogram TPP-1	PDB	1*210	180	103	2400000	Gas shortage
	Chattogram TPP-2	PDB	1*210	180	0	0	Gas shortage
42	Razzan 25 MW PP	RPCL	3*9.9	25	17	160614	Fuel shortage
43	Teknaf 20MW PP (Solartech)	IPP	20	20	0	122580	
44	Patenga 50MW PP (Baraka)	IPP	8*6.98	50	40	290400	Engine problem
45	Kapla Hydro Unit-1,2,3,4, 5	PDB	2*40+3*50	230	202	4651653	
46	Sikalbaha 225MW	PDB	1*150+1*75	225	225	5193818	
47	Sikalbaha Peaking GT	PDB	1*150	150	0	0	Under maint.
48	Sikalbaha 105 MW PP (Baraka Sikalbaha)	IPP	6*17.5	105	51	1013673	Fuel shortage
49	Hathazari 100 MW peaking PP	PDB	11*8.9	98	71	554928	
50	Dohazari -Kalaish 100 MW Peaking	PDB	6*17	102	0	0	Fuel shortage
51	Julidah 100 MW Unit-1 (Acom)	NENP	8*13.45	100	58	781680	Fuel shortage
52	Julidah 100 MW PP Unit-3 (Acom)	IPP	8*13.5	100	50	819940	Fuel shortage
53	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8*2.90	22	11	235152	Engine problem
*	Malancha, Cig. EPZ (United)		5*8.73+3*9.34	0	14	559680	
54	Chattogram 108 MW PP (ECPV)	IPP	16*7	108	0	0	Fuel shortage
55	Kapla 7 MW Solar PP	PDB	7.4 MW	7	0	29520	
56	Anwara 300 MW PP (United)	IPP	17*17+24	300	282	2318400	Engine problem
57	Jodiac Power	IPP	3*18.55+1*3.6	54	54	431288	
58	Karnaphuli Power Ltd.	IPP	18.415*6+8.5	110	55	1295522	Fuel shortage
59	Julidah unit-2 (Acom)	IPP	8*13.6	100	50	603840	Fuel shortage
60	Anlima Energy Ltd.	IPP	6*21.2	116	51	717600	Fuel shortage
	Mirshana 150 MW	BPDB-RPCL	18.5*9	163	0	1673	Low demand
	SS Power 1	SS Power	0	0	550	13558180	
	Cox's Bazar Wind	IPP	66	0	0	46560	On test.
	Matarbari 2*600 MW (CPGCL)	CPGCL	0	0	42	734545	On test.
Chattogram area Total				2545	1926	36641126	
61	Ashuganj TPP Unit- 3	APSCL	1*150	0	0	0	Contract Expired
	Ashuganj TPP Unit- 4	APSCL	1*150	0	0	0	Contract Expired
	Ashuganj TPP Unit- 5	APSCL	1*150	0	0	0	Contract Expired
62	Ashuganj 225 MW CCPP	APSCL	1*142+1*75	221	208	4724000	FGMO
63	Ashuganj 450 MW CCPP(North)	APSCL	1*360	360	290	7772800	FGMO
64	Ashuganj 450 MW CCPP(South)	APSCL	1*360	360	270	7093000	FGMO
65	Ashuganj 420 MW CCPP(East)	APSCL	284*1+116*1	400	0	0	Under maint.
66	Ashuganj 50 MW PP	APSCL	14*3.968	45	48	1137744	
67	Ashuganj 55 MW PP (Precision)	QRPP	15*4	0	0	0	Contract Expired
67	Ashuganj 195 MW PP (APSCL-United)	IPP	20*9.73+1*16	195	145	2341818	Gas shortage
68	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	51	932188	
69	Ashuganj 150 MW PP (Midland)	IPP	22*7.015	150	107	558690	Low demand
70	Titas 50 MW Peaking PP	PDB	6*8.92	52	0	40784	Reserve
71	Chandpur 150 MW CCPP	IPP	1*106+1*57	163	0	0	Under maint.
72	Chandpur 200 MW (Desh energy)	IPP	12*18.4	200	86	1356000	Fuel shortage
73	Feni 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	0	382320	Engine problem
74	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	10	228420	
**	Import (Tatpara)	Imported power	0	160	152	3464640	
75	Jangalia 33 MW PP (Summit)	SIPP, PDB	4*8.73	33	33	802200	
76	Jangalia 52 MW PP (Lakdanavi)	IPP	6*8.92	52	52	837321	
77	Cumilla 25 MW PP (Summit)	SIPP, REB	3*3.67+2*6.97	25	12	223320	Engine problem
78	Daudkandi 200 MW PP (B.Trac)	IPP	15*14.1	0	0	0	Contract Expired
79	Feni Lanka Power	IPP	7*18.15+1*3.78	114	105	1781820	Engine problem
80	Chowmuhani 113 MW	IPP	12*9.78+2*3.1	113	86	829080	Fuel shortage
81	Bhairab 54.5 MW	IPP	3*18.2	54	35	787680	Machine problem
82	Chandpur 115(Doreen)	IPP	4*18.5+2*22.5	115	52	1278720	Fuel shortage
Cumilla Area Total				2896	1742	36572545	
83	RPCL 210MW CCPP	IPP	4*35+1*70	202	30	802590	Gas shortage
84	Tangail 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	0	226644	Engine problem
85	Jamalpur 95 MW PP(Powerpac)	IPP	12*8.924	0	0	0	Under maint.
86	Sanishabari 3 MW Solar Plant	IPP	1*3	3	0	11850	
87	Mymensingh 200 MW PP (United)	IPP	9*78*21	200	153	2114400	Fuel shortage
88	Jamalpur 115 MW PP (United)	IPP	9*78.12	115	94	942000	Fuel shortage
89	Sutahat 50 MW Solar PP	IPP	50	0	0	325750	
90	Tangail Pali Power Gen 22 MW	IPP	4*6.7	22	18	337920	Engine problem
Mymensingh Area Total				614	295	4764124	
91	Fenchugonj CCPP Phase-1	PDB	2*32+1*33	70	43	1006000	Machine problem
92	Fenchugonj CCPP Phase-2	PDB	2*35+1*35	90	30	696720	Machine problem
93	Kushara 163 MW CCPP (KPI)	IPP	1*109+1*54	163	112	2401200	ST Under maint.
94	Shahjibazar 330 MW CCPP	PDB	3*110	330	0	0	Under maint.
95	Fenchugonj 51 MW PP (Barakatullah)	RPP	19*2.90	51	50	1158600	
	Fenchuganj 44 MW (Energyprima)	NENP	12*3.3+5*2	50	47	1127304	
96	Hobiganj 11 MW PP Confidence-E	SIPP, REB	4*2.90	11	5	209328	
97	Shahjibazar GTPP Unit- 8 & 9	PDB	2*3.5	66	0	0	Under maint.
98	Shahjibazar 86 MW PP (Shahjibazar)	RPP	32*2.90	86	86	1921920	
99	Shahjibazar 100 MW GTTP	PDB	1*100	100	0	0	
100	Sylhet 225 MW CCPP	PDB	1*142+1*89	231	182	4736790	Machine problem
101	Sylhet 20 MW GTTP	PDB	1*20	20	17	398000	
	Sylhet 50 MW PP (EPL)	NENP	2*7.2	0	0	0	Contract Expired
102	Shahjahanulla 25 MW PP	SIPP, REB	3*9.34	25	8	190080	Engine problem
103	Bibiana-II 341 MW CCPP (Summit)	IPP	1*222+1*119	341	260	7025500	FGMO
104	Bibiyana-III 400 MW CCPP	PDB	285*1+134*1	400	409	9543000	
105	Sylhet 10MW PP (Desh)	RPP	6*1.95	10	10	247680	
106	Bibiyana South 400 MW	PDB	400 MW	383	397	9133300	
Sylhet Area Total				2427	1656	39795422	
107	Bheramara GTTP Unit-3	PDB	1*20	16	0	0	
**	Bheramara (HVDC)	Imported power	2*500	1000	778	21616000	
108	Khulna 115 PP MW (KPLC-2)	NENP	7*17	115	82	501120	
109	Fariapur 50 MW Peaking PP	PDB	6*6.98	54	0	41760	
110	Khulna 225 MW CCPP	NWPGCL	1*150+1*75	230	0	0	Reserve
111	Gopalganj 100 MW Peaking PP	PDB	16*6.98	109	0	0	Low demand
112	Bheramara 410 MW CCPP	NWPGCL	1*278+1*132	410	0	0	Gas shortage
113	Noapara 40 MW PP (Khanjahan Ali)	NENP	5*8.5	40	8	49875	Low demand
114	Noapara 100 MW PP (Bangla Trac)	IPP	9*14.4	0	0	0	Contract Expired
114	Rupsha 105 MW PP (Oron rupsha)	IPP	6*18.445	105	41	56688	