

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date: 28-Sep-23

Page -2

| Sl. No. | Name of the Power Stations | Producer | Installed Capacity | Present Capacity | | Peak Hour Generation | | Energy Generated | Remarks |
|------------------------------|--|----------------|--------------------|----------------------------|-------------|----------------------|-----|------------------------|---------|
| | | | | MW | MW | MW | KWH | | |
| | | | | Unit No. X Capacity | | | | | |
| 1 | Ghorasal Repowered CCPP-Unit-3 (GT) | PDB | 1280 | 280 | 0 | 0 | 0 | Under maint. | |
| 2 | Ghorasal Repowered CCPP Unit-4 | PDB | 1210 | 180 | 150 | 367094 | 0 | Under maint. | |
| 3 | Ghorasal 365 MW CCPP Unit-7 | PDB | 1240+1122 | 365 | 0 | 0 | 0 | Air Compressor problem | |
| 4 | Ghorasal 78.5 MW PPMAX | QRPP | 240 | 0 | 0 | 0 | 0 | Contract Expired | |
| 5 | Ghorasal 108 MW PP (Regent) | IPP | 3*435 | 108 | 42 | 903272 | 0 | Gas shortage | |
| 6 | Haripur GTPP | SBU, PDB | 232 | 20 | 0 | 0 | 0 | Under maint. | |
| 7 | Haripur 412 MW CCPP | EGCB | 1*273+1139 | 412 | 398 | 9177080 | 0 | Gas shortage | |
| 8 | Haripur 360 MW CCPP(HPL) | IPP | 1*235+1125 | 360 | 327 | 7320000 | 0 | Gas shortage | |
| 9 | Meghnaghat 450 MW CCPP(MPL) | IPP | 2*150+1150 | 450 | 420 | 9365500 | 0 | Gas shortage | |
| 10 | Meghnaghat 100 MW PP (Acorn) | NENP | 1210 | 9 | 0 | 221780 | 0 | Low demand | |
| 11 | Meghnaghat CCPP(Summit) | IPP | 2*110+1110 | 335 | 272 | 6858551 | 0 | FGMO | |
| 12 | Madanganj 102 PP(Summit) | NENP | 6*17 | 102 | 31 | 610770 | 0 | Low demand | |
| 13 | Madanganj-55 MW PP(Summit) | IPP | 3*17.08+111.3 | 55 | 15 | 263714 | 0 | Fuel shortage | |
| 14 | Keraniganj 100 MW PP (Powerpac) | NENP | 8*13.45 | 75 | 0 | 18328 | 0 | Reserve | |
| 15 | Narainpuri 22 MW PP (Doreen) | SIPP, REB | 8*2.90 | 22 | 19 | 354428 | 0 | Engine problem | |
| 16 | 210 MW Siddhirganj PP | PDB | 1210 | 115 | 0 | 0 | 0 | Under maint. | |
| 17 | Siddhirganj 2*120 MW GTPP | EGCB | 2*105 | 210 | 160 | 2709000 | 0 | Gas shortage | |
| 18 | Siddhirganj 109 PP(Dutch Bangla) | NENP | 12*8.9 | 100 | 14 | 480000 | 0 | Low demand | |
| 19 | Siddhirganj 335 MW CCPP | EGCB | 1*217+118 | 335 | 0 | 7945 | 0 | Under maint. | |
| 20 | Gaspara 102 MW PP (Digital Power) | IPP | 12*8.924 | 102 | 16 | 654624 | 0 | Low demand | |
| 21 | Katpatti 52 MW PP (Siraha) | IPP | 7*7.9 | 0 | 0 | 0 | 0 | Fuel shortage | |
| 22 | Kamalaghat 54 MW PP(Banco Energy) | IPP | 3*18 | 54 | 54 | 389160 | 0 | Gas shortage | |
| 23 | Kodda 150 MW PP | BPDB-RPCL | 9*17.06 | 149 | 148 | 1638720 | 0 | Gas shortage | |
| 24 | Manikganj 55 MW PP (Northern) | IPP | 3*19.3 | 55 | 35 | 805802 | 0 | Engine problem | |
| 25 | Nabaganj 55 MW PP (Southern power) | IPP | 3*19.3 | 55 | 55 | 508153 | 0 | Engine problem | |
| 26 | Bosila 108 MW PP(RCL) | IPP | 12*8.775+13.5 | 0 | 0 | 0 | 0 | Under maint. | |
| 27 | Summit Power (Madhabdi+Ashulia) | SIPP, REB | 3*3.67+4*8.73 | 80 | 37 | 871440 | 0 | Engine problem | |
| 28 | Maona 33 MW PP(Summit) | SIPP, REB | 4*8.73 | 33 | 25 | 591700 | 0 | Engine problem | |
| 29 | Rugganj 33 MW PP(Summit) | SIPP, REB | 4*8.73 | 33 | 29 | 720700 | 0 | Engine problem | |
| 30 | Gaopur 52 MW PP | RPCL | 5*9.9 | 25 | 25 | 281280 | 0 | Fuel shortage | |
| 31 | Tongi 80 MW GTPP | PDB | 1*105 | 105 | 0 | 0 | 0 | Gas shortage | |
| 32 | Kodda 300 MW PP Unit-2 (Summit) | IPP | 18*1.076 | 300 | 15 | 546982 | 0 | Low demand | |
| 33 | Bramhangon 100 MW PP (Aggreko) | IPP | 114*0.959 | 0 | 0 | 0 | 0 | Contract Expired | |
| 34 | Auraha 100MW PP (Aggreko) | IPP | 0.85*23+0.95*91 | 0 | 0 | 0 | 0 | Contract Expired | |
| 35 | Kodda 149 MW PP Unit-1 (Summit) | IPP | 8*16.45+97 | 149 | 116 | 908352 | 0 | Fuel shortage | |
| 36 | Gaopur 100 MW PP | RPCL | 6*17.5 | 105 | 105 | 1155840 | 0 | Fuel shortage | |
| 37 | Meghnaghat 104 MW PP (OPCL) | IPP | 18.5*6 | 104 | 43 | 769920 | 0 | Fuel shortage | |
| 38 | Manikganj 162MW PP(MPGL) | IPP | 9*18 | 162 | 126 | 1117440 | 0 | Fuel shortage | |
| 39 | Spectra Solar Plant Ltd | IPP | 35 | 35 | 0 | 218847 | 0 | Low demand | |
| 40 | Kanchan Purbasolar Power Generation Ltd. | IPP | 18*13 | 55 | 17 | 433080 | 0 | On test. | |
| 41 | Meghnaghat Uniques power | IPP | 589 | 0 | 0 | 0 | 0 | On test. | |
| 42 | Summit Meghnaghat-2 589 MW(Gas) | IPP | 589 | 0 | 0 | 0 | 0 | On test. | |
| Dhaka area Total | | | | 5422 | 2703 | 5322582 | | | |
| 41 | Chattogram TPP-1 | PDB | 1*210 | 180 | 100 | 2500000 | 0 | Gas shortage | |
| 42 | Chattogram TPP-2 | PDB | 1*210 | 180 | 0 | 0 | 0 | Gas shortage | |
| 43 | Razran 25 MW PP | RPCL | 3*8.9 | 25 | 17 | 236770 | 0 | Fuel shortage | |
| 44 | Teknaf 20MW PP (Solartech) | IPP | 20 | 20 | 0 | 86265 | 0 | Low demand | |
| 45 | Patenga 50MW PP (Baraka) | IPP | 8*6.98 | 50 | 6 | 153600 | 0 | Low demand | |
| 46 | Kapla Hydro Unit-1,2,3,4,5 | PDB | 2*40+3*50 | 230 | 201 | 4747075 | 0 | Low demand | |
| 47 | Sikalbaha 225MW | PDB | 1*150+1*75 | 225 | 219 | 5135125 | 0 | Under maint. | |
| 48 | Sikalbaha Peaking GT | PDB | 1*150 | 0 | 0 | 0 | 0 | Fuel shortage | |
| 49 | Sikalbaha 105 MW PP (Baraka Sikalbaha) | IPP | 6*17.5 | 105 | 17 | 429890 | 0 | Engine problem | |
| 50 | Hathazari 100 MW peaking PP | PDB | 11*8.9 | 98 | 70 | 1132944 | 0 | Fuel shortage | |
| 51 | Dohazari-Kalaish 100 MW Peaking | PDB | 6*17 | 102 | 16 | 86365 | 0 | Fuel shortage | |
| 52 | Juidah 100 MW Unit-1 (Acorn) | NENP | 8*13.45 | 100 | 58 | 1104240 | 0 | Fuel shortage | |
| 53 | Juidah 100 MW Unit-2 (Acorn) | IPP | 8*13.5 | 50 | 50 | 800640 | 0 | Fuel shortage | |
| 54 | Barabkunda 22 MW PP (Regent) | SIPP, PDB | 8*2.90 | 22 | 9 | 209088 | 0 | Engine problem | |
| 55 | Malancha, Cig. EPZ (United) | IPP | 5*8.73+3*9.34 | 0 | 36 | 691680 | 0 | Fuel shortage | |
| 56 | Chattogram 108 MW PP (ECPV) | IPP | 16*7 | 108 | 0 | 0 | 0 | Fuel shortage | |
| 57 | Kapla 7 MW Solar PP | PDB | 7.4 MW | 7 | 0 | 24602 | 0 | Low demand | |
| 58 | Arwara 300 MW PP (United) | IPP | 17*17+24 | 300 | 265 | 2458909 | 0 | Low demand | |
| 59 | Jodica Power | IPP | 3*18.55+13.6 | 54 | 53 | 440490 | 0 | Fuel shortage | |
| 60 | Karnaphuli Power Ltd. | IPP | 18.415*6+8.5 | 110 | 55 | 1339849 | 0 | Fuel shortage | |
| 61 | Juidah unit-2 (Acorn) | IPP | 8*13.6 | 100 | 50 | 762240 | 0 | Fuel shortage | |
| 62 | Anlima Energy Ltd. | IPP | 6*21.2 | 116 | 34 | 671182 | 0 | Fuel shortage | |
| 63 | Mirshara 150 MW | BPDB-RPCL | 18*9 | 163 | 16 | 185709 | 0 | Low demand | |
| 64 | SS Power | SS Power | 0 | 0 | 551 | 9327271 | 0 | On test. | |
| 65 | Cox's Bazar Wind | IPP | 66 | 0 | 0 | 44640 | 0 | On test. | |
| 66 | Matarbari 2*600 MW (CPGCL) | CPGCL | 0 | 0 | 270 | 10836363 | 0 | On test. | |
| Chattogram area Total | | | | 2545 | 2093 | 43423946 | | | |
| 61 | Ashuganj TPP Unit-3 | APSCCL | 1*150 | 0 | 0 | 0 | 0 | Contract Expired | |
| 62 | Ashuganj TPP Unit-4 | APSCCL | 1*150 | 0 | 0 | 0 | 0 | Contract Expired | |
| 63 | Ashuganj TPP Unit-5 | APSCCL | 1*150 | 0 | 0 | 0 | 0 | Contract Expired | |
| 64 | Ashuganj 225 MW CCPP | APSCCL | 1*142+1*75 | 221 | 172 | 4488000 | 0 | FGMO | |
| 65 | Ashuganj 450 MW CCPP(North) | APSCCL | 1*360 | 360 | 280 | 7255700 | 0 | FGMO | |
| 66 | Ashuganj 450 MW CCPP(South) | APSCCL | 1*360 | 360 | 270 | 6699000 | 0 | FGMO | |
| 67 | Ashuganj 420 MW CCPP(East) | APSCCL | 284*1+116*1 | 400 | 300 | 1744000 | 0 | FGMO | |
| 68 | Ashuganj 50 MW PP | APSCCL | 14*3.68 | 45 | 45 | 1100684 | 0 | Low demand | |
| 69 | Ashuganj 55 MW PP (Precision) | QRPP | 15*4 | 0 | 0 | 0 | 0 | Contract Expired | |
| 70 | Ashuganj 195 MW PP (APSCCL-United) | IPP | 20*9.73+1*16 | 195 | 8 | 1639273 | 0 | Gas shortage | |
| 71 | Ashuganj 51 MW PP (Midland) | IPP | 6*9.34 | 51 | 51 | 955688 | 0 | Low demand | |
| 72 | Ashuganj 150 MW PP (Midland) | IPP | 22*7.015 | 150 | 43 | 788181 | 0 | Low demand | |
| 73 | Titas 50 MW Peaking PP | IPP | 6*8.92 | 50 | 30 | 282240 | 0 | Low demand | |
| 74 | Chandpur 150 MW CCPP | PDB | 1*106+1*57 | 163 | 0 | 0 | 0 | Under maint. | |
| 75 | Chandpur 200 MW (Desh energy) | IPP | 12*18.4 | 200 | 17 | 428160 | 0 | Fuel shortage | |
| 76 | Feni 22 MW PP (Doreen) | SIPP, PDB | 8*2.90 | 22 | 18 | 432108 | 0 | Engine problem | |
| 77 | Feni 11 MW PP (Doreen) | SIPP, REB | 4*2.90 | 11 | 10 | 234720 | 0 | Engine problem | |
| 78 | Imported (Titas) | Imported power | 0 | 0 | 148 | 3420480 | 0 | Low demand | |
| 79 | Jangalia 33 MW PP (Summit) | IPP | 4*8.73 | 33 | 32 | 788600 | 0 | Low demand | |
| 80 | Jangalia 52 MW PP (Lakdanavi) | IPP | 6*8.92 | 52 | 52 | 824102 | 0 | Low demand | |
| 81 | Cumilla 25 MW PP (Summit) | SIPP, REB | 3*3.67+2*6.97 | 25 | 12 | 266300 | 0 | Engine problem | |
| 82 | Daukandi 200 MW PP (B.Trac) | IPP | 1*541.4 | 0 | 0 | 0 | 0 | Contract Expired | |
| 83 | Feni Lanka Power | IPP | 7*18.15+1*13.78 | 114 | 105 | 212280 | 0 | Fuel shortage | |
| 84 | Chowmuhani 113 MW | IPP | 12*9.78+2*3.1 | 113 | 86 | 842520 | 0 | Fuel shortage | |
| 85 | Bhairab 54.5 MW | IPP | 3*18.2 | 54 | 35 | 685080 | 0 | Machine problem | |
| 86 | Chandpur 115(Doreen) | IPP | 4*18.5+2*22.5 | 115 | 54 | 1303680 | 0 | Fuel shortage | |
| Cumilla Area Total | | | | 2896 | 1771 | 36274576 | | | |
| 83 | RPCL 210MW CCPP | IPP | 4*36+1*70 | 202 | 41 | 1031040 | 0 | Gas shortage | |
| 84 | Tangail 22 MW PP (Doreen) | SIPP, PDB | 8*2.90 | 22 | 19 | 376524 | 0 | Engine problem | |
| 85 | Jamalpur 95 MW PP(Powerpac) | IPP | 12*8.924 | 0 | 0 | 0 | 0 | Under maint. | |
| 86 | Sarishabari 3 MW Solar Plant | IPP | 1*3 | 3 | 0 | 10850 | 0 | Low demand | |
| 87 | Mymensingh 200 MW PP (United) | IPP | 9*79.21 | 200 | 125 | 1932000 | 0 | Fuel shortage | |
| 88 | Jamalpur 115 MW PP (United) | IPP | 9*79.12 | 115 | 94 | 817200 | 0 | Fuel shortage | |
| 89 | Sutahat 50 MW Solar PP | IPP | 50 | 50 | 0 | 357310 | 0 | Low demand | |
| 90 | Tangail Pali Power Gen 22 MW | IPP | 4*6.7 | 22 | 18 | 352320 | 0 | Engine problem | |
| Mymensingh Area Total | | | | 614 | 297 | 4877244 | | | |
| 91 | Fenchuganj CCPP Phase-1 | PDB | 2*32+1*33 | 70 | 43 | 981000 | 0 | Machine problem | |
| 92 | Fenchuganj CCPP Phase-2 | PDB | 2*35+1*35 | 90 | 30 | 667320 | 0 | Machine problem | |
| 93 | Kushaura 353 MW CCPP (MP) | IPP | 1*1109+1*154 | 163 | 80 | 2241245 | 0 | ST Under maint. | |
| 94 | Shahbazar 330 MW CCPP | PDB | 3*110 | 330 | 0 | 0 | 0 | Under maint. | |
| 95 | Fenchuganj 51 MW PP (Barakallah) | RPP | 19*2.90 | 51 | 50 | 1128600 | 0 | Low demand | |
| 96 | Fenchuganj 44 MW (Energyprima) | NENP | 12*3.3+5*2 | 50 | 47 | 1328544 | 0 | Engine problem | |
| 97 | Hobiganj 11 MW PP Confidence-E | SIPP, REB | 4*2.90 | 11 | 5 | 202464 | 0 | Engine problem | |
| 98 | Shahbazar GTPP Unit-1 & 2 | PDB | 2*35 | 66 | 0 | 0 | 0 | Under maint. | |
| 99 | Shahbazar 86 MW PP (Shahbazar) | RPP | 32*2.90 | 86 | 84 | 1881600 | 0 | Low demand | |
| 100 | Shahbazar 100 MW GTPP | PDB | 1*100 | 100 | 0 | 0 | 0 | Under maint. | |
| 101 | Sylhet 225 MW CCPP | PDB | 1*142+1*89 | 231 | 179 | 3688820 | 0 | Machine problem | |
| 102 | Sylhet 20 MW GTPP | PDB | 1*20 | 20 | 17 | 393000 | 0 | Low demand | |
| 103 | Sylhet 50 MW PP (EPL) | NENP | 2*22 | 0 | 0 | 0 | 0 | Contract Expired | |
| 104 | Shahjanuilla 25 MW PP | SIPP, REB | 3*9.34 | 25 | 8 | 187584 | 0 | Engine problem | |
| 105 | Bibiana-II 341 MW CCPP (Summit) | IPP | 1*222+1*119 | 341 | 280 | 7004500 | 0 | FGMO | |
| 106 | Bibiyana-III 400 MW CCPP | PDB | 285*1+134*1 | 400 | 380 | 9132000 | 0 | Low demand | |
| 107 | Sylhet 10MW PP (Desh) | RPP | 6*1.95 | 10 | 10 | 247500 | 0 | Low demand | |
| 108 | Bibiyana South 400 MW | PDB | 400 MW | 383 | 387 | 6864700 | 0 | Low demand | |
| Sylhet Area Total | | | | 2427 | 1600 | 37588577 | | | |
| 107 | Bheramara GTTP Unit-3 | PDB | 1*20 | 16 | 0 | 0 | 0 | Low demand | |
| 108 | Bheramara (HVDC) | Imported power | 2*500 | 1000 | 778 | 21061818 | 0 | Low demand | |
| 109 | Khulna 115 PP MW (RPCL-2) | NENP | 7*17 | 115 | 16 | 296640 | 0 | Low demand | |
| 110 | Faridpur 50 MW Peaking PP | PDB | 6*8.98 | 50 | 0 | 21120 | 0</ | | |