

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 3564667, 9551095

Month October, 2023					Day : Thursday				Date : 05.10.23				
Probable Maximum Demand : 13200 MW					Probable Maximum Generation : 16017 MW				Rule Curve = 106.27 ft.				
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 107.88 ft		Today = 107.84 ft		05.10.23		04.10.23		
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	04.10.23 (Yesterday)		05.10.23 (Today)		Gen. shortfall for :		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gas/Coal/Water Limitation MW		Machines shut down (MW)	Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening					
(A) Plants in operation:													
1	Ghorasal Repowered CAPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work	
2	a) Ghorasal Repowered CAPP Unit-4 b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	180	130	150	150	150				
3	Ghorasal 365 MW CAPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	190		Gas Shortage	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	22	22	32	32				
5	Tong 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0				
7	Haripur 360MW CAPP(HPL)	Gas (IPP)	1x235+1x125	360	360	307	341	330	330				
8	Meghnaghat 450 MW CAPP(MPL)	Gas (IPP)	2x140+1x170	450	450	350	350	450	450				
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115		Under Overhauling	
10	Haripur 412 MW CAPP	Gas (EGCB)	1x273+1x139	412	412	394	422	412	412				
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	125	78	0	0	132		Gas Shortage	
12	Siddhirgonj 335 MW CAPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335		Under maint.	
13	Meghnaghat 335MW CAPP(Summit)	Gas (IPP)	2x110+1x110	335	335	290	254	150	150				
14	Madangan-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	8	15	15	55				
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	42	33	102	102				
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	14	18	20	20				
17	Summit Power(Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	35	39	39	39				
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	25	25				
19	Ruggan 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	8	22	25	25				
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	25	8	25				
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	35	50	34	105				
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	32	98	32	115				
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	17	35	54				
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	0	300	300				
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	17	90	50	135				
26	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	17	35	55				
27	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	35	35	35				
28	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	34	34	53	70				
29	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	54	54	54	108				
30	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	7	0	35	0				
31	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	34	35	54	54				
32	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	8	8	92	92				
33	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	0	0	84	84				
34	Madangan 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	17	85	85				
35	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	0	55	55				
	Meghnaghat Unique Power	Gas				0	0	0	0				
	Meghnaghat 589 MW CAPP(Summit)	Gas				0	0	0	0				
Dhaka Zone Total				5604	5422	2066	2249	2791	3162	295	842		
36	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	157	195	199	199				
37	a) Chattogram TPP-1 b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	79	80	0	0	100		Gas Shortage	
		Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.	
38	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	3	0	5	0				
39	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	17	8	17				
40	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	8	0	20	0				
41	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	6	6	40				
42	Sikalbaha 105 MW PP (Baraka Sikabaha)	HFO (IPP)	6x18.415	105	105	51	51	51	51				
43	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150		Under maint.	
44	Sikalbaha 225 MW CAPP	Gas (PDB)	1 x 150+1 x 75	225	225	221	226	225	225				
45	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	70	120	70	300				
46	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	25	25	25				
47	Dohazari-Kalash 100 MW Peaking	HFO (PDB)	6x17.0	102	102	17	16	17	17				
48	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	64	40	70				
49	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	11	11	11	11				
	* Malancha, Ctg.EPZ (United)	Gas	5x8.73+3x9.34			7	25	7	25				
50	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0				
51	Sikalbaha 54 MW PP (Jodiad Power)	HFO (IPP)	3x18.5+1x3.6	54	54	17	29	17	54				
52	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	55	67	55	55				
53	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	25	30	25	25				
54	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	25	25	25	25				
55	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	34	51	34	51				
56	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	52	0	54	150				
	SS Power Unit-1	Coal (IPP)				300	300	612	612			Test run	
	Matarbari 2*600 MW (CPGCL)	Coal				555	554	390	390			Test run	
	Cox's Bazar Wind PP	(Wind) (IPP)				1	7	10	20				
Chattogram Zone Total				2605	2545	1727	1899	1906	2362	100	330		
57	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	5	5	5	40			Gas Shortage	
58	Ashuganj 225 MW CAPP	Gas (APSCCL)	1x142+1*75	221	221	185	178	200	200	43		Gas Shortage	
59	Ashuganj 450 MW CAPP(South)	Gas (APSCCL)	1x360	360	360	275	270	300	300	90		Gas Shortage	
60	Ashuganj 450 MW CAPP(North)	Gas (APSCCL)	1x361	360	360	285	280	300	300	80		Gas Shortage	
61	Ashuganj 420 MW CAPP(East)	Gas (APSCCL)	1x284+1x116	400	400	285	285	240	280	115		Gas Shortage	
62	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*116	195	195	0	0	0	195			Gas Shortage	
63	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	5	35	50	50				
64	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	28	150	150				
65	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	31	0	31				
66	Chandpur 150 MW CAPP	Gas (PDB)	1x106+1x57	163	163	0	0	0	0	163		Under maint.	
67	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	17	17	17				
68	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	18	18	18				
69	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
70	Jangalia 33 MW PP (Summit))	Gas (SIPP, PDB)	4x8.73	33	33	25	33	33	33				
71	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	8	52	52				
72	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	12	12	12	12				
73	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	3	17	17				
74	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	27	55	28	85				
75	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	35	35	35	35				
76	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	72	93	72	94				
**	Import (Tirupura)	India		160	160	124	120	149	165				
Cumilla Zone Total				2904	2896	1406	1517	1689	1855	563	163		
77	RPCL 210MW CAPP	Gas (IPP)	4x35+1x70	210	202	23	24	32	40	178		Gas Shortage	
78	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	16	18	18	18				
79	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	38	108	37	100				
80	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	116	84	115	142				
81	Sarishabani 3 MW Solar Plant	Solar (IPP)	1x3	3	3	0	0	1.6	0				
82	Sutiakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	16	0	50	0				
83	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	18	18	18	18				
Mymensingh Zone Total				622	614	227	252	272	318	178	0		

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	04.10.23 (Yesterday)		05.10.23 (Today)		04.10.23 (Yesterday)		Status of Machines under shut-down/ Maintenance		
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW		Machines shut down (MW)	Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening					
84	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 Under maint.		
85	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	40	40	40	40		50	GT-4 Under maint.		
86	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	22	42	50	50					
87	Kushiara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	112	112	80	112		54	ST Under maint.		
88	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8					
89	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	56	57	51	60					
90	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.		
91	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	0	0	0	0	86		Gas Shortage		
92	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	187	184	180	185					
93	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	16	17	17	17					
94	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10					
95	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16					
96	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	265	290	300					
97	Bibiana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	378	378	400	400					
98	Bibiana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	387	400	315	400					
99	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work		
100	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	20	47	40	46					
Sylhet Zone Total						2472	2427	1595	1619	1540	1687	86	561	
101	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0					
102	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0	410		Gas Shortage		
103	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	25	40					
104	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	40					
105	Khulna 225 MW CCPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0					
106	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	0	53	53					
107	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	15	50	100					
108	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	7	0	100	0					
109	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	16	16	66					
110	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	0	0	24					
111	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BHPCL)	1x617	617	617	365	361	520	570					
112	Khulna 330 MW CCPP (GT)	Gas/HSD (BPD)	1x220	220	220	102	103	330	330					
**	Bheramara (H/DC)	India		1000	1000	900	901	909	909					
Khulna Zone Total						3125	3121	1374	1396	2003	2132	410	0	
113	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	16	110					
114	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	17	16	23	25					
115	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	80	130	135	135					
116	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	650	750	650	650					
117	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	35	150					
118	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	140	140	140	140					
119	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	180	220	220	220					
Barishal Zone Total						2265	2265	1067	1256	1219	1430	0	0	
120	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage		
121	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.		
122	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	0	38					
123	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0					
124	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	5	0	0					
125	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	40	50	90					
126	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	40	30	40					
127	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	34	42					
128	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	30	24	32					
129	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	130	205	170	190					
130	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage		
131	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	130	170	170	190					
132	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	230	230	150	390	184		Gas Shortage		
133	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	0	8	8	8					
134	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	0	52	52					
135	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	35	35	113					
136	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	35	35	50					
137	Amnara 50 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	0	0	28	28					
138	Sirajgonj 5.55 MW Solar	Solar (NWPGL)	1x6	6	6	1	0	6	0					
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	1069	1269	1200	1400					
Rajshahi Zone Total						3653	3631	1560	2067	1992	2663	475	100	
139	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage		
140	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling		
141	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	180	180	180	180					
142	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
143	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x.23	113	113	0	81	34	113					
144	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
145	Maipara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	2	0	8	0					
146	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	35	35	115					
147	Lalmohana 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	3	0	30	0					
148	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	38	0	130	0					
Rangpur Zone Total						1030	950	223	306	417	408	85	85	
Sub-total: Plants in operation						24280	23871	11245.0	12561	13829	16017	2192	2081	
(B) Plants under long term maintenance/ contract expired														
149	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0					
148	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0					
149	Bosilla 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0					
150	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	0	0	0	0	0					
151	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	0	0	0	0	0					
Sub-Total: Plants under long term maintenance/ contract expired						331	0	0	0	0	0	0	0	
Gross Total						24611	23871	11245	12561	13829	16017	2192	2081	
(C) Actual data of 04.10.23 (Yesterday) Wednesday :														
01.	Max. Demand at eve. peak (Generation end)	:	12582 MW, at =	19:00 hrs		12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	12099 MW, at =	19:00 hrs		Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW	
03.	Highest Generation (Generation end)	:	12561 MW, at =	19:00 hrs		Dhaka	4660	4660	0	Mymensingh	1023	1003	20	
04.	Minimum Generation (Generation end)	:	10027 MW, at =	7:00 hrs		Chattoagram	1279	1279	0	Sylhet	507	507	0	
05.	Day-peak Generation (Generation end)	:	11245 MW, at =	12:00 hrs		Khulna	1336	1336	0	Barishal	344	344	0	
06.	Evening-peak Generation (Generation end)	:	12561 MW, at =	19:00 hrs		Rajshahi	1200	1200	0	Rangpur	695	695	0	
07.	Evening Peak Load-shed (Sub-station end)	:	20 MW, at =	19:00 hrs		Cumilla	1056	1056	0					
08.	Minimum Generation Forecast up to 8:00 hrs.	:	8825 MW, at =	5:00 hrs						Total	12099	12079	20	
09.	Generation shortfall at evening peak due to :	:				13.	Fuel cost :	(a) Gas = 142629425 Taka	(c) Coal = 548543407 Taka					
a) Gas/LF limitation	:	2107 MW					(b) Oil = 299170254 Taka		Total = 990343086 Taka					
d) Coal supply Limitation	:	85 MW				14.	Maximum Temperature in Dhaka was : 30°C							
b) Low water level in Kaptai lake	:	0 MW				15.	Export through East-West interconnections :							
c) Plants under shut down/ maintenance	:	2081 MW					At evening peak-hour	:	11245 MW, at	19:00 hrs				
10.	Total Energy (Generation + India Import)	:	271.41 MMCFD				Maximum	:	444 MW, at	21:00 hrs				
	By Gas = 133.816 MKWH		By Oil = 25.283 MKWH				Energy	:	0 MKWH					
	By Coal = 83.026 MKWH		By Hydro = 4.488 MKWH											
	By Solar= 0.748 MKWH													
11.	Total Gas Supplied	:	1018.02 MMCFD											
(D) Forecast of 05.10.23 (Today) Thursday :														
01.	Maximum Demand	:	13200 MW (Generation end)			04.	Maximum Load-shed : 0 MW At evening peak (Sub-station end)							
02.	Maximum Generation	:	16017 MW (Generation end)			05.	Total Generation : 285.22 MKWh							
03.	Reserve / Shortage	:	2817 MW (Generation end)			06.	Probable Max. Temperature in Dhaka : 30°C							