

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 3564667, 9551095

Month October, 2023					Day : Friday				Date : 06.10.23					
Probable Maximum Demand : 11500 MW					Probable Maximum Generation : 15116 MW									
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 107.84 ft		Today = 107.81 ft		Rule Curve = 106.45 ft					
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	05.10.23 (Yesterday)		06.10.23 (Today)		05.10.23 (Yesterday)		06.10.23 (Today)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Machines shut down (MW)		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	Gas/Coal/Water Limitation MW					
(A) Plants in operation:														
1	Ghorasal Repowered CAPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260		Under project work	
2	a) Ghorasal Repowered CAPP Unit-4	Gas (PDB)	1 x 210	210	180	150	130	150	150					
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190			Gas Shortage	
3	Ghorasal 365 MW CAPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0					
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	52	52	52	52					
5	Tong 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105			Gas Shortage	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0					
7	Haripur 360MW CAPP(HPL)	Gas (IPP)	1x235+1x125	360	360	242	222	220	330					
8	Meghnaghat 450 MW CAPP(MPL)	Gas (IPP)	2x140+1x170	450	450	330	225	225	225					
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115		Under Overhauling	
10	Haripur 412 MW CAPP	Gas (EGCB)	1x273+1x139	412	412	403	343	412	412					
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0		210		Gas Shortage	
12	Siddhirgonj 335 MW CAPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0		335		Under maint.	
13	Meghnaghat 335MW CAPP(Summit)	Gas (IPP)	2x110+1x110	335	335	150	131	150	150					
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	15	15	55					
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	50	66	102	102					
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	20	20	20	20					
17	Summit Power(Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	38	37	39	39					
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	25	25					
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	14	14	25	25					
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	25	8	25					
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	35	35	34	105					
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	32	16	48	132					
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	54	35	54					
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	70	0	300	300					
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	17	71	50	100					
26	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	55	35	55					
27	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	37	35	35					
28	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	34	71	53	70					
29	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	35	17	54	108					
30	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	0	0	35	0					
31	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	54	34	54	54					
32	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	10	32	92	92					
33	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	0	17	84	84					
34	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	17	30	85	85					
35	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	0	55	55					
	Meghnaghat Unique Power	Gas				0	0	0	0					
	Meghnaghat 589 MW CAPP(Summit)	Gas				0	0	0	0					
Dhaka Zone Total				5604	5422	1888	1774	2492	2939	295	920			
36	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	201	200	199	199					
37	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	67	0	0	0	180			Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180		Under maint.	
	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	1	0	5	0					
39	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	8	8	17					
40	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	13	0	20	0					
41	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	40	6	40					
42	Sikalbaha 105 MW PP (Baraka Sikabaha)	HFO (IPP)	6x18.415	105	105	17	34	17	17					
43	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150		Under maint.	
44	Sikalbaha 225 MW CAPP	Gas (PDB)	1 x 150+1 x 75	225	225	162	162	162	162					
45	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	87	150	70	300					
46	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	27	41	25	37					
47	Dohazari-Kalash 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	31	34	34					
48	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	32	40	70					
49	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	11	11	11	11					
*	Malancha, Ctg.EPZ (United)	Gas	5x8.73+3x9.34			0	18	20	35					
50	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0					
51	Sikalbaha 54 MW PP (Jodiach Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	54					
52	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	53	75	55	55					
53	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	35	38	25	25					
54	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	25	12	25	35					
55	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	34	51	34	34					
56	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	0	0	54	150					
	SS Power Unit-1	Coal (IPP)				340	450	0	0				Test run	
	Matarbari 2*600 MW (CPGCL)	Coal				355	356	390	390				Test run	
	Cox's Bazar Wind PP	(Wind) (IPP)				18	9	10	20					
Chattogram Zone Total				2605	2545	1477	1735	1227	1685	180	330			
57	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	5	5	5	5		40		Gas Shortage	
58	Ashuganj 225 MW CAPP	Gas (APSCCL)	1x142+1*75	221	221	205	179	200	200		42		Gas Shortage	
59	Ashuganj 450 MW CAPP(South)	Gas (APSCCL)	1x360	360	360	240	270	300	300		90		Gas Shortage	
60	Ashuganj 450 MW CAPP(North)	Gas (APSCCL)	1x361	360	360	340	280	0	150		80		Gas Shortage	
61	Ashuganj 420 MW CAPP(East)	Gas (APSCCL)	1x284+1x116	400	400	240	240	240	280		160		Gas Shortage	
62	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*116	195	195	0	0	45	60		195		Gas Shortage	
63	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	50	50					
64	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	7	50	150	150					
65	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	31					
66	Chandpur 150 MW CAPP	Gas (PDB)	1x106+1x57	163	163	0	0	0	0		163		Under maint.	
67	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	0	17	17	17					
68	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	18	18	18					
69	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	0	11	11	11					
70	Jangalia 33 MW PP (Summit))	Gas (SIPP, PDB)	4x8.73	33	33	30	25	33	33					
71	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	25	52	52					
72	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	10	12	12	12					
73	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	34	105	105					
74	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	28	85	28	85					
75	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	35	35					
76	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	72	96	72	94					
**	Import (Tirupura)	India		160	160	134	148	149	165					
Cumilla Zone Total				2904	2896	1397	1563	1522	1853	607	163			
77	RPCL 210MW CAPP	Gas (IPP)	4x35+1x70	210	202	23	23	32	40		179		Gas Shortage	
78	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	10	18	18					
79	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	70	45	37	100					
80	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	18	35	115	142					
81	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	0	0	1.6	0					
82	Sutiakhali 50 MW Solar PP	Solar (IPP)	1x50	50	50	7	0	50	0					
83	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22									

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	05.10.23 (Yesterday)		06.10.23 (Today)		05.10.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)		
84	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	40	43	43		30	GT-1 Under maint.	
85	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	40	40	40	40		50	GT-4 Under maint.	
86	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	42	47	50	50				
87	Kushiara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	112	112	80	112		54	ST Under maint.	
88	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	8	8	8				
89	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	50	57	60	60				
90	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
91	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	0	0	0	0	86		Gas Shortage	
92	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	184	184	185	185				
93	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	0	17	17	17				
94	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
95	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	8	16	16				
96	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	315	270	300	300				
97	Bibiana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	402	402	400	400				
98	Bibiana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	385	400	220	400				
99	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
100	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	42	49	40	46				
Sylhet Zone Total				2472	2427	1644	1644	1469	1687	86	564		
101	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
102	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0	410		Gas Shortage	
103	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	25	40				
104	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	40				
105	Khulna 225 MW CCPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0				
106	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	42	54	54				
107	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	100	100				
108	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	33	0	100	0				
109	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	12	16	66				
110	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	0	0	24				
111	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BHPCL)	1x617	617	617	372	507	520	570				
112	Khulna 330 MW CCPP (GT)	Gas/HSD (BPD)	1x220	220	220	362	0	330	330				
**	Bheramara (H/DC)	India		1000	1000	891	697	909	909				
Khulna Zone Total				3125	3121	1658	1258	2054	2133	410	0		
113	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	18	110				
114	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	15	23	23	25				
115	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	136	130	135	135				
116	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	600	510	650	650				
117	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	35	150				
118	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	140	140	140	140				
119	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	220	220	220				
Barishal Zone Total				2265	2265	1111	1023	1219	1430	0	0		
120	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
121	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.	
122	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	0	38				
123	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0				
124	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	0				
125	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	0	50	90				
126	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	24	30	40				
127	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	34	42				
128	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	24	32				
129	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	172	150	170	190	60		Gas Shortage	
130	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage	
131	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	147	143	170	190	77		Gas Shortage	
132	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	0	350	150	390	64		Gas Shortage	
133	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8				
134	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	0	52	52				
135	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	0	35	113				
136	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	0	35	50				
137	Amnara 50 MW PP (Sinha)	HFO (NENP)	7x7.19	50	50	0	0	28	28				
138	Sirajgonj 5.55 MW Solar	Solar (NWPGL)	1x6	6	6	0	0	6	0				
**	Adani Power Jharkhand Ltd	(Import)	2x748	1496	1496	1116	1218	1200	1400				
Rajshahi Zone Total				3653	3631	1443	1893	1992	2663	492	100		
139	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
140	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
141	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	160	170	180	180				
142	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
143	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*18.23	113	113	0	74	34	113				
144	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
145	Maipara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	1	0	8	0				
146	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	35	35	115				
147	Lalmoharhat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	7	0	30	0				
148	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	45	0	130	0				
Rangpur Zone Total				1030	950	213	279	417	408	85	85		
Sub-total: Plants in operation				24280	23871	10985.0	11300	12664	15116	2334	2162		
(B) Plants under long term maintenance/ contract expired													
149	Jamalpur 95 MW PP (Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
150	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
151	Bosilla 108MW PP (CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
152	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	0	0	0	0	0				
153	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	0	0	0	0	0				
Sub-Total: Plants under long term maintenance/ contract expired				331	0	0	0	0	0	0	0		
Gross Total				24611	23871	10985	11300	12664	15116	2334	2162		
(C) Actual data of 05.10.23 (Yesterday) Thursday :													
01.	Max. Demand at eve. peak (Generation end)	:	11300	MW, at =	19:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	10770	MW, at =	19:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	11300	MW, at =	19:00 hrs	Dhaka	4091	4091	0	Mymensingh	553	553	0
04.	Minimum Generation (Generation end)	:	8825	MW, at =	6:00 hrs	Chattogram	1255	1255	0	Sylhet	488	488	0
05.	Day-peak Generation (Generation end)	:	10985	MW, at =	12:00 hrs	Khulna	1318	1318	0	Barishal	394	394	0
06.	Evening-peak Generation (Generation end)	:	11300	MW, at =	19:00 hrs	Rajshahi	851	851	0	Rangpur	665	665	0
07.	Evening Peak Load-shed (Sub-station end)	:	0	MW, at =	19:00 hrs	Cumilla	1156	1156	0				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	8008	MW, at =	5:00 hrs					Total	10770	10770	0
09.	Generation shortfall at evening peak due to :	:				13.	Fuel cost :	(a) Gas = 13212092 Taka (b) Oil = 291256740 Taka		(c) Coal = 502027086 Taka Total = 925395918 Taka			
a) Gas/LF limitation	:	2249	MW			14.	Maximum Temperature in Dhaka was :	29.3°C					
d) Coal supply Limitation	:	85	MW			15.	Export through East-West interconnections :						
b) Low water level in Kaptai lake	:	0	MW				At evening peak-hour	:	10985	MW, at	19:00 hrs		
c) Plants under shut down/ maintenance	:	2162	MW				Maximum	:	950	MW, at	22:00 hrs		
10.	Total Energy (Generation + India Import)	:	253.63	MKWh			Energy	:	0	MKWh			
	By Gas = 125.360 MKWh			By Oil = 24.655 MKWh									
	By Coal = 74.354 MKWh			By Hydro = 4.716 MKWh									
	By Solar = 0.635 MKWh												
11.	Total Gas Supplied	:	920.89	MMCFD									
(D) Forecast of 06.10.23 (Today) Friday :													
01.	Maximum Demand	:	11500	MW	(Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)		
02.	Maximum Generation	:	15116	MW	(Generation end)	05.	Total Generation	:	258.12	MKWh			
03.	Reserve / Shortage	:	3616	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	:	29.3°C				

* Captive Power ** Imported Power
#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21