

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 3564667, 9551095

Month October, 2023					Day : Saturday				Date : 07.10.23				
Probable Maximum Demand : 12500 MW					Probable Maximum Generation : 14859 MW								
Water Level of Kapitai Lake at 06:00 AM					Yesterday = 107.81 ft		Today = 107.72 ft		Rule Curve = 106.54 ft.				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	06.10.23 (Yesterday)		07.10.23 (Today)		06.10.23 (Yesterday)		07.10.23 (Today)		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Status of Machines under shut-down/ Maintenance		
					Day	Evening	Day	Evening	Gas/Coal/Water Limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date	
(A) Plants in operation:													
1	Ghorasal Repowered CAPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work	
2	a) Ghorasal Repowered CAPP Unit-4	Gas (PDB)	1 x 210	210	180	130	130	150	150				
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190		Gas Shortage	
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0				
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	52	52	52	52				
5	Tong 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0				
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	228	277	280	330				
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225				
9	210 MW Siddhigongj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115		Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	369	405	412	412				
11	Siddhigongj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage	
12	Siddhigongj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0		335	Under maint.	
13	Meghnaghat 335MW CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	90	0	0	0	335		Gas Shortage	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	55	15	55				
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	2	91	102	102				
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	10	0	20	20				
17	Summit Power(Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	19	38	39	39				
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	8	16	25	25				
19	Rugganji 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	20	24	25	25				
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	25	8	25				
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	0	17	34	105				
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	0	16	48	132				
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	54	35	54				
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	95	300	300				
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	0	72	36	100				
26	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	35	35	55				
27	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	35	35	35				
28	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	0	70	53	70				
29	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	0	54	54	108				
30	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	4	0	35	0				
31	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	17	54	54				
32	Siddhigongj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	2	82	92	92				
33	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	0	65	84	90				
34	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	68	85	85				
35	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	24	55	55				
	Meghnaghat Unique Power	Gas				0	0	0	0				
	Meghnaghat 589 MW CCPP(Summit)	Gas				0	0	0	0				
Dhaka Zone Total				5604	5422	1176	2042	2402	2795	840	710		
36	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	156	156	199	199				
37	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.	
	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	2	0	5	0				
39	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	17	8	17				
40	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	14	0	20	0				
41	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	1	6	6	40				
42	Sikalbaha 105 MW PP (Baraka Sikabaha)	HFO (IPP)	6x18.415	105	105	17	17	17	17				
43	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150		Under maint.	
44	Sikalbaha 225 MW CAPP	Gas (PDB)	1 x 150+1 x 75	225	225	163	188	180	188				
45	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	20	249	70	300				
46	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	25	25	37				
47	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	26	34	34				
48	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	40	70				
49	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	11	9	11	11				
*	Malancha, Ctg.EPZ (United)	Gas	5x8.73+3x9.34			37	42	20	30				
50	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0				
51	Sikalbaha 54 MW PP (Jodiach Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	54				
52	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	37	55	55	55				
53	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	12	25	25	25				
54	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	0	25	25	35				
55	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	34	34	34	34				
56	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	0	17	54	150				
	SS Power Unit-1	Coal (IPP)				0	0	0	0			Test run	
	Matarbari 2*600 MW (CPGCL)	Coal				356	358	390	390			Test run	
	Cox's Bazar Wind PP	(Wind) (IPP)				3	5	10	20				
Chattogram Zone Total				2605	2545	905	1271	1245	1706	180	330		
57	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	24	51	10	50				
58	Ashuganj 225 MW CAPP	Gas (APSCCL)	1x142+175	221	221	206	193	200	200				
59	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	345	310	300	300				
60	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	0	100	250	300	260		Gas Shortage	
61	Ashuganj 420 MW CCPP(East)	Gas (APSCCL)	1x284+1x116	400	400	357	300	330	330	100		Gas Shortage	
62	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+11*6	195	195	55	102	45	60	93		Gas Shortage	
63	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	15	51	50	50				
64	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	113	150	150				
65	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	0				
66	Chandpur 150 MW CAPP	Gas (PDB)	1x106+1x57	163	163	0	0	0	0	163		Under maint.	
67	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	0	34	34	34				
68	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	18	18	18				
69	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
70	Jangalia 33 MW PP (Summit))	Gas (SIPP, PDB)	4x8.73	33	33	21	33	33	33				
71	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	52	52	52				
72	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	12	12	12	12				
73	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	17	17	105				
74	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	27	86	28	85				
75	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	0	17	35	35				
76	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	38	76	72	94				
**	Import (Tirupura)	India		160	160	128	152	149	165				
Cumilla Zone Total				2904	2896	1257	1728	1796	2084	453	163		
77	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	34	57	50	62	145		Gas Shortage	
78	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	14	16	18	18				
79	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	37	99	37	100				
80	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	10	65	20	65				
81	Sarishabani 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0				
82	Sutiakehi 50 MW Solar PP	Solar (IPP)	1x50	50	50	16	0	50	0				
83	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	0	18	18	18				
Mymensingh Zone Total				622	614	112	255	195	263	145	0		

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	06.10.23 (Yesterday)		07.10.23 (Today)		06.10.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)		
84	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 Under maint.	
85	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	39	39	40	40		51	GT-4 Under maint.	
86	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	47	50	50	50				
87	Kushiara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	112	112	110	112		54	ST Under maint.	
88	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	0	8	8				
89	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	61	57	60	60				
90	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
91	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	0	0	0	0	86		Gas Shortage	
92	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	184	184	185	185				
93	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	16	17	17	17				
94	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	10	10	10				
95	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16				
96	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	320	275	300	300				
97	Bibiana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	402	403	400	400				
98	Bibiana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	185	395	392	400				
99	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
100	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	38	49	40	46				
Sylhet Zone Total				2472	2427	1480	1650	1671	1687	86	562		
101	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
102	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0	410		Gas Shortage	
103	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	40	25	40				
104	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	40				
105	Khulna 225 MW CCPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0				
106	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	17	54	54				
107	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	15	100	100				
108	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	86	0	100	0				
109	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	16	16	66				
110	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	0	0	24				
111	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BHPCL)	1x617	617	617	370	577	520	570				
112	Khulna 330 MW CCPP (GT)	Gas/HSD (BPDB)	1x220	220	220	362	0	0	0				
**	Bheramara (H/DC)	India		1000	1000	889	694	909	909				
Khulna Zone Total				3125	3121	1707	1359	1724	1803	410	0		
113	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	16	16	110				
114	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	22	27	23	25				
115	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	130	132	135	135				
116	Payra 1320 MW TTP	Coal (BCPCL)	2x622	1244	1244	350	600	650	650				
117	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	17	35	150				
118	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	150	150	150	150				
119	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	224	220	220				
Barishal Zone Total				2265	2265	872	1166	1229	1440	0	0		
120	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
121	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.	
122	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	0	38				
123	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0				
124	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	5	0	0				
125	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	0	50	90				
126	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	30	40				
127	Katakhali 50 MW PP (Northern)	HFO (QRP)	6x8.9	50	50	0	0	34	42				
128	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	24	32				
129	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	180	205	200	200				
130	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage	
131	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	152	150	170	190	70		Gas Shortage	
132	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	350	350	380	390	64		Gas Shortage	
133	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8				
134	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	0	52	52				
135	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	35	35	113				
136	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	35	35	50				
137	Amnara 50 MW PP(Sinha)	HFO (NENP)	7x7.19	50	28	0	28	28	28				
138	Sirajgonj 5.55 MW Solar	Solar (NWPGL)	1x6	6	6	4	0	6	0				
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	853	828	1200	1400				
Rajshahi Zone Total				3653	3631	1547	1616	2252	2673	425	100		
139	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
140	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
141	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	170	170	180	180				
142	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
143	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	0	104	34	113				
144	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
145	Maipara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	6	0	8	0				
146	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	35	35	115				
147	Lalmohana 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	16	0	30	0				
148	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	78	0	130	0				
Rangpur Zone Total				1030	950	270	309	417	408	85	85		
Sub-total: Plants in operation				24280	23871	9326.0	11396	12931	14859	2624	1950		
(B) Plants under long term maintenance/ contract expired													
149	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
148	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
149	Bosilla 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
150	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	0	0	0	0	0				
151	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	0	0	0	0	0				
Sub-Total: Plants under long term maintenance/ contract expired				331	0	0	0	0	0	0	0		
Gross Total				24611	23871	9326	11396	12931	14859	2624	1950		
(C) Actual data of 06.10.23 (Yesterday) Friday :													
01.	Max. Demand at eve. peak (Generation end)	:	11396	MW, at =	21:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	10926	MW, at =	21:00 hrs								
03.	Highest Generation (Generation end)	:	11396	MW, at =	21:00 hrs								
04.	Minimum Generation (Generation end)	:	8008	MW, at =	1:00 hrs								
05.	Day-peak Generation (Generation end)	:	9326	MW, at =	12:00 hrs								
06.	Evening-peak Generation (Generation end)	:	11396	MW, at =	21:00 hrs								
07.	Evening Peak Load-shed (Sub-station end)	:	0	MW, at =	21:00 hrs								
08.	Minimum Generation Forecast up to 8:00 hrs.	:	9215	MW, at =	5:00 hrs	13. Fuel cost : (a) Gas = 124542943 Taka (c) Coal = 439508059 Taka (b) Oil = 318494342 Taka Total = 882545344 Taka							
09.	Generation shortfall at evening peak due to :	:											
a)	Gas/LF limitation	:	2539	MW									
d)	Coal supply Limitation	:	85	MW									
b)	Low water level in Kaptai lake	:	0	MW									
c)	Plants under shut down/ maintenance	:	1950	MW									
10.	Total Energy (Generation + India Import)	:	232.29	MKWh									
	By Gas =	117.525	MKWh	By Oil =	26.799	MKWh							
	By Coal =	59.059	MKWh	By Hydro =	4.057	MKWh							
	By Solar=	1.079	MKWh										
11.	Total Gas Supplied	:	932.39	MMCFD		14. Maximum Temperature in Dhaka was : 28.6°C 15. Export through East-West interconnections : At evening peak-hour : 9326 MW, at 21:00 hrs Maximum : 570 MW, at 21:00 hrs Energy : 0 MKWh							
(D) Forecast of 07.10.23 (Today) Saturday :													
01.	Maximum Demand	:	12500	MW	(Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)		
02.	Maximum Generation	:	14859	MW	(Generation end)	05.	Total Generation	:	254.79	MKWh			
03.	Reserve / Shortage	:	2359	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka ;	:	28.6°C				