

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 3564667, 9551095

Month October, 2023					Day : Sunday				Date : 08.10.23				
Probable Maximum Demand : 14500 MW					Probable Maximum Generation : 14955 MW					Rule Curve = 106.54 ft.			
Water Level of Kapitai Lake at 06:00 AM					Yesterday = 107.72 ft		Today = 107.61 ft						
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	07.10.23 (Yesterday)		08.10.23 (Today)		07.10.23 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/Water Limitation MW		Machines shut down (MW)	Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening					
(A) Plants in operation:													
1	Ghorasal Repowered CAPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work	
2	a) Ghorasal Repowered CAPP Unit-4	Gas (PDB)	1 x 210	210	180	150	150	150	150				
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190		Gas Shortage	
3	Ghorasal 365 MW CAPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0				
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	52	52	52	52				
5	Tong 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0				
7	Haripur 360MW CAPP(HPL)	Gas (IPP)	1x235+1x125	360	360	330	332	280	330				
8	Meghnaghat 450 MW CAPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	450	450	450				
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling	
10	Haripur 412 MW CAPP	Gas (EGCB)	1x273+1x139	412	412	403	410	412	412				
11	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage	
12	Siddhirgonj 335 MW CAPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0		335	Under maint.	
13	Meghnaghat 335MW CAPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	10	277	277	325		Gas Shortage	
14	Madangan-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	15	15	55				
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	42	95	102	102				
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	12	20	20	20				
17	Summit Power(Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	36	36	38	38				
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	25	25				
19	Ruggan 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	24	16	25	25				
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	25	8	25				
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	35	105	34	105				
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	64	132	48	132				
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	30	35	54				
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	134	290	80	130				
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	35	74	17	100				
26	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	55	35	35	55				
27	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	35	35	35				
28	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	35	53	53	70				
29	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	54	108	54	108				
30	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	11	0	35	0				
31	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	54	54	54	54				
32	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	45	82	92	92				
33	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	22	83	84	90				
34	Madangan 102 PP(Summit)	HFO (NENP)	6x17	102	102	55	65	85	85				
35	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	15	47	55	55				
	Meghnaghat Unique Power	Gas				0	0	0	0				
	Meghnaghat 589 MW CAPP(Summit)	Gas				0	0	0	0				
Dhaka Zone Total					5604	5422	1953	2829	2650	3126	830	710	
36	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	201	202	199	199				
37	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.	
38	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0				
39	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	17	8	17				
40	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	15	0	20	0				
41	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	40	6	40				
42	Sikalbaha 105 MW PP (Baraka Sikabaha)	HFO (IPP)	6x18.415	105	105	27	34	34	34				
43	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.	
44	Sikalbaha 225 MW CAPP	Gas (PDB)	1 x 150+1 x 75	225	225	202	225	225	225				
45	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	98	258	70	270				
46	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	30	25	25	25				
47	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	17	16	34	34				
48	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	8	55	40	70				
49	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	9	8	8	8				
*	Malancha, Ctg.EPZ (United)	Gas	5x8.73+3x9.34			7	15	5	20				
50	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0				
51	Sikalbaha 54 MW PP (Jodiad Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	54				
52	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	55	55	55	55				
53	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	25	25	25	25				
54	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	35	25	25	35				
55	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	34	51	34	51				
56	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	24	160	54	150				
	SS Power Unit-1	Coal (IPP)				0	0	350	620				
	Matarbari 2*600 MW (CPGCL)	Coal				0	0	200	350			Test run	
	Cox's Bazar Wind PP	(Wind) (IPP)				0	0	10	20			Test run	
Chattogram Zone Total					2605	2545	822	1228	1449	2302	180	330	
57	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	50	30	10	50				
58	Ashuganj 225 MW CAPP	Gas (APSCCL)	1x142+1*75	221	221	179	191	200	200				
59	Ashuganj 450 MW CAPP(South)	Gas (APSCCL)	1x360	360	360	290	240	270	300				
60	Ashuganj 450 MW CAPP(North)	Gas (APSCCL)	1x361	360	360	190	360	290	300				
61	Ashuganj 420 MW CAPP(East)	Gas (APSCCL)	1x284+1x116	400	400	305	365	330	330				
62	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*116	195	195	16	8	45	60	187		Gas Shortage	
63	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51				
64	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	53	128	150	150				
65	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	31	0	0				
66	Chandpur 150 MW CAPP	Gas (PDB)	1x106+1x57	163	163	0	0	0	0		163	Under maint.	
67	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	34	34	34	34				
68	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	18	18	18				
69	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	5	11	11				
70	Jangalia 33 MW PP (Summit))	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33				
71	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	16	42	52	52				
72	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	12	12	12	12				
73	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	52	106	17	105				
74	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	26	85	28	85				
75	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	35	35				
76	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	53	96	72	94				
**	Import (Tirupura)	India		160	160	146	150	149	165				
Cumilla Zone Total					2904	2896	1549	2002	1807	2085	187	163	
77	RPCL 210MW CAPP	Gas (IPP)	4x35+1x70	210	202	40	42	50	62	160		Gas Shortage	
78	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	16	17	17	17				
79	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	80	109	70	110				
80	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	75	140	38	140				
81	Sarishabani 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0				
82	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	6	0	50	0				
83	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	0	18	18	18				
Mymensingh Zone Total					622	614	218	326	245	347	160	0	

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	07.10.23 (Yesterday)		08.10.23 (Today)		07.10.23 (Yesterday)		Status of Machines under shut-down/ Maintenance					
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date				
						Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)						
84	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	40	43	43		30	GT-1 Under maint.					
85	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	39	39	40	40		51	GT-4 Under maint.					
86	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	47	47	50	50								
87	Kushiara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	112	112	112	112		54	ST Under maint.					
88	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	8	11	11								
89	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	56	57	60	60								
90	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.					
91	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	0	0	0	0	86		Gas Shortage					
92	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	184	184	185	185								
93	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	18	18	17	17								
94	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10								
95	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16								
96	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	330	300	300	300								
97	Bibiana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	402	402	400	400								
98	Bibiana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	395	380	392	400								
99	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work					
100	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	45	48	40	46								
Sylhet Zone Total				2472	2427	1705	1661	1676	1690	86	565						
101	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0								
102	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0	410		Gas Shortage					
103	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	25	40								
104	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	40								
105	Khulna 225 MW CCPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0								
106	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	35	35	54	54								
107	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	15	105	100	100								
108	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	83	0	100	0								
109	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	6	48	16	66								
110	Nasipara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	24	0	24								
111	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BHPCL)	1x617	617	617	528	574	520	570								
112	Khulna 330 MW CCPP (GT)	Gas/HSD (BPD)	1x220	220	220	0	0	0	0								
**	Bheramara (H/DC)	India		1000	1000	884	786	909	909								
Khulna Zone Total				3125	3121	1551	1572	1724	1803	410	0						
113	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	96	16	110								
114	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	22	28	23	25								
115	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	132	134	135	135								
116	Payra 1320 MW TTP	Coal (BCPCL)	2x622	1244	1244	600	600	650	650								
117	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	150	35	150								
118	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	150	150	150	150								
119	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	220	220	220								
Barishal Zone Total				2265	2265	1124	1378	1229	1440	0	0						
120	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage					
121	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.					
122	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	0	38								
123	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0								
124	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	0								
125	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	94	50	90								
126	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	30	40								
127	Katakhali 50 MW PP (Northern)	HFO (QRP)	6x8.9	50	50	0	16	34	42								
128	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	30	24	32								
129	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	205	201	200	200								
130	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage					
131	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	207	180	170	190								
132	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	414	414	380	414								
133	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8								
134	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	8	52	52								
135	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	35	74	35	113								
136	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	50	35	50								
137	Amnara 50 MW PP(Sinha)	HFO (NENP)	7x7.9	50	50	0	28	0	28								
138	Sirajgonj 5.55 MW Solar	Solar (NWPGL)	1x6	6	6	3	0	6	0								
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	989	1058	500	500								
Rajshahi Zone Total				3653	3631	1861	2133	1552	1797	291	100						
139	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage					
140	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling					
141	Barapukuria 275 MW TTP Unit-3	Coal (PDB)	1 x 274	274	274	170	170	180	180								
142	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0								
143	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	10	70	0	70								
144	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0								
145	Maipara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	7	0	8	0								
146	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	89	115	115								
147	Lalmohana 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	10	0	30	0								
148	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	50	0	130	0								
Rangpur Zone Total				1030	950	247	329	463	365	85	85						
Sub-total: Plants in operation				24280	23871	11030.0	13458	12795	14955	2229	1953						
(B) Plants under long term maintenance/ contract expired																	
149	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0								
148	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0								
149	Bosilla 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0								
150	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	0	0	0	0	0								
151	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	0	0	0	0	0								
Sub-Total: Plants under long term maintenance/ contract expired				331	0	0	0	0	0	0	0						
Gross Total				24611	23871	11030	13458	12795	14955	2229	1953						
(C) Actual data of 07.10.23 (Yesterday) Saturday :																	
01.	Max. Demand at eve. peak (Generation end)	:	13458	MW, at =	19:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :											
02.	Max. Demand at eve. peak (Sub-station end)	:	12900	MW, at =	19:00 hrs												
03.	Highest Generation (Generation end)	:	13458	MW, at =	19:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW				
04.	Minimum Generation (Generation end)	:	9215	MW, at =	7:00 hrs	Dhaka	4826	4826	0	Mymensingh	1024	1024	0				
05.	Day-peak Generation (Generation end)	:	11030	MW, at =	12:00 hrs	Chattogram	1298	1298	0	Sylhet	467	467	0				
06.	Evening-peak Generation (Generation end)	:	13458	MW, at =	19:00 hrs	Khulna	1642	1642	0	Barishal	396	396	0				
07.	Evening Peak Load-shed (Sub-station end)	:	0	MW, at =	19:00 hrs	Rajshahi	1256	1256	0	Rangpur	764	764	0				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	10344	MW, at =	5:00 hrs	Cumilla	1227	1227	0								
09.	Generation shortfall at evening peak due to :	:								Total	12900	12900	0				
a)	Gas/LF limitation	:	2144	MW						(a) Gas =	137463832	Taka	(c) Coal = 509952701 Taka				
d)	Coal supply Limitation	:	85	MW						(b) Oil =	561074771	Taka	Total = 1208491304 Taka				
b)	Low water level in Kaptai lake	:	0	MW													
c)	Plants under shut down/ maintenance	:	1953	MW													
10.	Total Energy (Generation + India Import)	:	285.09	MKWh													
	By Gas =	132.013	MKWh	By Oil =	44.533												
	By Coal =	77.970	MKWh	By Hydro =	4.693												
	By Solar=	1.617	MKWh														
11.	Total Gas Supplied	:	1020.56	MMCFD													
(D) Forecast of 08.10.23 (Today) Sunday :																	
01.	Maximum Demand	:	14500	MW	(Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)						
02.	Maximum Generation	:	14955	MW	(Generation end)	05.	Total Generation	:	307.16	MKWh							
03.	Reserve / Shortage	:	455	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka ;	:	28.6°C								