

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 3564667, 9551095

Month October, 2023				Day : Monday				Date : 09.10.23				
Probable Maximum Demand : 14500 MW				Probable Maximum Generation : 15582 MW								
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 107.61 ft		Today = 107.40 ft		Rule Curve = 106.72 ft				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	08.10.23 (Yesterday)		09.10.23 (Today)		08.10.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gas/Coal/Water Limitation MW			Machines shut down (MW)
					Day	Evening	Day	Evening	Day	Evening		
(A) Plants in operation:												
1	Ghorasal Repowered CCGP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work	
2	a) Ghorasal Repowered CCGP Unit-4 b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	180	170	190	180	190		Gas Shortage	
3	Ghorasal 365 MW CCGP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0			
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	52	52	52	52			
5	Tong 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0			
7	Haripur 360MW CCGP(HPL)	Gas (IPP)	1x235+1x125	360	360	332	332	280	330			
8	Meghnaghat 450 MW CCGP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	420	450	450			
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
10	Haripur 412 MW CCGP	Gas (EGCB)	1x273+1x139	412	412	410	409	412	412			
11	Siddhirganj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage	
12	Siddhirganj 335 MW CCGP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335	Under maint.	
13	Meghnaghat 335MW CCGP(Summit)	Gas (IPP)	2x110+1x110	335	335	280	276	277	275	59	Gas Shortage	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.09+1x11.3	55	55	15	15	15	15			
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	16	102	90	90			
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	19	20	20			
17	Summit Power, Madhabdi+Ashulia	Gas (SIPP, REB)	6x3.77+7x8.73	80	80	33	37	37	37			
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33			
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	24	24	24	24			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	25	8	25			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	35	105	34	105			
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	48	149	48	149			
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	35	17	35			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	80	130	80	130			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	17	95	17	100			
26	Natabaganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	55	35	55			
27	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	35	35	35			
28	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	63	53	70			
29	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	54	108	54	108			
30	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	23	0	35	0			
31	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	54	52	54	54			
32	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	65	64	90	90			
33	Meghnaghat 100 MW(EL)	HFO (NENP)	12x8.9	100	100	71	68	81	90			
34	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	60	80	80	80			
35	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	27	23	55	55			
	Meghnaghat Unique Power	Gas				0	0	0	0			
	Meghnaghat 589 MW CCGP(Summit)	Gas				0	0	0	0			
Dhaka Zone Total				5604	5422	2445	3036	2646	3149	564	710	
36	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	201	201	199	199			
37	a) Chattogram TPP-1 b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage	
38	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0		Under maint.	
39	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	17	8	17			
40	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	20	0	20	0			
41	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	40	6	40			
42	Sikalbaha 105 MW PP (Baraka Sikalabaha)	HFO (IPP)	6x18.415	105	105	34	34	34	51			
43	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	30	0	0	0	150	Under maint.	
44	Sikalbaha 225 MW CCGP	Gas (PDB)	1 x 150+1 x 75	225	225	223	225	225	225			
45	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	69	258	70	280			
46	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	25	25	25			
47	Dohazari -Kalash 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	16	16	16			
48	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	38	63	60	63			
49	Barakkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	11	11	11	11			
	* Malancha, Cig,EPZ (United)	Gas	5x8.73+3x9.34			4	24	5	20			
50	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0			
51	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	17			
52	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	55	55	55	55			
53	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	25	25	25	25			
54	Juldah 100 MW Unit-1 (Acom)	HFO (ORPP)	8x13.45	100	100	25	25	25	25			
55	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	34	34	34	51			
56	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	35	52	54	150			
	SS Power Unit-1	Coal (IPP)				430	612	350	620		Test run	
	Matarbari 2*600 MW (CPGCL)	Coal				352	356	200	350		Test run	
	Cox's Bazar Wind PP	(Wind) (IPP)				2	0	10	20			
Chattogram Zone Total				2605	2545	1648	2090	1454	2260	180	330	
57	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	48	51	10	50			
58	Ashuganj 225 MW CCGP	Gas (APSCCL)	1x142+1*75	221	221	180	210	200	210			
59	Ashuganj 450 MW CCGP(South)	Gas (APSCCL)	1x360	360	360	315	310	270	300			
60	Ashuganj 450 MW CCGP(North)	Gas (APSCCL)	1x361	360	360	0	0	290	360	360	Under maint.	
61	Ashuganj 420 MW CCGP(East)	Gas (APSCCL)	1x284+1x116	400	400	285	300	300	300			
62	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*116	195	195	55	183	0	0			
63	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51			
64	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	70	12	150	150			
65	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	18	30	0	30			
66	Chandpur 150 MW CCGP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163	Under maint.	
67	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	34	17	17	17			
68	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	18	18	18			
69	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11			
70	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33			
71	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	25	34	40	43			
72	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	6	12	12	12			
73	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	52	88	17	88			
74	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	27	84	28	51			
75	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	35	35	35	35			
76	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	54	96	72	96			
**	Impoport (Tripura)	India		160	160	130	130	149	165			
Cumilla Zone Total				2904	2896	1444	1705	1703	2020	0	523	
77	RPCL 210MW CCGP	Gas (IPP)	4x35+1x70	210	202	36	51	50	60	151	Gas Shortage	
78	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	17	17	17	17			
79	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	89	99	70	100			
80	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	65	149	38	140			
81	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
82	Sutakhalhi 50 MW Solar PP	Solar (IPP)	1x50	50	49	0	50	0	0			
83	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	18	18	18	18			
Mymensingh Zone Total				622	614	276	334	245	335	151	0	

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	08.10.23 (Yesterday)		09.10.23 (Today)		08.10.23 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/Coal/Oil/Water Limitation MW	Machines shut down (MW)			
84	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	42	43	43	43		27	GT-1 Under maint.	
85	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	39	39	40	40		51	GT-4 Under maint.	
86	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	47	50	50	50				
87	Kushiara 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	80	112	0	0		54	ST Under maint.	
88	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.50	11	11	11	8	11	11				
89	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	59	56	60	60				
90	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
91	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	0	0	60	86	86		Gas Shortage	
92	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	185	185	185	185				
93	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	17	18	17	18				
94	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
95	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16				
96	Bibiana-III 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	270	300	300	300				
97	Bibiyana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	405	403	400	400				
98	Bibiyana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	398	400	392	400				
99	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
100	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12'3.3-5'2	50	50	43	46	40	46				
Sylhet Zone Total					2472	2427	1622	1686	1624	1665	86	562	
101	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
102	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0	410		Gas Shortage	
103	Fardipur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	43	25	41				
104	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	47	0	50				
105	Khulna 225 MW CAPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0				
106	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	36	36	54	54				
107	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	15	105	100	100				
108	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	95	0	100	0				
109	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	15	65	16	66				
110	Nasipara 40 MW PP (Khatijahan Ali)	HFO (NENP)	5'8.5	40	40	8	32	0	32				
111	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BHPCL)	1x617	617	617	522	570	520	570				
112	Khulna 330 MW CAPP (GT)	Gas/HSD (BPDB)	1x220	220	220	0	0	0	0				
**	Bheramara (H/DC)	India		1000	1000	885	800	909	909				
Khulna Zone Total					3125	3121	1576	1698	1724	1822	410	0	
113	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	48	18	110				
114	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	22	27	23	27				
115	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	74	134	135	135				
116	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	600	600	1000	1244				
117	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	150	37	150				
118	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	150	150	200	280				
119	Bhola 220MW CAPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	220	220	220				
Barishal Zone Total					2265	2265	1101	1329	1631	2166	0	0	
120	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.	
121	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	35	0	35				
122	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0				
123	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	0				
124	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	31	95	50	95				
125	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	39	38	30	40				
126	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	8	42	34	42				
127	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	38	24	38				
128	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	202	213	200	210				
129	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage	
130	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	190	203	210	210				
131	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	350	414	380	414				
132	Lillapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8				
133	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	40	52	52				
134	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6'18.65	113	113	35	56	35	56				
135	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6'18.65	113	113	25	50	35	50				
136	Armura 50 MW Peaking PP	HFO (NENP)	7x7.79	50	50	28	0	28	28				
137	Sirajgonj 5.55 MW Solar	Solar (NWPGL)	1x6	6	6	1	0	6	0				
**	Adani Power Jharkhand Ltd	(Import)	2x748	1496	1496	543	532	500	532				
Rajshahi Zone Total					3653	3631	1440	1792	1592	1810	291	100	
138	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
139	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	170	170	170	170				
140	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
141	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'18.2'3	113	113	0	67	0	70				
142	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
143	Majpara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	2	0	8	0				
144	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6'20	115	115	49	114	115	115				
145	Lalmohat 30 MW Solar (Intraco)	Solar (IPP)	1'30	30	30	8	0	30	0				
146	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	198	0	130	0				
Rangpur Zone Total					1030	950	427	351	453	355	85	85	
Sub-total: Plants in operation					24280	23871	11979.0	14021	13072	15582	1767	2310	
(B) Plants under long term maintenance/ contract expired													
147	Jamalpur 95 MW PP (Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
148	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	12	0	0	0				
149	Bosilla 108MW PP (CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
150	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	0	0	0	0	0				
151	Ashugonj 55 MW PP (Precision)	Gas (RPP)	15'4	55	0	0	0	0	0				
Sub-Total: Plants under long term maintenance/ contract expired					331	0	12	0	0	0	0	0	
Gross Total					24611	23871	11991	14021	13072	15582	1767	2310	
(C) Actual data of 08.10.23 (Yesterday) Sunday :													
01.	Max. Demand at eve. peak (Generation end)	: 14060 MW, at = 19:00 hrs		12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :									
02.	Max. Demand at eve. peak (Sub-station end)	: 13437 MW, at = 19:00 hrs		Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW		
03.	Highest Generation (Generation end)	: 14021 MW, at = 19:00 hrs		Dhaka	4879	4879	0	Mymensingh	1161	1134	27		
04.	Minimum Generation (Generation end)	: 10344 MW, at = 7:00 hrs		Chattogram	1337	1337	0	Sylhet	506	506	0		
05.	Day-peak Generation (Generation end)	: 11991 MW, at = 12:00 hrs		Khulna	1704	1704	0	Barishal	405	405	0		
06.	Evening-peak Generation (Generation end)	: 14021 MW, at = 19:00 hrs		Rajshahi	1368	1368	0	Rangpur	882	882	0		
07.	Evening Peak Load-shed (Sub-station end)	: 37 MW, at = 19:00 hrs		Cumilla	1195	1185	10						
08.	Minimum Generation Forecast up to 8:00 hrs.	: 10584 MW, at = 5:00 hrs						Total	13437	13400	37		
09.	Generation shortfall at evening peak due to :												
a) Gas/LF limitation	: 1682 MW												
d) Coal supply Limitation	: 85 MW												
b) Low water level in Kaptai lake	: 0 MW												
c) Plants under shut down/ maintenance	: 2310 MW												
10. Total Energy (Generation + India Import)	: 288.61 MKWh												
	By Gas =	143.075 MKWh	By Oil =	46.564 MKWh									
	By Coal =	67.911 MKWh	By Hydro =	4.871 MKWh									
	By Solar =	2.590 MKWh											
11. Total Gas Supplied	: 1071.35 MMCFD												
(D) Forecast of 09.10.23 (Today) Monday :													
01.	Maximum Demand	: 14500 MW (Generation end)		04.	Maximum Load-shed	: 0 MW At evening peak (Sub-station end)							
02.	Maximum Generation	: 15582 MW (Generation end)		05.	Total Generation	: 298.47 MKWh							
03.	Reserve / Shortage	: 1082 MW (Generation end)		06.	Probable Max. Temperature in Dhaka	: 34.1°C							

#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation