

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 3564667, 3551095

Month October, 2023				Day : Sunday				Date : 15.10.23				
Probable Maximum Demand : 14500 MW				Probable Maximum Generation : 14937 MW				Rule Curve = 107.20 ft.				
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 106.49 ft				Today = 106.31 ft				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	14.10.23 (Yesterday)		15.10.23 (Today)		14.10.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW			
					Day	Evening	Day	Evening	Day	Evening		
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	130	140	170	170			
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190	Gas Shortage	
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0			
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0			
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage	
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0			
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	332	332	330	330			
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450			
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	408	415	410	410			
11	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage	
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	324	334	335	335			
13	Meghnaghat 335MW CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	298	299	300	300			
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	4	30	15	15			
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	16	91	80	90			
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	10	17	17	17			
17	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	37	36	37	37			
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	33	25	25			
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	16	21	24	24			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	25	8	25			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	52	105	35	105			
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	16	149	16	149			
23	Kamalghat 54 MW PP (Barco Energy)	HFO (IPP)	3x18.69	54	54	0	35	0	35			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	47	125	80	130			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	17	115	17	135			
26	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	17	55	35	55			
27	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	35	35	35			
28	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	56	53	17	53			
29	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	17	72	17	72			
30	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	30	0	35	0			
31	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	11	55	35	55			
32	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	14	88	40	88			
33	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	8	57	70	80			
34	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	80	80	80			
35	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	24	44	55			
36	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			
	Meghnaghat Unique Power	Gas				84	42	0	0			
	Meghnaghat 589 MW CCPP(Summit)	Gas				0	0	0	0			
Dhaka Zone Total				5655	5422	2427	3273	2757	3355	505	375	
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	153	152	153	153			
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		Under maint.	
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0			
40	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	17	8	17			
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	14	0	20	0			
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	40	6	40			
43	Sikalbaha 105 MW PP (Baraka Sikabaha)	HFO (IPP)	6x18.415	105	105	17	17	17	17			
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	220	224	225	225			
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.94	300	300	68	236	70	270			
47	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	25	25	25			
48	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	17	0	17			
49	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	64	60	70			
50	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	12	10	12	12			
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			6	24	10	30			
51	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0			
52	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	17			
53	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	17	17	17			
54	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	25	25	25	25			
55	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	25	25	25	25			
56	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	18	34	17	34			
57	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	0	89	54	160			
58	SS Power Unit-1	Coal (IPP)	1x612	612	612	410	500	500	550			
	Matarbari 2*600 MW (CPGCL)	Coal				205	203	207	207		Test run	
	Cox's Bazar Wind PP	(Wind) (IPP)				1	3	10	10		Test run	
Chattogram Zone Total				3217	3157	1243	1739	1483	1921	180	330	
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	50	50	50	50			
60	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	202	209	210	210			
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	290	265	300	300			
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	305	285	300	300			
63	Ashuganj 420 MW CCPP(East)	Gas (APSCCL)	1x284+1x116	400	400	300	285	300	300			
64	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	0	0	0	195	Gas Shortage	
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51			
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	3	99	12	150			
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	39	47	0	47			
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163	Under maint.	
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	17	17	17			
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	13	15	15	15			
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	0	8	11	11			
72	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33			
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	52	8	52			
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	0	12	12	12			
75	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	52	17	114			
76	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	9	76	27	75			
77	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	21	35			
78	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	36	94	36	95			
**	Impoqit (Tripura)	India		160	160	116	144	149	165			
Cumilla Zone Total				2904	2896	1514	1811	1569	2032	195	163	
79	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	32	33	32	65	169	Gas Shortage	
80	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	17	19	19	19			
81	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	89	107	70	105			
82	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	65	120	65	145			
83	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	0	0	1.6	0			
84	Sutiakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	46	0	50	0			
85	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	18	18	18	18			
Mymensingh Zone Total				622	614	267	297	256	352	169	0	

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	14.10.23 (Yesterday)		15.10.23 (Today)		14.10.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	Gas/Coal/Oil/Water Limitation MW	Machines shut down (MW)		
86	Fenchuganj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43		27	GT-1 Under maint.	
87	Fenchuganj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	28	28	30		62	GT-4 Under maint.	
88	Fenchuganj 51 MW PP (Barakattullah)	Gas (RPP)	19x2.90	51	51	43	50	50				
89	Kushnara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	112	112	112		51	Under maint.	
90	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	5	11				
91	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	60	62	60				
92	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0		330	Under maint.	
93	Shahjibazar 68MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	84	84	86				
94	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	163	159	158				
95	Sylhet 20 MW GTTP	Gas (PDB)	1x2.20	20	20	17	17	17				
96	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10				
97	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	8	8				
98	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	290	290	300				
99	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	404	403	400				
100	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	50	0	0		383	under maint.	
101	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0		100	Under project work	
102	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12'3.3+5'2	50	50	48	48	48				
Sylhet Zone Total					2472	2427	1391	1319	1333	1333	0	953
103	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0				
104	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0		410	Gas Shortage	
105	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	43	0		45		
106	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	6	0		51		
107	Khulna 225 MW CCPP	HSD Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0				
108	Ruoshu 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	22	35		50		
109	Machumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	50	100		105		
110	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	84	0	100		0		
111	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	49	49		49		
112	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5'8.5	40	40	0	24	0		24		
113	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	372	541	450		520		
114	Khulna 330 MW CCPP (GT)	Gas/HSD (PDB)	1x220+1x116	336	336	0	0	0				
**	Bheramara (HVCDC)	India		1000	1000	911	751	911		911		
Khulna Zone Total					3241	3237	1367	1486	1645	1755	410	0
115	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	16	16		110		
116	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	18	29	21		28		
117	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	80	71	130		130		
118	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	790	1200	1000		1244		
119	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	81	38		150		
120	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	150	150	150		150		
121	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	180	200	220		220		
Barishal Zone Total					2265	2265	1218	1747	1575	2032	0	0
122	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0		71	Gas Shortage	
123	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0		100	Under maint.	
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	0		31		
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0		0		
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0		16		
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	40	50		92		
128	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	39	30		39		
129	Katakhali 50 MW PP (Northern)	HFO (ORPP)	6x8.9	50	50	0	34	34		42		
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	30	24		30		
131	Sirajganj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	211	214	200		200		
132	Sirajganj 225MW CCPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	0	0	0		220	Gas Shortage	
133	Sirajganj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	194	210	170		200		
134	Sirajganj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	414	414	380		400		
135	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	0	11		11		
136	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	8	8		8		
137	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6'18.55	113	113	35	55	35		55		
138	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	23	50	35		50		
139	Ammura 50 MW PP (Sinha)	HFO (NENP)	7x7.79	50	28	0	0	28		28		
140	Sirajganj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	4	0	6		0		
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	531	518	550		600		
Rajshahi Zone Total					3653	3631	1423	1612	1561	1802	291	100
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0		85	Coal Shortage	
142	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0		85	Under Overhauling	
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	170	170	170		170		
144	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0		0		
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x2'3	113	113	0	71	0		70		
146	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0		0		
147	Majpara, Talsila 5 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	7	0	8		0		
148	Thakurgaon 118MW PP (Energypac)	HFO (IPP)	6'20	115	115	0	114	70		115		
149	Lalmohanhat 30 MW Solar (Intraco)	Solar (IPP)	1'30	30	30	28	0	30		0		
150	Treesta Solar Limited	Solar (IPP)	1 x 200	200	200	175	0	130		0		
Rangpur Zone Total					1030	950	380	355	408	355	85	85
Sub-total: Plants in operation					25059	24599	11230.0	13639	12587	14937	1835	2006
(B) Plants under long term maintenance/ contract expired												
149	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0		0		
150	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0		0		
151	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	0	0	0	0		0		
152	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	0	0	0	0		0		
Sub-Total: Plants under long term maintenance/ contract expired					280	0	0	0	0	0	0	0
Gross Total					25339	24599	11230	13639	12587	14937	1835	2006
(C) Actual data of 14.10.23 (Yesterday) Saturday :												
01.	Max. Demand at eve. peak (Generation end)	:	13720 MW, at =	19:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	13223 MW, at =	19:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	13639 MW, at =	19:00 hrs	Dhaka	4774	4774	0	Mymensingh	1085	1008	77
04.	Minimum Generation (Generation end)	:	9972 MW, at =	8:00 hrs	Chattogram	1331	1331	0	Sylhet	537	537	0
05.	Day-peak Generation (Generation end)	:	11230 MW, at =	12:00 hrs	Khulna	1627	1627	0	Barishal	410	410	0
06.	Evening-peak Generation (Generation end)	:	13639 MW, at =	19:00 hrs	Rajshahi	1329	1329	0	Rangpur	853	853	0
07.	Evening Peak Load-shed (Sub-station end)	:	77 MW, at =	19:00 hrs	Cumilla	1278	1278	0				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	10321 MW, at =	5:00 hrs								
09.	Generation shortfall at evening peak due to :	:										
	a) Gas/LF limitation	:	1750 MW		13.	Fuel cost :	(a) Gas = 153451092 Taka	(c) Coal = 497615332 Taka				
	d) Coal supply Limitation	:	85 MW			(b) Oil = 454091382 Taka	Total = 1105157806 Taka					
	b) Low water level in Kaptai lake	:	0 MW									
	c) Plants under shut down/ maintenance	:	2006 MW		14.	Maximum Temperature in Dhaka was :	34.2°C					
10.	Total Energy (Generation + India Import)	:	282.19 MKWh		15.	Export through East-West interconnections :						
	By Gas = 143.629 MKWh	By Oil =	34.625 MKWh			At evening peak-hour	: 11230 MW, at 19:00 hrs					
	By Coal = 73.543 MKWh	By Hydro =	3.649 MKWh			Maximum	: 216 MW, at 19:30 hrs					
	By Solar = 2.578 MKWh					Energy	: 0 MKWh					
11.	Total Gas Supplied	:	1088.94 MMCFD									
(D) Forecast of 15.10.23 (Today) Sunday :												
01.	Maximum Demand	:	14500 MW (Generation end)		04.	Maximum Load-shed	:	0 MW At evening peak (Sub-station end)				
02.	Maximum Generation	:	14937 MW (Generation end)		05.	Total Generation	:	300.00 MKWh				
03.	Reserve / Shortage	:	437 MW (Generation end)		06.	Probable Max. Temperature in Dhaka :	34.2°C					

* Captive Power ** Imported Power
#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation