

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 3564667, 3551095

Month October, 2023				Day : Monday				Date : 16.10.23				
Probable Maximum Demand : 14000 MW				Probable Maximum Generation : 14964 MW								
Water Level of Kapitai Lake at 06:00 AM				Yesterday = 106.31 ft				Today = 106.14 ft				
								Rule Curve = 107.40 ft				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	15.10.23 (Yesterday)		16.10.23 (Today)		15.10.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)		
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	140	135	140	140			
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190		Gas Shortage
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0			
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0			
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0			
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	330	332	330	330			
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450			
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	405	410	410	410			
11	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	330	335	335	335			
13	Meghnaghat 335MW CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	281	297	300	300			
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	15	15	15			
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	24	82	80	92			
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	17	17	17	17			
17	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	37	37	37	37			
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33			
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	22	21	24	24			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	25	8	25			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	34	105	35	105			
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	16	149	16	149			
23	Kamalghat 54 MW PP (Barco Energy)	HFO (IPP)	3x18.69	54	54	0	35	0	35			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	80	130	80	130			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	17	108	17	135			
26	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	55	0	55			
27	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	35	0	35			
28	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	54	72	17	72			
29	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	17	72	17	72			
30	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	33	0	35	0			
31	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	28	55	35	55			
32	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	68	64	68	92			
33	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	46	66	66	72			
34	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	65	93	80	93			
35	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	42	50	44	55			
36	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			
	Meghnaghat Unique Power	Gas			0	0	0	0	0			
	Meghnaghat 589 MW CCPP(Summit)	Gas			0	0	0	0	0			
Dhaka Zone Total				5655	5422	2599	3273	2689	3363	505	375	
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	154	151	153	153			
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0			
40	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	17	8	17			
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	15	0	20	0			
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	20	6	40			
43	Sikalbaha 105 MW PP (Baraka Sikabaha)	HFO (IPP)	6x18.415	105	105	17	17	17	17			
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	220	222	225	225			
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.94	300	300	69	263	70	270			
47	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	25	25	25			
48	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	32	0	17			
49	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	40	74	60	70			
50	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	10	12	12	12			
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			5	12	10	12			
51	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0			
52	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	17			
53	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	17	17	17			
54	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	25	25	25	25			
55	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	25	25	25	25			
56	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	24	51	34	51			
57	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	53	100	33	160			
58	SS Power Unit-1	Coal (IPP)	1x612	612	612	500	612	500	600			
	Matarbari 2*600 MW (CPGCL)	Coal				200	207	180	180			Test run
	Cox's Bazar Wind PP	(Wind) (IPP)				2	2	10	10			Test run
Chattogram Zone Total				3217	3157	1436	1901	1452	1943	180	330	
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	47	47	50	50			
60	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	206	205	210	210			
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	270	280	300	300			
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	285	285	300	300			
63	Ashuganj 420 MW CCPP(East)	Gas (APSCCL)	1x284+1x116	400	400	330	285	300	300			
64	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*16	195	195	0	0	0	0	195		Gas Shortage
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51			
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	6	122	6	150			
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	47			
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163		Under maint.
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	17	17	17			
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	15	15	15	15			
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	10	11	11			
72	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33			
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	52	8	52			
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	0	12	12	12			
75	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	114	17	114			
76	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	28	78	27	75			
77	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	11	54	21	54			
78	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	36	95	36	95			
**	Import (Tripura)	India		160	160	140	144	149	165			
Cumilla Zone Total				2904	2896	1508	1899	1563	2051	195	163	
79	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	30	31	32	65	171		Gas Shortage
80	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	17	18	19	19			
81	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	88	99	70	105			
82	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	65	150	65	145			
83	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
84	Sutiakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	48	0	50	0			
85	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	18	18	18	18			
Mymensingh Zone Total				622	614	268	316	256	352	171	0	

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	15.10.23 (Yesterday)		16.10.23 (Today)		15.10.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	Gas/Coal/Oil/Water Limitation MW	Machines shut down (MW)		
86	Fenchuganj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43		27	GT-1 Under maint.	
87	Fenchuganj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	27	27	30		63	GT-4 Under maint.	
88	Fenchuganj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	47	50	50				
89	Kushiana 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	112	163	163				
90	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	11	11				
91	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	60	61	60				
92	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0		330	Under maint.	
93	Shahjibazar 68MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	84	85	86				
94	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	159	159	158				
95	Sylhet 20 MW GTTP	Gas (PDB)	1x2.0	20	20	0	0	17				
96	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	10	10				
97	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	8	8				
98	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	280	285	300				
99	Bibiana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	403	403	400				
100	Bibiana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	0	0	0		383	under maint.	
101	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0		100	Under project work	
102	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12'3.3+5'2	50	50	42	42	48				
Sylhet Zone Total					2472	2427	1285	1347	1384	1384	0	903
103	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0				
104	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0		410	Gas Shortage	
105	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0		45		
106	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	44	0		51		
107	Khulna 225 MW CAPP	HSD Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0		0		
108	Russha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	53	35		50		
109	Machumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	15	100		105		
110	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	82	0	100		0		
111	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	51	49		51		
112	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5'8.5	40	40	0	8	0		24		
113	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	376	523	450		520		
114	Khulna 330 MW CAPP (GT)	Gas/HSD (PDB)	1x220+1x116	336	336	186	120	0		0		
**	Bheramara (HVCDC) India			1000	1000	906	735	911		911		
Khulna Zone Total					3241	3237	1550	1549	1645	1757	410	0
115	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	16	16		110		
116	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	21	28	21		28		
117	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	124	132	130		130		
118	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	740	1090	1000		1244		
119	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	19	38		150		
120	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	150	150	150		150		
121	Bhola 220MW CAPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	220	220		220		
Barishal Zone Total					2265	2265	1255	1655	1575	2032	0	0
122	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0		71	Gas Shortage	
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0		100	Under maint.	
123	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	28	0		31		
124	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0		0		
125	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	10	0		16		
126	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	48	48	50		92		
127	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	32	39	30		39		
128	Katakhal 50 MW PP (Northern)	HFO (ORPP)	6x8.9	50	50	42	8	34		42		
129	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	35	38	24		30		
130	Sirajganj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	212	180	200		200		
131	Sirajganj 225MW CAPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	0	0	0		220	Gas Shortage	
132	Sirajganj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	212	212	170		200		
133	Sirajganj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	414	350	380		400		
134	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11		11		
135	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	8	8		8		
136	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6'18.55	113	113	35	55	35		55		
137	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	28	50	35		50		
138	Ammura 50 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	28	14	28		28		
139	Sirajganj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	4	0	6		0		
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	524	519	525		525		
Rajshahi Zone Total					3653	3631	1633	1570	1536	1727	291	100
140	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0		85	Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0		85	Under Overhauling	
141	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	170	170	170		170		
142	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0		0		
143	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	0	71	0		70		
144	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0		0		
145	Majpara, Talsila 5 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	6	0	8		0		
146	Thakurgaon 118MW PP (Energypac)	HFO (IPP)	6'20	115	115	0	75	70		115		
147	Lalmohar 30 MW Solar (Intraco)	Solar (IPP)	1'30	30	30	24	0	30		0		
148	Tweeta Solar Limited	Solar (IPP)	1 x 200	200	200	164	0	130		0		
Rangpur Zone Total					1030	950	364	316	408	355	85	85
Sub-total: Plants in operation					25059	24599	11898.0	13826	12508	14964	1837	1956
(B) Plants under long term maintenance/ contract expired												
149	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0		0		
150	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0		0		
151	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	0	0	0	0		0		
152	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	0	0	0	0		0		
Sub-total: Plants under long term maintenance/ contract expired					280	0	0	0	0	0	0	0
Gross Total					25339	24599	11898	13826	12508	14964	1837	1956
(C) Actual data of 15.10.23 (Yesterday) Sunday :												
01.	Max. Demand at eve. peak (Generation end)	:	13852	MW, at =	19:30 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :						
02.	Max. Demand at eve. peak (Sub-station end)	:	13319	MW, at =	19:30 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW
03.	Highest Generation (Generation end)	:	13826	MW, at =	19:30 hrs	Dhaka	5008	4993	15	Mymensingh	1076	1066
04.	Minimum Generation (Generation end)	:	10321	MW, at =	6:00 hrs	Chattogram	1317	1317	0	Sylhet	534	534
05.	Day-peak Generation (Generation end)	:	11898	MW, at =	12:00 hrs	Khulna	1596	1596	0	Barishal	404	404
06.	Evening-peak Generation (Generation end)	:	13826	MW, at =	19:30 hrs	Rajshahi	1299	1299	0	Rangpur	779	779
07.	Evening Peak Load-shed (Sub-station end)	:	25	MW, at =	19:30 hrs	Cumilla	1308	1308	0			
08.	Minimum Generation Forecast up to 8:00 hrs.	:	10163	MW, at =	5:00 hrs							
09.	Generation shortfall at evening peak due to :	:								Total	13319	13294
	a) Gas/LF limitation	:	1752	MW								
	d) Coal supply Limitation	:	85	MW								
	b) Low water level in Kaptai lake	:	0	MW								
	c) Plants under shut down/ maintenance	:	1956	MW								
10.	Total Energy (Generation + India Import)	:	288.96	MKWh								
	By Gas =	146,089	MKWh	By Oil =	40,142	MKWh						
	By Coal =	72,311	MKWh	By Hydro =	3,634	MKWh						
	By Solar =	2,443	MKWh									
11.	Total Gas Supplied	:	1061.45	MMCFD								
(D) Forecast of 16.10.23 (Today) Monday :												
01.	Maximum Demand	:	14000	MW	(Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)	
02.	Maximum Generation	:	14964	MW	(Generation end)	05.	Total Generation	:	292.59	MKWh		
03.	Reserve / Shortage	:	964	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	:	32.2°C			

* Captive Power ** Imported Power
#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation