

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 3564667, 3551095

Month October, 2023				Day : Tuesday				Date : 17.10.23				
Probable Maximum Demand : 14000 MW				Probable Maximum Generation : 14627 MW								
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 106.14 ft		Today = 106.00 ft		Rule Curve = 107.50 ft				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	16.10.23 (Yesterday)		17.10.23 (Today)		16.10.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/Oil/Water Limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	140	140	140	140			
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190		Gas Shortage
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0			
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108		Gas Shortage
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0			
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	332	320	330	330			
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450			
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	411	422	410	412			
11	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	323	336	335	335			
13	Meghnaghat 335MW CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	307	266	300	300			
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	25	15	15			
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	24	74	80	92			
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	17	17	17	17			
17	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	19	31	37	37			
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33			
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	18	20	24	24			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	25	8	25			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	34	105	35	105			
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	16	149	16	149			
23	Kamalaghat 54 MW PP (Barco Energy)	HFO (IPP)	3x18.69	54	54	0	35	0	35			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	85	130	80	130			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	17	104	17	105			
26	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	55	0	55			
27	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	35	0	35			
28	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	53	53	17	53			
29	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	17	72	17	72			
30	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	30	0	35	0			
31	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	55	55	55	55			
32	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	57	57	55	65			
33	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	39	74	66	72			
34	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	72	93	80	93			
35	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	37	36	44	44			
36	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			
	Meghnaghat Unique Power	Gas			0	0	0	0	0			
	Meghnaghat 589 MW CCPP(Summit)	Gas			0	0	0	0	0			
Dhaka Zone Total			5655	5422	2609	3212	2696	3278	613	375		
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	109	108	118	153			
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0			
40	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	17	8	17			
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	19	0	20	0			
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	19	6	40			
43	Sikalbaha 105 MW PP (Baraka Sikabaha)	HFO (IPP)	6x18.415	105	105	17	17	17	17			
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	217	224	225	225			
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.94	300	300	70	267	70	270			
47	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	12	12	12	12			
48	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	0	0	0			
49	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	41	57	65	70			
50	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	10	12	12	12			
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			2	9	10	10			
51	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0			
52	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	17			
53	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	17	17	17			
54	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	12	12	12	12			
55	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	12	12	25	25			
56	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	34	51	34	51			
57	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	22	110	33	160			
58	SS Power Unit-1	Coal (IPP)	1x612	612	612	500	612	600	600			
	Matarbari 2*600 MW (CPGCL)	Coal				146	146	150	150			Test run
	Cox's Bazar Wind PP	(Wind) (IPP)				2	1	10	10			Test run
Chattogram Zone Total			3217	3157	1271	1720	1466	1868	180	330		
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	49	47	50	50			
60	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	203	189	210	210			
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	310	270	300	300			
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	320	300	300	300			
63	Ashuganj 420 MW CCPP(East)	Gas (APSCCL)	1x284+1x116	400	400	315	310	300	300			
64	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*16	195	195	0	0	0	195			Gas Shortage
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51			
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	5	112	6	150			
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	47			
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0		163	Under maint.
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	17	17	17			
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	15	18	15	15			
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	10	10	11	11			
72	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33			
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	52	8	52			
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	12	12	12	12			
75	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	34	17	114			
76	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	28	77	27	75			
77	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	35	54	35	54			
78	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	36	95	36	95			
**	Import (Tripura)	India		160	160	130	134	149	165			
Cumilla Zone Total			2904	2896	1569	1815	1577	2051	195	163		
79	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	26	33	32	65	169		Gas Shortage
80	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	16	16	19	19			
81	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	88	99	60	99			
82	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	65	103	18	100			
83	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
84	Sutiakehal 50 MW Solar PP	Solar (IPP)	1x50	50	50	35	0	50	0			
85	Tangail 22 MW PP(PPLGL)	HFO (IPP)	4x6.7	22	22	18	18	18	18			
Mymensingh Zone Total			622	614	250	269	199	301	169	0		

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	16.10.23 (Yesterday)		17.10.23 (Today)		16.10.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	Gas/Coal/Oil/Water Limitation MW	Machines shut down (MW)		
86	Fenchuganj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43		27	GT-1 Under maint.	
87	Fenchuganj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	27	27	30		63	GT-4 Under maint.	
88	Fenchuganj 51 MW PP (Barakattullah)	Gas (RPP)	19x2.90	51	51	47	50	50				
89	Kushiana 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	163	163				
90	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	3	11		11		
91	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	59	60	60				
92	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0		330	Under maint.	
93	Shahjibazar 68MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	81	85	86				
94	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	158	159	158				
95	Sylhet 20 MW GTTP	Gas (PDB)	1x 20	20	20	0	0	17				
96	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10				
97	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16				
98	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	260	300				
99	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	405	403	400				
100	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	0	0	0		383	under maint.	
101	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0		100	Under project work	
102	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.4+5*2	50	50	44	47	48				
Sylhet Zone Total					2472	2427	1358	1392	0	903		
103	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0				
104	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0		410	Gas Shortage	
105	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	12	0		12		
106	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0		51		
107	Khulna 225 MW CCPP	HSD Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0				
108	Ruzsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	35	35		50		
109	Machumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	25	100		105		
110	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	84	0	100				
111	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	61	49		61		
112	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	24	0		24		
113	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	377	453	450		520		
114	Khulna 330 MW CCPP (GT)	Gas/HSD (BPDB)	1x220+1x116	336	336	357	117	0		0		
**	Bheramara (HVCDC) India			1000	1000	905	734	910		750		
Khulna Zone Total					3241	3237	1723	1461	1644	1573	410	0
115	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	32	16		110		
116	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	20	28	21		28		
117	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	128	130	130		130		
118	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	680	1230	1000		1244		
119	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	54	38		150		
120	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	150	200	150		200		
121	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	222	220		220		
Barisal Zone Total					2265	2265	1198	1896	1575	2082	0	0
122	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0		71	Gas Shortage	
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0		100	Under maint.	
123	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	26	0		31		
124	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0		0		
125	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	5	0		16		
126	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	94	50		92		
127	Katakhat 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	39	30		39		
128	Katakhat 50 MW PP (Northern)	HFO (ORPP)	6x8.9	50	50	25	42	34		42		
129	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	38	24		30		
130	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	212	214	200		200		
131	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	0	0	0		220	Gas Shortage	
132	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	209	204	200		200		
133	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	414	390	380		400		
134	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11		11		
135	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	8	8		8		
136	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	35	55	35		55		
137	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	30	50	35		50		
138	Ammura 50 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	0	0	28		28		
139	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	4	0	6	0		0		
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	531	524	525		525		
Rajshahi Zone Total					3653	3631	1471	1700	1566	1727	291	100
140	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0		85	Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0		85	Under Overhauling	
141	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	170	170	170		170		
142	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0		0		
143	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	29	61	30		70		
144	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0		0		
145	Majpara, Talsila 5 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	5	0	8		0		
146	Thakurgaon 118MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	112	70		115		
147	Lalmohanhat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	32	0	30		0		
148	Treesta Solar Limited	Solar (IPP)	1 x 200	200	200	177	0	130		0		
Rangpur Zone Total					1030	950	413	343	438	355	85	85
Sub-total: Plants in operation					25059	24599	11862.0	13742	12553	14627	1943	1956
(B) Plants under long term maintenance/ contract expired												
149	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0		0		
150	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0		0		
151	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	0	0	0	0		0		
152	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	0	0	0	0		0		
Sub-Total: Plants under long term maintenance/ contract expired					280	0	0	0	0	0	0	0
Gross Total					25339	24599	11862	13742	12553	14627	1943	1956
(C) Actual data of 16.10.23 (Yesterday) Monday :												
01.	Max. Demand at eve. peak (Generation end)	:	13742 MW, at =	19:30 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	13177 MW, at =	19:30 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	13742 MW, at =	19:30 hrs	Dhaka	5026	5026	0	Mymensingh	1086	1086	0
04.	Minimum Generation (Generation end)	:	10163 MW, at =	6:00 hrs	Chattogram	1227	1227	0	Sylhet	535	535	0
05.	Day-peak Generation (Generation end)	:	11862 MW, at =	12:00 hrs	Khulna	1553	1553	0	Barisal	395	395	0
06.	Evening-peak Generation (Generation end)	:	13742 MW, at =	19:30 hrs	Rajshahi	1331	1331	0	Rangpur	758	758	0
07.	Evening Peak Load-shed (Sub-station end)	:	0 MW, at =	19:30 hrs	Cumilla	1265	1265	0				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	10151 MW, at =	5:00 hrs								
09.	Generation shortfall at evening peak due to :	:							Total	13177	13177	0
	a) Gas/LF limitation	:	1858 MW		13.	Fuel cost :	(a) Gas = 156179624 Taka	(c) Coal = 471321733 Taka				
	d) Coal supply Limitation	:	85 MW				(b) Oil = 459161964 Taka	Total = 1086663321 Taka				
	b) Low water level in Kaptai lake	:	0 MW									
	c) Plants under shut down/ maintenance	:	1956 MW		14.	Maximum Temperature in Dhaka was :	33.3°C					
10.	Total Energy (Generation + India Import)	:	279.51 MKWh		15.	Export through East-West interconnections :						
	By Gas = 140.643 MKWh	By Oil =	39.153 MKWh			At evening peak-hour	:	11862 MW, at	19:30 hrs			
	By Coal = 69.939 MKWh	By Hydro =	3.012 MKWh			Maximum	:	232 MW, at	20:00 hrs			
	By Solar = 2.664 MKWh					Energy	:	0 MKWh				
11.	Total Gas Supplied	:	1070.75 MMCFD									
(D) Forecast of 17.10.23 (Today) Tuesday :												
01.	Maximum Demand	:	14000 MW (Generation end)		04.	Maximum Load-shed	:	0 MW At evening peak (Sub-station end)				
02.	Maximum Generation	:	14627 MW (Generation end)		05.	Total Generation	:	284.75 MKWh				
03.	Reserve / Shortage	:	627 MW (Generation end)		06.	Probable Max. Temperature in Dhaka :	33.3°C					

* Captive Power ** Imported Power

#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation