

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9364667, 9551095

Month October, 2023				Day: Wednesday				Date: 18.10.23				
Probable Maximum Demand : 14000 MW				Probable Maximum Generation : 14730 MW				Rule Curve = 107.60 ft.				
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 106.00 ft				Today = 105.84 ft				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	17.10.23 (Yesterday)		18.10.23 (Today)		17.10.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
					Day	Evening	Day	Evening	Gas/Coal/Oil/Water Limitation MW	Machines shut down (MW)		
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	140	140	140	140			
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190	Gas Shortage	
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0			
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108	Gas Shortage	
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage	
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0			
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	323	292	330	330			
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450			
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	411	409	410	412			
11	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage	
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	330	330	335	335			
13	Meghnaghat 335MW CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	307	250	300	300			
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	15	15	15			
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	25	58	80	92			
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	15	17	17	17			
17	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	30	30	37	37			
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	33	33	33			
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	14	20	24	24			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	25	8	25			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	35	105	35	105			
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	16	149	16	149			
23	Kamalghat 54 MW PP (Barco Energy)	HFO (IPP)	3x18.69	54	54	0	35	0	35			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	80	130	80	130			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	17	118	17	105			
26	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	55	0	55			
27	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	35	0	35			
28	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	35	72	17	72			
29	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	17	72	17	72			
30	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	0	0	35	0			
31	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	35	55	55	55			
32	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	55	66	55	65			
33	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	42	75	66	75			
34	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	48	95	80	95			
35	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	24	25	44	44			
36	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			
	Meghnaghat Unique Power	Gas			0	0	0	0	0			
	Meghnaghat 589 MW CCPP(Summit)	Gas			0	0	0	0	0			
Dhaka Zone Total			5655	5422	2497	3156	2696	3302	613	375		
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	151	153	162	197			
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180 Under maint.	
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0			
40	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	17	8	17			
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	20	0	20	0			
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	19	6	40			
43	Sikalbaha 105 MW PP (Baraka Sikabaha)	HFO (IPP)	6x18.415	105	105	17	17	17	17			
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	215	223	225	225			
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.94	300	300	70	214	70	270			
47	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	12	12	12	12			
48	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	0	0	0			
49	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	24	66	65	70			
50	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	12	12	12	12			
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			2	18	10	18			
51	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0			
52	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	17			
53	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	17	17	17			
54	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	12	12	12	12			
55	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	12	12	25	25			
56	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	34	51	34	51			
57	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	35	114	33	160			
58	SS Power Unit-1	Coal (IPP)	1x612	612	612	621	621	600	600			
	Matarbari 2*600 MW (CPGCL)	Coal				138	144	150	150		Test run	
	Cox's Bazar Wind PP	(Wind) (IPP)				0	0	10	10		Test run	
Chattogram Zone Total			3217	3157	1427	1739	1510	1920	180	330		
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	50	50	50	50			
60	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	200	176	210	210			
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	325	300	300	300			
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	340	280	300	300			
63	Ashuganj 420 MW CCPP(East)	Gas (APSCCL)	1x284+1x116	400	400	280	375	300	300			
64	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*16	195	195	0	0	0	0	195	Gas Shortage	
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51			
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	5	118	6	150			
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	47			
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163	Under maint.	
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	34	17	17			
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	18	18	18			
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	10	10	11	11			
72	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	25	25	33	33			
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	52	16	52			
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	12	12	12	12			
75	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	102	17	114			
76	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	9	78	27	75			
77	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	35	54	35	54			
78	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	36	95	36	95			
**	Impoort (Tripura)	India		160	160	96	140	149	165			
Cumilla Zone Total			2904	2896	1534	1970	1588	2054	195	163		
79	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	26	34	32	65	168	Gas Shortage	
80	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	16	16	19	19			
81	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	79	99	60	99			
82	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	28	102	18	100			
83	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0			
84	Sutiakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	51	0	50	0			
85	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	18	18	18	18			
Mymensingh Zone Total			622	614	219	269	199	301	168	0		

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	17.10.23 (Yesterday)		18.10.23 (Today)		17.10.23 (Yesterday)		Status of Machines under shut-down/ Maintenance			
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date		
						Day	Evening	Day	Evening	Gas/Coal/Oil/Water Limitation MW	Machines shut down (MW)				
86	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	42	43	43	43		27	GT-1 Under maint.			
87	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	0	20	30	30		70	GT-4 Under maint.			
88	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	42	50	50	50						
89	Kushiera 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	163	163	163						
90	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	3	11	11						
91	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	59	61	60	60						
92	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.			
93	Shahjibazar 68MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	84	85	86	86						
94	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	159	157	158	158						
95	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	0	0	17	17						
96	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10						
97	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16						
98	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	305	265	300	300						
99	Bibiana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	405	368	400	400						
100	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	0	0	0	0		383	under maint.			
101	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work			
102	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12'3.3+5'2	50	50	44	47	48	48						
Sylhet Zone Total						2472	2427	1337	1288	1392	1392	0	910		
103	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0						
104	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0		410	Gas Shortage			
105	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	26	0	26						
106	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	51						
107	Khulna 225 MW CCPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0						
108	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	53	35	53						
109	Machumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	15	50	100	105						
110	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	71	0	100	0						
111	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	16	81	49	81						
112	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5'8.5	40	40	16	16	0	24						
113	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	401	571	450	520						
114	Khulna 330 MW CCPP (GT)	Gas/HSD (BPDB)	1x220+1x116	336	336	0	0	0	0						
**	Bheramara (HVCDC) India			1000	1000	895	757	910	750						
Khulna Zone Total						3241	3237	1414	1554	1644	1610	410	0		
115	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	32	16	110						
116	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	20	27	21	28						
117	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	130	126	130	130						
118	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	860	1244	1000	1244						
119	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	12	54	38	150						
120	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	150	150	150	150						
121	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	222	220	220						
Barishal Zone Total						2265	2265	1408	1855	1575	2032	0	0		
122	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage			
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.			
123	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	26	0	31						
124	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0						
125	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	16						
126	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	47	94	50	92						
127	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	39	39	30	39						
128	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	34	42	34	42						
129	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	24	30						
130	Sirajganj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	214	209	200	200						
131	Sirajganj 225MW CCPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	0	0	0	0		220	Gas Shortage			
132	Sirajganj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	208	205	200	200						
133	Sirajganj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	414	360	380	400						
134	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11						
135	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	8	8	8						
136	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6'18.55	113	113	35	35	35	55						
137	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	35	35	50						
138	Ammura 50 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	0	0	28	28						
139	Sirajganj 6.55 MW Solar	Solar (NWPGL)	1x6	6	4	0	0	6	0						
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	522	530	525	525						
Rajshahi Zone Total						3653	3631	1536	1594	1566	1727	291	100		
140	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Coal Shortage			
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling			
141	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	170	170	170	170						
142	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	16	0	0						
143	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	6	107	30	107						
144	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0						
145	Majpara, Talsila 5 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	7	0	8	0						
146	Thakurgaon 118MW PP (Energypac)	HFO (IPP)	6'20	115	115	0	114	70	115						
147	Lalmohanhat 30 MW Solar (Intraco)	Solar (IPP)	1'30	30	30	36	0	30	0						
148	Tweeta Solar Limited	Solar (IPP)	1 x 200	200	200	163	0	130	0						
Rangpur Zone Total						1030	950	382	407	438	392	85	85		
Sub-total: Plants in operation						25059	24599	11754.0	13832	12608	14730	1942	1963		
(B) Plants under long term maintenance/ contract expired															
149	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0						
150	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0						
151	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	0	0	0	0	0						
152	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	0	0	0	0	0						
Sub-Total: Plants under long term maintenance/ contract expired						280	0	0	0	0	0	0	0		
Gross Total						25339	24599	11754	13832	12608	14730	1942	1963		
(C) Actual data of 17.10.23 (Yesterday) Tuesday :															
01.	Max. Demand at eve. peak (Generation end)	:	13832	MW, at =	19:30 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :									
02.	Max. Demand at eve. peak (Sub-station end)	:	13235	MW, at =	19:30 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW		
03.	Highest Generation (Generation end)	:	13832	MW, at =	19:30 hrs	Dhaka	4993	4993	0	Mymensingh	1093	1093	0		
04.	Minimum Generation (Generation end)	:	10151	MW, at =	6:00 hrs	Chattogram	1268	1268	0	Sylhet	539	539	0		
05.	Day-peak Generation (Generation end)	:	11754	MW, at =	12:00 hrs	Khulna	1560	1560	0	Barishal	411	411	0		
06.	Evening-peak Generation (Generation end)	:	13832	MW, at =	19:30 hrs	Rajshahi	1310	1310	0	Rangpur	762	762	0		
07.	Evening Peak Load-shed (Sub-station end)	:	0	MW, at =	19:30 hrs	Cumilla	1300	1300	0						
08.	Minimum Generation Forecast up to 8:00 hrs.	:	10120	MW, at =	5:00 hrs										
09.	Generation shortfall at evening peak due to :	:				Total						13235	13235	0	
	a) Gas/LF limitation	:	1857	MW		13. Fuel cost :									
	d) Coal supply Limitation	:	85	MW		(a) Gas = 153449893 Taka						(c) Coal = 493507489 Taka			
	b) Low water level in Kaptai lake	:	0	MW		(b) Oil = 470048874 Taka						Total = 1117006256 Taka			
	c) Plants under shut down/ maintenance	:	1963	MW		14. Maximum Temperature in Dhaka was :						33.5°C			
10.	Total Energy (Generation + India Import)	:	284.28	MKWh		15. Export through East-West interconnections :									
	By Gas = 144.440 MKWh			By Oil = 36.277 MKWh		At evening peak-hour :						11754	MW, at 19:30 hrs		
	By Coal = 74.036 MKWh			By Hydro = 3.617 MKWh		Maximum :						232	MW, at 20:00 hrs		
	By Solar= 2.515 MKWh					Energy :						0	MKWh		
11.	Total Gas Supplied	:	1059.11	MMCFD		06. Probable Max. Temperature in Dhaka : 33.5°C									
(D) Forecast of 18.10.23 (Today) Wednesday :															
01.	Maximum Demand	:	14000	MW (Generation end)		04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)				
02.	Maximum Generation	:	14730	MW (Generation end)		05.	Total Generation	:	287.73	MKWh					
03.	Reserve / Shortage	:	730	MW (Generation end)		06.	Probable Max. Temperature in Dhaka :	:	33.5°C						

* Captive Power ** Imported Power

#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation