

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 3564667, 3551095

Month October, 2023				Day : Sunday				Date : 29.10.23				
Probable Maximum Demand : 13000 MW				Probable Maximum Generation : 14344 MW				Rule Curve = 108.70 ft.				
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 103.27 ft				Today = 103.02 ft				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	28.10.23 (Yesterday)		29.10.23 (Today)		28.10.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)		
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	150	180	130	180			
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190		Gas Shortage
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0			
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108		Gas Shortage
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0			
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	325	327	330	330			
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225	225		Gas Shortage
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	417	420	400	412			
11	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	254	260	250	300			
13	Meghnaghat 335MW CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	152	152	150	150	183		Gas Shortage
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	15	15	15			
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	0	8	8	8			
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	18	18	18	18			
17	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	31	31	31	32	32		
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33			
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	32	30	33	33			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	25	8	25			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	17	34	35	88			
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	0	48	16	149			
23	Kamalghat 54 MW PP (Barco Energy)	HFO (IPP)	3x18.69	54	54	0	17	0	17			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	10	15	80	130			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	17	82	17	136			
26	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	17	0	55			
27	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	35	0	35			
28	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	0	17	0	17			
29	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	17	35	17	35			
30	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	30	0	35	0			
31	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	35	55	55			
32	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	0	9	8	8			
33	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	5	8	8	8			
34	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	52	85	97			
35	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	0	10	45			
36	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			
	Meghnaghat Unique Power	Gas			100	63	100	100	100			
	Meghnaghat 589 MW CCPP(Summit)	Gas			0	0	0	0	0			
Dhaka Zone Total			5655	5422	1858	2191	2098	2736	1021	375		
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	206	205	205	205			
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0			
40	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	3	8	17			
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	20	0	20	0			
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	19	6	19			
43	Sikalbaha 105 MW PP (Baraka Sikabaha)	HFO (IPP)	6x18.415	105	105	17	17	17	17			
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150		Under maint.
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	215	215	210	215			
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.94	300	300	100	150	100	270			
47	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	12	12	12	12			
48	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	17	34	17	34			
49	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	66	40	70			
50	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	12	12	12	12			
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			1	20	10	20			
51	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0			
52	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	17	17	17			
53	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	11	17	17	17			
54	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	12	12	12	12			
55	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	10	12	12	12			
56	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	3	34	17	34			
57	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	0	17	35	163			
58	SS Power Unit-1	Coal (IPP)	1x612	612	612	325	602	480	600			
	Matarbari 2*600 MW (CPGCL)	Coal			199	193	180	180				Test run
	Cox's Bazar Wind PP	(Wind) (IPP)			1	2	10	10				Test run
Chattogram Zone Total			3217	3157	1165	1659	1442	1936	180	330		
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	0	0	0	0			
60	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	163	188	190	200			
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	270	240	250	260			
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	280	280	275	300			
63	Ashuganj 420 MW CCPP(East)	Gas (APSCCL)	1x284+1x116	400	400	250	230	250	250			
64	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*16	195	195	0	0	0	0	195		Gas Shortage
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51			
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	66	6	150			
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	30			
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163		Under maint.
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	0	17	17	17			
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	16	18	18			
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	9	9	11	11			
72	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33			
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	16	52	52			
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	12	12	12	12			
75	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	17	17	17			
76	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	7	37	28	78			
77	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	35			
78	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	18	90	18	90			
**	Import (Tripura)	India		160	160	130	158	143	166			
Cumilla Zone Total			2904	2896	1258	1477	1388	1770	195	163		
79	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	32	33	30	45	169		Gas Shortage
80	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	17	16	16	19			
81	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	45	87	40	85			
82	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	8	64	66	100			
83	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
84	Sutiakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	51	0	50	0			
85	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	0	6	6	12			
Mymensingh Zone Total			622	614	155	206	210	261	169	0		

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	28.10.23 (Yesterday)		29.10.23 (Today)		28.10.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)		
86	Fenchuganj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43	27	GT-1 Under maint.	
87	Fenchuganj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	0	0	0	0	45	GT-4 Under maint.	
88	Fenchuganj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	0	0	0	0			
89	Kushiana 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	163	163	163			
90	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	2	2	2			
91	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	58	57	50	62	330	Under maint.	
92	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0			
93	Shahjibazar 68MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	0	0	0	0			
94	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	192	191	180	190			
95	Sylhet 20 MW GTTP	Gas (PDB)	1x20	20	16	18	17	18	18			
96	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10			
97	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16			
98	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	270	300	300			
99	Bibiana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	365	367	400	400			
100	Bibiana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	310	310	300	310			
101	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0	100	Under project work	
102	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12'3.3+5'2	50	50	42	42	42	42			
Sylhet Zone Total					2472	2427	1520	1489	1523	1556	45	502
103	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0			
104	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0	410	Gas Shortage	
105	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	40			
106	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	60			
107	Khulna 225 MW CAPP	HSD Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0			
108	Ruzsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	0	53	74			
109	Machumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	9	15	32			
110	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	84	0	100	0			
111	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	0	49	65			
112	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5'8.5	40	40	0	8	0	16			
113	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	354	352	350	400			
114	Khulna 330 MW CAPP (GT)	Gas/HSD (BPDB)	1x220+1x116	336	336	0	0	0	0			
**	Bheramara (HVCDC) India			1000	1000	897	802	902	902			
Khulna Zone Total					3241	3237	1335	1171	1469	1589	410	0
115	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	16	110			
116	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	16	23	21	25			
117	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	130	128	130	130			
118	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	700	1210	800	1244			
119	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	38	150			
120	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	150	150	150	150			
121	Bhola 220MW CAPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	222	220	220			
Barisal Zone Total					2265	2265	1216	1733	1375	2029	0	0
122	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71	Gas Shortage	
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100	Under maint.	
123	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	0	30			
124	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0			
125	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	16			
126	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	25	50	94			
127	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	30	40			
128	Katakali 50 MW PP (Northern)	HFO (ORPP)	6x8.9	50	50	0	0	34	42			
129	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	24	35			
130	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	160	148	150	160	62	Gas Shortage	
131	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	0	0	0	0	220	Gas Shortage	
132	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0	220	Gas Shortage	
133	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	414	212	250	300	202	Gas Shortage	
134	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	0	11	11	11			
135	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	0	8	8			
136	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6'18.55	113	113	0	35	35	55			
137	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	30	35	50			
138	Ammura 50 MW PP (Sinha)	HFO (NENP)	7x7.79	50	28	0	0	28	28			
139	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	5	0	0	6	0			
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	813	1161	950	1200			
Rajshahi Zone Total					3553	3631	1392	1622	1611	2069	775	100
140	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Under Overhauling	
141	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	170	170	170	170			
142	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
143	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x2'3	113	113	0	45	34	113			
144	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
145	Majpara, Talsila 5 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	6	0	8	0			
146	Thakurgaon 118MW PP (Energypac)	HFO (IPP)	6'20	115	115	0	35	70	115			
147	Lalmohanhat 30 MW Solar (Intraco)	Solar (IPP)	1'30	30	30	35	0	30	0			
148	Tweeta Solar Limited	Solar (IPP)	1 x 200	200	200	189	0	130	0			
Rangpur Zone Total					1030	950	400	250	442	398	85	85
Sub-total: Plants in operation					25059	24599	10299.0	11798	11558	14344	2880	1555
(B) Plants under long term maintenance/ contract expired												
149	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			
150	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			
151	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	0	0	0	0	0			
152	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	0	0	0	0	0			
Sub-Total: Plants under long term maintenance/ contract expired					280	0	0	0	0	0	0	0
Gross Total					25339	24599	10299	11798	11558	14344	2880	1555
(C) Actual data of 28.10.23 (Yesterday) Saturday :												
01.	Max. Demand at eve. peak (Generation end)	:	11798 MW, at =	19:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	11399 MW, at =	19:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	11798 MW, at =	19:00 hrs	Dhaka	4355	4355	0	Mymensingh	863	863	0
04.	Minimum Generation (Generation end)	:	8411 MW, at =	6:00 hrs	Chattogram	1216	1216	0	Sylhet	487	487	0
05.	Day-peak Generation (Generation end)	:	10299 MW, at =	12:00 hrs	Khulna	1309	1309	0	Barisal	334	334	0
06.	Evening-peak Generation (Generation end)	:	11798 MW, at =	19:00 hrs	Rajshahi	1084	1084	0	Rangpur	638	638	0
07.	Evening Peak Load-shed (Sub-station end)	:	0 MW, at =	19:00 hrs	Cumilla	1114	1114	0				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	8502 MW, at =	5:00 hrs								
09.	Generation shortfall at evening peak due to :	:							Total	11399	11399	0
	a) Gas/LF limitation	:	2795 MW		13.	Fuel cost :	(a) Gas = 121058901 Taka	(c) Coal = 521796290 Taka				
	d) Coal supply Limitation	:	85 MW				(b) Oil = 173121254 Taka	Total = 815976445 Taka				
	b) Low water level in Kaptai lake	:	0 MW									
	c) Plants under shut down/ maintenance	:	1555 MW		14.	Maximum Temperature in Dhaka was :	33°C					
10.	Total Energy (Generation + India Import)	:	238.66 MKWh		15.	Export through East-West interconnections :						
	By Gas = 118.149 MKWh	By Oil =	13.195 MKWh			At evening peak-hour	:	10299 MW, at	19:00 hrs			
	By Coal = 74.871 MKWh	By Hydro =	4.969 MKWh			Maximum	:	870 MW, at	19:30 hrs			
	By Solar = 2.746 MKWh					Energy	:	0 MKWh				
11.	Total Gas Supplied	:	937.45 MMCFD									
(D) Forecast of 29.10.23 (Today) Sunday :												
01.	Maximum Demand	:	13000 MW (Generation end)		04.	Maximum Load-shed	:	0 MW At evening peak (Sub-station end)				
02.	Maximum Generation	:	14344 MW (Generation end)		05.	Total Generation	:	262.97 MKWh				
03.	Reserve / Shortage	:	1344 MW (Generation end)		06.	Probable Max. Temperature in Dhaka :	:	33°C				

* Captive Power ** Imported Power
#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation