

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 3564667, 3551095

Month October, 2023				Day : Monday				Date : 30.10.23				
Probable Maximum Demand : 13000 MW				Probable Maximum Generation : 14532 MW								
Water Level of Kapitai Lake at 06:00 AM				Yesterday = 103.02 ft				Today = 102.66 ft				
				Rule Curve = 108.70 ft								
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	29.10.23 (Yesterday)		30.10.23 (Today)		29.10.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW			
					Day	Evening	Day	Evening	Machines shut down (MW)		Description/ Remarks	Probable start-up date
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	180	180	180	180			
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190	Gas Shortage	
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0			
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108	Gas Shortage	
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage	
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0			
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	330	327	330	330			
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225	225	Gas Shortage	
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	386	374	400	412			
11	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage	
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	235	222	0	220			
13	Meghnaghat 335MW CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	152	150	150	150	185	Gas Shortage	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	5	15	15	15			
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	8	8	8	8			
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	15	15	16	16			
17	Summit Power,Madhabdi+Ashulia	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	31	29	31	31			
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	25	25			
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	30	30	30	30			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	25	8	25			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	34	70	35	88			
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	16	98	16	132			
23	Kamalshat 54 MW PP (Barco Energy)	HFO (IPP)	3x18.69	54	54	0	17	0	17			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	38	85	80	130			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	17	76	17	135			
26	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	35	0	55			
27	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	0	0	35			
28	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	0	1	0	17			
29	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	17	35	17	35			
30	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	32	0	35	0			
31	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	33	35	35	55			
32	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	8	9	8	8			
33	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	4	8	8	8			
34	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	45	95	100	100			
35	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	0	10	45			
36	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			
	Meghnaghat Unique Power	Gas				98	51	100	100			
	Meghnaghat 589 MW CCPP(Summit)	Gas				0	0	0	0			
Dhaka Zone Total			5655	5422	1972	2240	1879	2627	1023	375		
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	207	206	205	205			
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0			
40	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	8	8	17			
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	20	0	20	0			
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	19	6	18			
43	Sikalbaha 105 MW PP (Baraka Sikabaha)	HFO (IPP)	6x18.415	105	105	17	17	17	17			
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	213	210	210	215			
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.94	300	300	70	170	65	245			
47	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	12	12	12	12			
48	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	34	17	17			
49	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	3	63	40	65			
50	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	12	12	12	12			
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			0	14	10	20			
51	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0			
52	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	17			
53	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	17	17	17			
54	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	12	12	12	12			
55	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	12	12	12	12			
56	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	17	27	17	34			
57	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	17	53	35	163			
58	SS Power Unit-1	Coal (IPP)	1x612	612	612	500	624	600	600			
	Matarbari 2*600 MW (CPGCL)	Coal				192	141	600	600		Test run	
	Cox's Bazar Wind PP	(Wind) (IPP)				4	4	10	10		Test run	
Chattogram Zone Total			3217	3157	1360	1672	1947	2308	180	330		
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	0	0	0	0			
60	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	198	193	190	200			
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	240	240	275	275			
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	280	280	280	280			
63	Ashuganj 420 MW CCPP(East)	Gas (APSCCL)	1x284+1x116	400	400	240	240	250	250			
64	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*16	195	195	0	0	0	0	195	Gas Shortage	
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51			
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	33	109	150	150			
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	30			
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163	Under maint.	
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	15	18	17	17			
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	12	17	18	18			
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	8	11	11			
72	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33			
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	7	52	52	52			
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	0	12	12	12			
75	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	17	0	0			
76	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	28	77	28	75			
77	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	35			
78	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	18	83	17	94			
**	Import (Tripura)	India		160	160	140	154	143	166			
Cumilla Zone Total			2904	2896	1337	1601	1544	1749	195	163		
79	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	34	33	30	45	169	Gas Shortage	
80	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	16	16	19			
81	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	59	60	40	85			
82	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	38	18	66	100			
83	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
84	Sutakhalai 50 MW Solar PP	Solar (IPP)	1x50	50	50	55	0	50	0			
85	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	6	6	6	6			
Mymensingh Zone Total			622	614	212	133	210	255	169	0		

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	29.10.23 (Yesterday)		30.10.23 (Today)		29.10.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/Oil/Water Limitation MW		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening				
86	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	41	43	43		29	GT-1 Under maint.	
87	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	0	0	0	0	45	45	GT-4 Under maint.	
88	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	0	0	0	0				
89	Kushiana 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	163	163	163				
90	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	2	2	2	2				
91	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	59	62	62	62				
92	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
93	Shahjibazar 68MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	0	0	0	0				
94	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	191	188	190	190				
95	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	16	17	17	18				
96	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
97	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	0	16	16	16				
98	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	280	280	280	300				
99	Bibiyana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	376	376	377	400				
100	Bibiyana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	300	310	300	310				
101	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
102	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12'3.3+5'2	50	50	42	42	42	42				
Sylhet Zone Total						2472	2427	1482	1507	1502	1556	45	504
103	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
104	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0	410		Gas Shortage	
105	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	29	0	40				
106	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	60				
107	Khulna 225 MW CAPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0				
108	Ruzsha 105 MW PP (Orion ruzsha)	HFO (IPP)	6x18.445	105	105	5	18	53	74				
109	Machumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	15	15	32				
110	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	79	0	100	0				
111	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	16	49	65				
112	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5'8.5	40	40	0	8	0	16				
113	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	353	333	350	350				
114	Khulna 330 MW CAPP (GT)	Gas/HSD (BPDB)	1x220+1x116	336	336	0	0	0	0				
**	Bheramara (HVCDC) India			1000	1000	896	896	902	902				
Khulna Zone Total						3241	3237	1333	1315	1469	1539	410	0
115	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	16	110				
116	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	19	22	21	25				
117	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	126	122	130	130				
118	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	780	680	800	1244				
119	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	17	38	150				
120	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	150	150	150	150				
121	Bhola 220MW CAPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	220	220	220				
Barishal Zone Total						2265	2265	1295	1211	1375	2029	0	0
122	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage	
123	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.	
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	0	30				
124	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0				
125	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	16				
126	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	55	50	94				
127	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	40	30	40				
128	Katakali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	8	34	42				
129	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	38	24	35				
130	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	142	152	150	160	58		Gas Shortage	
131	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	0	0	0	0	220		Gas Shortage	
132	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0	220		Gas Shortage	
133	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	229	201	250	300	213		Gas Shortage	
134	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
135	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	43	8	8				
136	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6'18.55	113	113	0	55	35	57				
137	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	43	35	50				
138	Ammura 50 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	0	0	28	28				
139	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	5	0	6	0	0				
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	907	1135	950	1200				
Rajshahi Zone Total						3653	3631	1294	1781	1611	2071	782	100
140	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Coal Shortage	
140	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
141	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	170	170	170	170				
142	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
143	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	0	108	42	113				
144	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
145	Majpara, Talsila 8 MW Solar PP (Sympe Power)	Solar (IPP)	1 x 8	8	8	0	0	8	0				
146	Thakurgaon 118MW PP (Energypac)	HFO (IPP)	6'20	115	115	0	87	70	115				
147	Lalmohanhat 30 MW Solar (Intraco)	Solar (IPP)	1'30	30	30	35	0	30	0				
148	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	185	0	130	0				
Rangpur Zone Total						1030	950	390	365	450	398	85	85
Sub-total: Plants in operation						25059	24599	10675.0	11825	11987	14532	2889	1557
(B) Plants under long term maintenance/ contract expired													
149	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
150	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
151	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	0	0	0	0	0				
152	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	0	0	0	0	0				
Sub-Total: Plants under long term maintenance/ contract expired						280	0	0	0	0	0	0	0
Gross Total						25339	24599	10675	11825	11987	14532	2889	1557
(C) Actual data of 29.10.23 (Yesterday) Sunday :													
01.	Max. Demand at eve. peak (Generation end)	:	11825 MW, at =	18:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :								
02.	Max. Demand at eve. peak (Sub-station end)	:	11642 MW, at =	18:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW	
03.	Highest Generation (Generation end)	:	11825 MW, at =	18:00 hrs	Dhaka	4438	4438	0	Mymensingh	927	927	0	
04.	Minimum Generation (Generation end)	:	8502 MW, at =	6:00 hrs	Chattogram	1233	1233	0	Sylhet	482	482	0	
05.	Day-peak Generation (Generation end)	:	10675 MW, at =	12:00 hrs	Khulna	1340	1340	0	Barishal	331	331	0	
06.	Evening-peak Generation (Generation end)	:	11825 MW, at =	18:00 hrs	Rajshahi	1092	1092	0	Rangpur	724	724	0	
07.	Evening Peak Load-shed (Sub-station end)	:	0 MW, at =	18:00 hrs	Cumilla	1075	1075	0					
08.	Minimum Generation Forecast up to 8:00 hrs.	:	8476 MW, at =	5:00 hrs									
09.	Generation shortfall at evening peak due to :	:											
	a) Gas/LF limitation	:	2804 MW										
	d) Coal supply Limitation	:	85 MW										
	b) Low water level in Kaptai lake	:	0 MW										
	c) Plants under shut down/ maintenance	:	1557 MW										
10.	Total Energy (Generation + India Import)	:	247.73 MKWh										
	By Gas =	123.748 MKWh	By Oil =	16.156 MKWh									
	By Coal =	75.674 MKWh	By Hydro =	4.872 MKWh									
	By Solar=	2.715 MKWh											
11.	Total Gas Supplied	:	943.74 MMCFD										
(D) Forecast of 30.10.23 (Today) Monday :													
01.	Maximum Demand	:	13000 MW (Generation end)		04.	Maximum Load-shed	:	0 MW	At evening peak (Sub-station end)				
02.	Maximum Generation	:	14532 MW (Generation end)		05.	Total Generation	:	272.34 MKWh					
03.	Reserve / Shortage	:	1532 MW (Generation end)		06.	Probable Max. Temperature in Dhaka :	:	32.5°C					

* Captive Power ** Imported Power
#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation