

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 3564667, 3551095

Month October, 2023					Day : Tuesday					Date : 31.10.23				
Probable Maximum Demand : 12000 MW					Probable Maximum Generation : 14555 MW					Rule Curve = 108.70 ft.				
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 102.66 ft Today = 102.39 ft									
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	30.10.23 (Yesterday)		31.10.23 (Today)		30.10.23 (Yesterday)		31.10.23 (Today)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :					
					Day	Evening	Day	Evening	Gas/Coal/Oil/Water Limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date		
(A) Plants in operation:														
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work		
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	160	180	180	180					
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190		Gas Shortage		
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0					
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108		Gas Shortage		
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage		
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0					
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	330	322	330	330					
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	170	225	225	280		Gas Shortage		
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling		
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	414	376	400	412					
11	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage		
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	30	335					
13	Meghnaghat 335MW CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	152	120	150	150	215		Gas Shortage		
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	15	15	15					
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	8	8	8	8					
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	11	15	16	16					
17	Summit Power,Madhabdi+Ashulia	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	30	30	31	31					
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33					
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	24	26	30	30					
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	25	8	25					
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	35	88	35	88					
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	16	82	16	132					
23	Kamalghat 54 MW PP (Barco Energy)	HFO (IPP)	3x18.69	54	54	0	35	0	17					
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	80	108	80	130					
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	17	41	17	135					
26	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	17	0	55					
27	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	35	0	35					
28	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	6	0	0	17					
29	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	17	35	17	35					
30	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	31	0	35	0					
31	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	35	35	35	55					
32	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	9	9	8	8					
33	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	4	8	8	8					
34	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	72	95	100	100					
35	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	13	45	10	45					
36	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0					
	Meghnaghat Unique Power	Gas			388	200	100	100	100					
	Meghnaghat 589 MW CCPP(Summit)	Gas			0	38	0	0	0					
Dhaka Zone Total			5655	5422	2133	2191	1917	2750	1108	375				
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	208	160	162	162					
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage		
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.		
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0					
40	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	5	8	17					
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	20	0	20	0					
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	2	19	6	19					
43	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	17	17	17					
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150		Under maint.		
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	202	202	210	215					
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.94	300	300	88	220	65	245					
47	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	12	12	12	12					
48	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	17	34	17	34					
49	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	6	82	40	65					
50	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	12	12	12	12					
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			0	0	7	20					
51	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0					
52	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	17					
53	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	17	17	17					
54	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	12	12	12	12					
55	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	12	12	12	12					
56	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	17	17	17	34					
57	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	36	36	35	163					
58	SS Power Unit-1	Coal (IPP)	1x612	612	612	321	415	600	600					
	Matarbari 2*600 MW (CPGCL)	Coal				257	257	300	300			Test run		
	Cox's Bazar Wind PP	(Wind) (IPP)				4	0	10	10			Test run		
Chattogram Zone Total			3217	3157	1281	1546	1601	1983	180	330				
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	0	0	0	0	45		Gas Shortage		
60	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	168	179	190	200					
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	240	240	275	275	120		Gas Shortage		
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	280	315	280	280					
63	Ashuganj 420 MW CCPP(East)	Gas (APSCCL)	1x284+1x116	400	400	240	240	240	240	160		Gas Shortage		
64	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*16	195	195	0	0	0	0	195		Gas Shortage		
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51					
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	50	100	150	150					
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	30					
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163		Under maint.		
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	17	17	17					
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	17	18	18	18					
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	8	11	11					
72	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	25	24	33	33					
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	28	43	52	52					
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	12	12	12	12					
75	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	17	17	17					
76	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	17	87	28	88					
77	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	35					
78	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	18	94	17	94					
**	Impootti (Tripura)	India		160	160	127	146	143	166					
Cumilla Zone Total			2904	2896	1332	1608	1551	1769	520	163				
79	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	33	34	34	45	168		Gas Shortage		
80	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	16	19					
81	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	89	90	40	85					
82	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	28	95	66	100					
83	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0					
84	Sutakhalai 50 MW Solar PP	Solar (IPP)	1x50	50	50	53	0	50	0					
85	Tangail 22 MW PP(PPLGL)	HFO (IPP)	4x6.7	22	22	6	6	6	6					
Mymensingh Zone Total			622	614	230	244	214	255	168	0				

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	30.10.23 (Yesterday)		31.10.23 (Today)		30.10.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening	Gas/Coal/Oil/Water Limitation MW	Machines shut down (MW)		
86	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	0	0	0	0		70	GT-1 Under maint.	
87	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	28	20	40	40	45	25	GT-4 Under maint.	
88	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)		51	51	0	0	0	0				
89	Kushlira 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	163	163	163				
90	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	2	2	2	2				
91	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	58	55	62	62				
92	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
93	Shahjibazar 68MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	0	0	0	0				
94	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	201	200	200	200				
95	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	17	17	17	17				
96	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
97	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	16	16	16				
98	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	290	290	290	300				
99	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	403	404	400	400				
100	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	300	300	300	310				
101	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
102	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12'3.3+5'2	50	50	45	42	42	42				
Sylhet Zone Total						2472	2427	1525	1519	1542	1562	45	525
103	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
104	Bheramara 410 MW CCPP	Gas (NWPGCL)	1 x 278+1 x 132	410	410	0	0	0	0	410		Gas Shortage	
105	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	40				
106	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	60				
107	Khulna 225 MW CCPP	HSD Gas (NWPGCL)	1 x 150+1x75	230	230	0	0	0	0				
108	Russha 105 MW PP (Orion rupsha)	HFO (iPP)	6x18.445	105	105	5	17	53	53				
109	Madhumati 100 MW PP	HFO (NWPGCL)	6x18.415	105	105	0	32	15	32				
110	Mongla Orion 100 MW Solar PP	Solar (iPP)		100	100	85	0	100	0				
111	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	19	49	65				
112	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5'8.5	40	40	0	0	0	16				
113	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	336	407	570	570				
114	Khulna 330 MW CCPP (GT)	Gas/HSD (BPDB)	1x220+1x116	336	336	0	0	0	0				
**	Bheramara (HYDC)	India		1000	1000	901	775	902	902				
Khulna Zone Total						3241	3237	1327	1250	1689	1738	410	0
115	Barisal 110 MW PP (Summit)	HFO (iPP)	7 x 17.076	110	110	0	0	16	110				
116	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	20	22	21	25				
117	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	130	130	130	130				
118	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	600	960	1244	1244				
119	Potukhali 150MW PP (UPPL)	HFO (iPP)	8x18.415+1x9.78	150	150	0	16	38	150				
120	Barisal Electric 307 MW	Coal (iPP)	1x307	307	307	150	150	150	150				
121	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (iPP)	2x75+1x70	220	220	220	222	220	220				
Barishal Zone Total						2265	2265	1120	1500	1819	2029	0	0
122	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Under maint.	
123	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	0	30				
124	Baghabari 200 MW PP (Paramount)	HSD (iPP)	135x1.6	200	200	0	0	0	0				
125	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	16				
126	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	32	50	94				
127	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	39	30	40				
128	Katakali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	8	34	42				
129	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	38	24	35				
130	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGCL)	1x150+1x75	210	210	149	145	150	160	65		Gas Shortage	
131	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGCL)	1x150+1x75	220	220	0	0	0	0	220		Gas Shortage	
132	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGCL)	1x141+1x79	220	220	0	0	0	0	220		Gas Shortage	
133	Sirajgonj 400 MW CCPP Unit-4	Gas (iPP)	1x282+1x132	414	414	154	161	250	300	253		Gas Shortage	
134	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	0	11	11				
135	Natore 52 MW PP (Rajlanka)	HFO (iPP)	6x8.92	52	52	0	10	8	8				
136	Bagura 113 MW (Confidence) U-1	HFO (iPP)	6'18.55	113	113	35	55	35	57				
137	Bagura 113 MW PP (Confidence) U-2	HFO (iPP)	6x18.55	113	113	6	49	35	50				
138	Ammura 50 MW PPS(Sinha)	HFO (NENP)	7x7.79	50	28	0	0	28	28				
139	Sirajgonj 6.55 MW Solar	Solar (NWPGCL)	1x6	6	6	5	0	6	0				
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	1110	1217	1200	1200				
Rajshahi Zone Total						3653	3631	1470	1754	1861	2071	829	100
140	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Under Overhauling	
141	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	170	170	170	170				
142	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
143	Rangpur 113 MW PP (Confidence)	HFO (iPP)	7'16x2'3	113	113	0	110	42	113				
144	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
145	Majpara, Talsila 5 MW Solar PP (Sympa Power)	Solar (iPP)	1 x 8	8	8	6	0	8	0				
146	Thakurgaon 118MW PP (Energypac)	HFO (iPP)	6'20	115	115	0	85	70	115				
147	Lalmohanhat 30 MW Solar (Intraco)	Solar (iPP)	1'30	30	30	36	0	30	0				
148	Tweeta Solar Limited	Solar (iPP)	1 x 200	200	200	193	0	130	0				
Rangpur Zone Total						1030	950	405	365	450	398	85	85
Sub-total: Plants in operation						25059	24599	10823.0	11977	12644	14555	3345	1578
(B) Plants under long term maintenance/ contract expired													
149	Jamalpur 95 MW PP(Powerpac)	HFO (iPP)		12x8.924	95	0	0	0	0	0	0		
150	Bosila 108MW PP(CLC)	HFO (iPP)		12x8.775+1x3.5	108	0	0	0	0	0	0		
151	Bogra 22 MW PP (GBB)	Gas (RPP)		6x4.0	22	0	0	0	0	0	0		
152	Ashuganj 55 MW PP (Precision)	Gas (RPP)		15'4	55	0	0	0	0	0	0		
Sub-Total: Plants under long term maintenance/ contract expired						280	0	0	0	0	0	0	0
Gross Total						25339	24599	10823	11977	12644	14555	3345	1578
(C) Actual data of 30.10.23 (Yesterday) Monday :													
01.	Max. Demand at eve. peak (Generation end)	:	11977 MW, at =	18:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	11770 MW, at =	18:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW	
03.	Highest Generation (Generation end)	:	11977 MW, at =	18:00 hrs	Dhaka	4568	4568	0	Mymensingh	930	930	0	
04.	Minimum Generation (Generation end)	:	8476 MW, at =	6:00 hrs	Chattogram	1199	1199	0	Sylhet	450	450	0	
05.	Day-peak Generation (Generation end)	:	10823 MW, at =	12:00 hrs	Khulna	1351	1351	0	Barishal	327	327	0	
06.	Evening-peak Generation (Generation end)	:	11977 MW, at =	18:00 hrs	Rajshahi	1129	1129	0	Rangpur	761	761	0	
07.	Evening Peak Load-shed (Sub-station end)	:	0 MW, at =	18:00 hrs	Cumilla	1057	1057	0					
08.	Minimum Generation Forecast up to 8:00 hrs.	:	8643 MW, at =	5:00 hrs									
09.	Generation shortfall at evening peak due to :	:											
	a) Gas/LF limitation	:	3260 MW										
	d) Coal supply Limitation	:	85 MW										
	b) Low water level in Kaptai lake	:	0 MW										
	c) Plants under shut down/ maintenance	:	1578 MW										
10.	Total Energy (Generation + India Import)	:	249.65 MKWh										
	By Gas =	122.612 MKWh	By Oil =	19.215 MKWh									
	By Coal =	75.735 MKWh	By Hydro =	4.516 MKWh									
	By Solar =	2.803 MKWh											
11.	Total Gas Supplied	:	920.49 MMCFD										
(D) Forecast of 31.10.23 (Today) Tuesday :													
01.	Maximum Demand	:	12000 MW (Generation end)		04.	Maximum Load-shed	:	0 MW At evening peak (Sub-station end)					
02.	Maximum Generation	:	14555 MW (Generation end)		05.	Total Generation	:	250.13 MKWh					
03.	Reserve / Shortage	:	2555 MW (Generation end)		06.	Probable Max. Temperature in Dhaka :	:	32.5°C					

* Captive Power ** Imported Power

#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation