

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9546667, 9551095

Month November, 2023					Day: Wednesday					Date: 01.11.23				
Probable Maximum Demand : 12700 MW					Probable Maximum Generation : 14901 MW					Rule Curve = 109.00 ft.				
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 102.39 ft					Today = 102.15 ft.				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	31.10.23 (Yesterday)		01.11.23 (Today)		31.10.23 (Yesterday)		01.11.23 (Today)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for (		Machines shut down (MW)			
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW					
(A) Plants in operation:														
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work		
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	130	220	180	180					
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190		Gas Shortage		
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0					
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108		Gas Shortage		
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage		
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0					
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	302	255	330	330					
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225	225		Gas Shortage		
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling		
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	408	399	400	412					
11	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage		
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	8	238	288	335					
13	Meghnaghat 335MW CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	110	72	150	150	263		Gas Shortage		
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	25	15	15					
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	8	8	8	8					
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	15	0	16	16					
17	Summit Power,Madhabadi+Ashulia	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	30	31	31	31					
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33					
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	16	30	33	33					
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	25	8	25					
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	35	88	35	88					
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	16	132	16	132					
23	Kamalaghat 54 MW PP (Barco Energy)	HFO (IPP)	3x18.69	54	54	0	17	0	17					
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	82	132	80	130					
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	17	99	17	135					
26	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	17	0	55					
27	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	35	0	35					
28	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	0	10	0	17					
29	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	17	35	17	35					
30	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	30	0	35	0					
31	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	17	17	17					
32	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	9	9	8	8					
33	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	2	9	8	8					
34	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	80	95	100	100					
35	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	15	40	10	45					
36	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0					
	Meghnaghat Unique Power	Gas				60	0	100	100					
	Meghnaghat 589 MW CCPP(Summit)	Gas				0	0	0	0					
Dhaka Zone Total				5655	5422	1680	2296	2160	2715	1101	375			
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	162	160	162	162					
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage		
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.		
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0					
40	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	17	8	17					
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	17	0	20	0					
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	19	6	19					
43	Sikalbaha 105 MW PP (Baraka Sikabaha)	HFO (IPP)	6x18.415	105	105	17	17	17	17					
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.		
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	189	179	210	215					
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.94	300	300	87	213	65	245					
47	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	12	12	12	12					
48	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	17	34	17	34					
49	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	50	82	50	82					
50	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	10	12	12	12					
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			0	0	7	10					
51	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0					
52	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	17					
53	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	17	17	17					
54	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	12	12	12	12					
55	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	12	12	12	12					
56	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	17	34	17	34					
57	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	0	162	35	163					
58	SS Power Unit-1	Coal (IPP)	1x612	612	612	326	494	600	600					
	Matarbari 2*600 MW (CPGCL)	Coal				258	263	300	300			Test run		
	Cox's Bazar Wind PP	(Wind) (IPP)				0	4	10	10			Test run		
Chattogram Zone Total				3217	3157	1238	1760	1611	1990	180	330			
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	0	0	0	0	45		Gas Shortage		
60	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	161	192	190	200					
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	240	240	150	275	120		Gas Shortage		
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	315	280	300	300	80		Gas Shortage		
63	Ashuganj 420 MW CCPP(East)	Gas (APSCCL)	1x284+1x116	400	400	240	240	300	240	160		Gas Shortage		
64	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*16	195	195	0	0	0	0	195		Gas Shortage		
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51					
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	87	119	150	150					
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	0					
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0		163	Under maint.		
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	17	17	17					
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	18	18	18					
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	8	11	11					
72	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	17	33	33	33					
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	52	52	52	52					
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	12	12	12	12					
75	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	17	114	114					
76	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	37	88	28	88					
77	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	34	17	17	35					
78	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	18	95	17	94					
**	Impootti (Tripura)	India		160	160	136	102	143	166					
Cumilla Zone Total				2904	2896	1460	1581	1603	1856	600	163			
79	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	33	59	60	60	143		Gas Shortage		
80	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	16	19					
81	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	89	90	40	90					
82	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	28	93	66	100					
83	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	16	0					
84	Sutakhalai 50 MW Solar PP	Solar (IPP)	1x50	50	50	51	0	50	0					
85	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	6	6	6	6					
Mymensingh Zone Total				622	614	228	267	240	275	143	0			

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	31.10.23 (Yesterday)		01.11.23 (Today)		31.10.23 (Yesterday)		Status of Machines under shut-down/ Maintenance				
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date			
						Day	Evening	Day	Evening	Gas/Coal/Oil/Water Limitation MW	Machines shut down (MW)					
86	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	0	0	0	0		70	GT-1 Under maint.				
87	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	36	37	40	40		53	GT-4 Under maint.				
88	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	0	0	0	0							
89	Kushlari 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	163	163	163							
90	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	2	2	2	2							
91	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	54	54	62	62		330	Under maint.				
92	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0							
93	Shahjibazar 68MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	0	0	0	0							
94	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	203	196	200	200							
95	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	16	17	17	17							
96	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10							
97	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16							
98	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	320	295	290	300							
99	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	405	402	400	400							
100	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	300	300	300	310							
101	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work				
102	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12'3.3+5'2	50	50	46	45	42	42							
Sylhet Zone Total						2472	2427	1571	1537	1542	1562	0	553			
103	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0							
104	Bheramara 410 MW CCPP	Gas (NWPGCL)	1 x 278+1 x 132	410	410	0	0	0	0		410	Gas Shortage				
105	Fairpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	25	0	25							
106	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	50							
107	Khulna 225 MW CCPP	HSD Gas (NWPGCL)	1 x 150+1x75	230	230	0	0	0	0							
108	Ruoshu 105 MW PP (Orion rupsha)	HFO (iPP)	6x18.445	105	105	0	30	53	53							
109	Madhumati 100 MW PP	HFO (NWPGCL)	6x18.415	105	105	0	32	15	32							
110	Mongla Orion 100 MW Solar PP	Solar (iPP)		100	100	84	0	100	0							
111	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	0	49	83							
112	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5'8.5	40	40	0	8	0	16							
113	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	450	501	780	800							
114	Khulna 330 MW CCPP (GT)	Gas/HSD (BPDB)	1x220+1x116	336	336	0	0	0	0							
**	Bheramara (HVCDC) India			1000	1000	902	767	902	902							
Khulna Zone Total						3241	3237	1436	1363	1899	1961	410	0			
115	Barisal 110 MW PP (Summit)	HFO (iPP)	7 x 17.076	110	110	0	28	16	110							
116	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	17	23	21	25							
117	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	130	122	130	130							
118	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	960	1244	1244	1244							
119	Potukhali 150MW PP (UPPL)	HFO (iPP)	8x18.415+1x9.78	150	150	0	82	38	150							
120	Barisal Electric 307 MW	Coal (iPP)	1x307	307	307	150	150	150	150							
121	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (iPP)	2x75+1x70	220	220	220	220	220	220							
Barishal Zone Total						2265	2265	1477	1869	1819	2029	0	0			
122	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage				
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.				
123	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	25	0	30							
124	Baghabari 200 MW PP (Paramount)	HSD (iPP)	135x1.6	200	200	0	0	0	0							
125	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	10	0	16							
126	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	94	50	94							
127	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	39	30	40							
128	Katakali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	8	34	42							
129	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	24	35							
130	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGCL)	1x150+1x75	210	210	157	155	150	160		55	Gas Shortage				
131	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGCL)	1x150+1x75	220	220	0	0	0	0		220	Gas Shortage				
132	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGCL)	1x141+1x79	220	220	0	0	0	0		220	Gas Shortage				
133	Sirajgonj 400 MW CCPP Unit-4	Gas (iPP)	1x282+1x132	414	414	202	265	250	300		149	Gas Shortage				
134	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11							
135	Natore 52 MW PP (Rajlanka)	HFO (iPP)	6x8.92	52	52	0	52	52	52							
136	Bagura 113 MW (Confidence) U-1	HFO (iPP)	6'18.55	113	113	35	55	35	57							
137	Bagura 113 MW PP (Confidence) U-2	HFO (iPP)	6x18.55	113	113	6	50	35	50							
138	Ammura 50 MW PPS(Sinha)	HFO (NENP)	7x7.79	50	28	0	0	28	28							
139	Sirajgonj 6.55 MW Solar	Solar (NWPGCL)	1x6	6	6	5	0	6	0							
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	1167	599	1200	1200							
Rajshahi Zone Total						3653	3631	1583	1395	1905	2115	715	100			
140	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Coal Shortage				
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0			85	Under Overhauling			
141	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	170	170	170	170							
142	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0							
143	Rangpur 113 MW PP (Confidence)	HFO (iPP)	7'16x 2'3	113	113	0	113	42	113							
144	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0							
145	Majpara, Talsila 5 MW Solar PP (Sympa Power)	Solar (iPP)	1 x 8	8	8	7	0	8	0							
146	Thakurgaon 118MW PP (Energypac)	HFO (iPP)	6'20	115	115	0	115	70	115							
147	Lalmoharhat 30 MW Solar (Intraco)	Solar (iPP)	1'30	30	30	36	0	30	0							
148	Tweeta Solar Limited	Solar (iPP)	1 x 200	200	200	192	0	130	0							
Rangpur Zone Total						1030	950	405	398	450	398	85	85			
Sub-total: Plants in operation						25059	24599	11078.0	12466	13229	14901	3234	1606			
(B) Plants under long term maintenance/ contract expired																
149	Jamalpur 95 MW PP(Powerpac)	HFO (iPP)	12x8.924	95	0	0	0	0	0							
150	Bosila 108MW PP(CLC)	HFO (iPP)	12x8.775+1x3.5	108	0	0	0	0	0							
151	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	0	0	0	0	0							
152	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	0	0	0	0	0							
Sub-Total: Plants under long term maintenance/ contract expired						280	0	0	0	0	0	0	0			
Gross Total						25339	24599	11078	12466	13229	14901	3234	1606			
(C) Actual data of 31.10.23 (Yesterday) Tuesday :																
01.	Max. Demand at eve. peak (Generation end)	:	12466	MW, at = 19:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :											
02.	Max. Demand at eve. peak (Sub-station end)	:	11987	MW, at = 19:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW				
03.	Highest Generation (Generation end)	:	12466	MW, at = 19:00 hrs	Dhaka	4483	4483	0	Mymensingh	989	989	0				
04.	Minimum Generation (Generation end)	:	8643	MW, at = 6:00 hrs	Chattogram	1352	1352	0	Sylhet	510	510	0				
05.	Day-peak Generation (Generation end)	:	11078	MW, at = 12:00 hrs	Khulna	1352	1352	0	Barisal	331	331	0				
06.	Evening-peak Generation (Generation end)	:	12466	MW, at = 19:00 hrs	Rajshahi	1125	1125	0	Rangpur	695	695	0				
07.	Evening Peak Load-shed (Sub-station end)	:	0	MW, at = 19:00 hrs	Cumilla	1151	1151	0								
08.	Minimum Generation Forecast up to 8:00 hrs.	:	8872	MW, at = 5:00 hrs												
09.	Generation shortfall at evening peak due to :	:			Total				11987	11987	0					
	a) Gas/LF limitation	:	3149	MW	13. Fuel cost :				(a) Gas = 122100350 Taka	(c) Coal = 558803470 Taka						
	d) Coal supply Limitation	:	85	MW	(b) Oil = 331611320 Taka				Total = 1012515141 Taka							
	b) Low water level in Kaptai lake	:	0	MW	14. Maximum Temperature in Dhaka was : 34.6°C											
	c) Plants under shut down/ maintenance	:	1606	MW	15. Export through East-West interconnections :											
10.	Total Energy (Generation + India Import)	:	255.72	MKWh	At evening peak-hour :				11078	MW, at 19:00 hrs						
	By Gas = 120.139 MKWh			By Oil = 25.297 MKWh	Maximum :				770	MW, at 18:00 hrs						
	By Coal = 79.436 MKWh			By Hydro = 3.983 MKWh	Energy :				0	MKWh						
	By Solar = 2.774 MKWh															
11.	Total Gas Supplied	:	944.40	MMCFD												
(D) Forecast of 01.11.23 (Today) Wednesday :																
01.	Maximum Demand	:	12700	MW (Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)						
02.	Maximum Generation	:	14901	MW (Generation end)	05.	Total Generation	:	260.52	MKWh							
03.	Reserve / Shortage	:	2201	MW (Generation end)	06.	Probable Max. Temperature in Dhaka :	34.6°C									

* Captive Power ** Imported Power
#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00