

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 3564667, 3551095

Month November, 2023				Day : Thursday				Date : 02.11.23				
Probable Maximum Demand : 12700 MW				Probable Maximum Generation : 15045 MW								
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 102.15 ft		Today = 101.91 ft		Rule Curve = 108.90 ft				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	01.11.23 (Yesterday)		02.11.23 (Today)		01.11.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/Water Limitation MW	Machines shut down (MW)		
					Day	Evening	Day	Evening				
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	180	170	180	180			
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190	Gas Shortage	
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0			
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	40	14	40	68	Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage	
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0			
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	242	235	250	250			
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	160	160	225	225	290	Gas Shortage	
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	401	404	400	412			
11	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage	
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	233	227	250	250			
13	Meghnaghat 335MW CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	93	80	100	100	255	Gas Shortage	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	31	15	15			
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	8	8	8	8			
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	16	15	16	16			
17	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	30	30	31	31			
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33			
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	30	33	33	33			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	4	8	8	25			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	35	70	35	88			
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	16	98	16	132			
23	Kamalaghat 54 MW PP (Barco Energy)	HFO (IPP)	3x18.69	54	54	0	17	0	17			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	82	125	80	130			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	17	135	17	135			
26	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	17	0	55			
27	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	35	0	35			
28	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	0	7	0	17			
29	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	17	35	17	35			
30	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	32	0	35	0			
31	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	17	17	17			
32	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	9	9	8	8			
33	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	9	8	8	8			
34	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	90	95	100	100			
35	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	40	32	10	45			
36	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			
	Meghnaghat Unique Power	Gas			0	0	0	100	100			
	Meghnaghat 589 MW CCPP(Summit)	Gas			0	0	0	0	0			
Dhaka Zone Total				5655	5422	1809	2174	2006	2540	1118	375	
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	161	205	205	205			
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0			
40	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	7	17	8	17			
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	19	0	20	0			
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	19	6	19			
43	Sikalbaha 105 MW PP (Baraka Sikabaha)	HFO (IPP)	6x18.415	105	105	17	17	17	17			
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	189	186	160	160			
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.94	300	300	69	227	65	245			
47	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	12	12	12	12			
48	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	15	17	17	34			
49	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	57	82	50	82			
50	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	12	12	12	12			
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			2	3	7	10			
51	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0			
52	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	17			
53	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	17	17	17			
54	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	12	12	12	12			
55	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	12	12	12	12			
56	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	17	34	17	34			
57	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	34	163	35	163			
58	SS Power Unit-1	Coal (IPP)	1x612	612	612	326	340	400	600			
	Matlabari 2*600 MW (CPGCL)	Coal				258	550	300	550		Test run	
	Cox's Bazar Wind PP	(Wind) (IPP)				0	0	10	10		Test run	
Chattogram Zone Total				3217	3157	1263	1942	1404	2228	180	330	
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	0	0	0	0	45	Gas Shortage	
60	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	204	206	190	200			
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	100	55	300	300	305	Gas Shortage	
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	340	280	280	300	80	Gas Shortage	
63	Ashuganj 420 MW CCPP(East)	Gas (APSCCL)	1x284+1x116	400	400	355	240	250	250	160	Gas Shortage	
64	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*16	195	195	0	0	0	0	195	Gas Shortage	
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	0	0	0	51			
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	11	94	150	150			
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	0			
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163	Under maint.	
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	20	17	17	17			
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	16	15	18	18			
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	8	11	11			
72	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	0	25	33	33			
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	52	52	52			
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	12	12	12	12			
75	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	88	97	114	114			
76	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	19	49	28	88			
77	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	35			
78	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	18	76	17	94			
**	Impoort (Tripura)	India		160	160	140	136	143	166			
Cumilla Zone Total				2904	2896	1356	1379	1632	1891	785	163	
79	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	60	97	72	97	105	Gas Shortage	
80	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	18	18	18			
81	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	66	85	40	90			
82	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	46	98	66	100			
83	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
84	Sutiakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	51	0	50	0			
85	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	4	6	6	6			
Mymensingh Zone Total				622	614	248	304	254	311	105	0	

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	01.11.23 (Yesterday)		02.11.23 (Today)		01.11.23 (Yesterday)		Status of Machines under shut-down/ Maintenance					
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date				
					Day	Evening	Day	Evening	Gas/Coal/Oil/Water Limitation MW	Machines shut down (MW)						
86	Fenchuganj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	0	0	0	0	70	GT-1 Under maint.					
87	Fenchuganj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	36	36	40	40	54	GT-4 Under maint.					
88	Fenchuganj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	0	0	0	0							
89	Kushnara 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	163	163	163							
90	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	3	2	2							
91	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	54	56	62	62	330	Under maint.					
92	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0							
93	Shahjibazar 68MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	0	0	0	0							
94	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	199	197	200	200							
95	Sylhet 20 MW GTTP	Gas (PDB)	1x20	20	20	0	17	17	17							
96	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10							
97	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	0	8	16	16							
98	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	320	260	290	300							
99	Bibiana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	380	404	400	400							
100	Bibiana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	0	0	300	310							
101	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0	100	Under project work					
102	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12'3.3+5'2	50	50	46	48	42	42							
Sylhet Zone Total					2472	2427	1213	1202	1542	1562	0	554				
103	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0							
104	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0	410	Gas Shortage					
105	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	25							
106	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	60	0	60							
107	Khulna 225 MW CAPP	HSD Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0							
108	Ruoshah 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	17	53	53							
109	Machumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	15	32							
110	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	81	0	100	0							
111	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	0	49	83							
112	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5'8.5	40	40	0	8	0	16							
113	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	792	791	780	800							
114	Khulna 330 MW CAPP (GT)	Gas/HSD (BPDB)	1x220+1x116	336	336	0	0	0	0							
**	Bheramara (HVCDC) India			1000	1000	906	783	902	902							
Khulna Zone Total					3241	3237	1779	1659	1899	1971	410	0				
115	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	16	110							
116	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	17	25	21	25							
117	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	122	130	130	130							
118	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	780	1120	1244	1244							
119	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	38	150							
120	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	150	150	150	150							
121	Bhola 220MW CAPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	220	220	220							
Barishal Zone Total					2265	2265	1289	1645	1819	2029	0	0				
122	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71	Gas Shortage					
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100	Under maint.					
123	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	0	30							
124	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0							
125	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	16							
126	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	92	50	94							
127	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	30	40							
128	Katakhal 50 MW PP (Northern)	HFO (ORPP)	6x8.9	50	50	0	8	34	42							
129	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	38	24	35							
130	Sirajganj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	158	151	150	160	59	Gas Shortage					
131	Sirajganj 225MW CAPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	0	0	0	0	220	Gas Shortage					
132	Sirajganj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0	220	Gas Shortage					
133	Sirajganj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	303	203	300	300	211	Gas Shortage					
134	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	0	11	11	11							
135	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	8	52	52							
136	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6'18.55	113	113	0	55	35	57							
137	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	50	35	50							
138	Ammura 50 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	0	28	28	28							
139	Sirajganj 6.55 MW Solar	Solar (NWPGL)	1x6	6	5	0	6	0	0							
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	1078	1217	1200	1200							
Rajshahi Zone Total					3653	3631	1544	1861	1955	2115	781	100				
140	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Coal Shortage					
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Under Overhauling					
141	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	170	170	170	170							
142	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0							
143	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	17	113	42	113							
144	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0							
145	Majpara, Talsila 5 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	6	0	8	0							
146	Thakurgaon 118MW PP (Energypac)	HFO (IPP)	6'20	115	115	36	75	70	115							
147	Lalmohanhat 30 MW Solar (Intraco)	Solar (IPP)	1'30	30	30	37	0	30	0							
148	Tweeta Solar Limited	Solar (IPP)	1 x 200	200	196	0	130	0	130							
Rangpur Zone Total					1030	950	462	358	450	398	85	85				
Sub-total: Plants in operation					25059	24599	10963.0	12524	12961	15045	3464	1607				
(B) Plants under long term maintenance/ contract expired																
149	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0							
150	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0							
151	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	0	0	0	0	0							
152	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	0	0	0	0	0							
Sub-Total: Plants under long term maintenance/ contract expired					280	0	0	0	0	0	0	0				
Gross Total					25339	24599	10963	12524	12961	15045	3464	1607				
(C) Actual data of 01.11.23 (Yesterday) Wednesday :																
01.	Max. Demand at eve. peak (Generation end)	:	12570 MW, at =	19:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :											
02.	Max. Demand at eve. peak (Sub-station end)	:	12243 MW, at =	19:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW				
03.	Highest Generation (Generation end)	:	12524 MW, at =	19:00 hrs	Dhaka	4657	4657	0	Mymensingh	1006	996	10				
04.	Minimum Generation (Generation end)	:	8872 MW, at =	6:00 hrs	Chattogram	1285	1285	0	Sylhet	517	499	18				
05.	Day-peak Generation (Generation end)	:	10963 MW, at =	12:00 hrs	Khulna	1372	1372	0	Barishal	368	368	0				
06.	Evening-peak Generation (Generation end)	:	12524 MW, at =	19:00 hrs	Rajshahi	1150	1150	0	Rangpur	679	679	0				
07.	Evening Peak Load-shed (Sub-station end)	:	44 MW, at =	19:00 hrs	Cumilla	1209	1193	16								
08.	Minimum Generation Forecast up to 8:00 hrs.	:	9243 MW, at =	5:00 hrs	Total				12243	12199	44					
09.	Generation shortfall at evening peak due to :	:			13. Fuel cost :				(a) Gas = 117282497 Taka							
	a) Gas/LF limitation	:	3379 MW						(c) Coal = 631887867 Taka							
	d) Coal supply Limitation	:	85 MW						(b) Oil = 320509771 Taka							
	b) Low water level in Kaptai lake	:	0 MW						Total = 1069680134 Taka							
	c) Plants under shut down/ maintenance	:	1607 MW		14. Maximum Temperature in Dhaka was :				34.3°C							
10.	Total Energy (Generation + India Import)	:	260.32 MKWh		15. Export through East-West interconnections :											
	By Gas =	115.513 MKWh	By Oil =	24.998 MKWh	At evening peak-hour				: 10963 MW, at 19:00 hrs							
	By Coal =	88.066 MKWh	By Hydro =	4.272 MKWh	Maximum				: 770 MW, at 18:00 hrs							
	By Solar =	2.886 MKWh			Energy				: 0 MKWh							
11.	Total Gas Supplied	:	891.43 MMCFD		06. Probable Max. Temperature in Dhaka :											
(D) Forecast of 02.11.23 (Today) Thursday :																
01.	Maximum Demand	:	12700 MW (Generation end)		04.	Maximum Load-shed	:	0 MW	At evening peak (Sub-station end)							
02.	Maximum Generation	:	15045 MW (Generation end)		05.	Total Generation	:	263.98 MKWh								
03.	Reserve / Shortage	:	2345 MW (Generation end)		06.	Probable Max. Temperature in Dhaka :	:	34.3°C								