

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 3564667, 3551095

Month November, 2023					Day : Sunday					Date : 05.11.23				
Probable Maximum Demand : 12800 MW					Probable Maximum Generation : 13604 MW									
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 101.60 ft					Today = 101.41 ft				
					Rule Curve = 108.70 ft									
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	04.11.23 (Yesterday)		05.11.23 (Today)		04.11.23 (Yesterday)		05.11.23 (Today)			
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Status of Machines under shut-down/ Maintenance			
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date		
(A) Plants in operation:														
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work		
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	165	220	180	180					
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190		Gas Shortage		
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0					
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	35	41	75	75	67		Gas Shortage		
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage		
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0					
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	234	212	250	250					
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225	225		Gas Shortage		
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling		
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	405	378	400	412					
11	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage		
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	170	164	170	170					
13	Meghnaghat 335MW CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	71	55	100	100	280		Gas Shortage		
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	15	15	30					
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	24	41	25	64					
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	15	17	18	18					
17	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	26	31	31	31					
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	33	33	33					
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	8	8	33	33					
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	25	8	25					
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	35	55	35	70					
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	16	132	16	130					
23	Kamalghat 54 MW PP (Barco Energy)	HFO (IPP)	3x18.69	54	54	0	17	0	17					
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	77	110	80	130					
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	22	62	17	135					
26	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	35	0	55					
27	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	35	0	35					
28	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	17	17	17					
29	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	17	35	17	35					
30	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	28	0	35	0					
31	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	17	17	34					
32	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	33	43	24	50					
33	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	43	51	50	50					
34	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	70	96	100	100					
35	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	31	36	10	45					
36	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0					
	Meghnaghat Unique Power	Gas				84	96	100	100					
	Meghnaghat 589 MW CCPP(Summit)	Gas				0	0	0	0					
Dhaka Zone Total			5655	5422	1916	2302	2081	2649	1077	375				
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	125	127	159	159					
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	80	100	100	100	80		Gas Shortage		
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.		
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0					
40	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	14	8	17					
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	19	0	20	0					
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	19	6	19					
43	Sikalbaha 105 MW PP (Baraka Sikabaha)	HFO (IPP)	6x18.415	105	105	17	17	17	17					
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.		
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0		225	Under maint.		
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.94	300	300	88	223	65	230					
47	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	12	12	12	12					
48	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	17	17	17	17					
49	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	56	40	60					
50	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	12	12	12	12					
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			0	10	10	25					
51	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0					
52	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	17					
53	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	17	17	17					
54	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	12	12	12	12					
55	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	12	12	12	12					
56	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	17	18	17	17					
57	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	0	0	35	163					
58	SS Power Unit-1	Coal (IPP)	1x612	612	612	325	300	600	600					
	Matarbari 2*600 MW (CPGCL)	Coal				345	342	200	350			Test run		
	Cox's Bazar Wind PP	(Wind) (IPP)				5	7	10	10			Test run		
Chattogram Zone Total			3217	3157	1138	1332	1391	1866	80	555				
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	50	51	50	50					
60	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	207	208	210	210					
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	335	310	310	310	50		Gas Shortage		
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	345	310	280	280	50		Gas Shortage		
63	Ashuganj 420 MW CCPP(East)	Gas (APSCCL)	1x284+1x116	400	400	0	0	0	0	400		Gas Shortage		
64	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*116	195	195	8	73	16	16	122		Gas Shortage		
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51					
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	120	150	150					
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	0					
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0		163	Under maint.		
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	19	17	17	17					
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	15	18	17	17					
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	10	11	11					
72	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	25	33	33	33					
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	29	25	52	52					
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	12	12	12	12					
75	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	63	114	114	114					
76	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	28	77	28	78					
77	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17					
78	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	18	45	17	72					
**	Import (Tripura)	India		160	160	112	158	143	166					
Cumilla Zone Total			2904	2896	1342	1649	1528	1656	622	163				
79	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	95	71	45	70	131		Gas Shortage		
80	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	16	16	18	18					
81	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	28	85	40	75					
82	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	84	98	66	100					
83	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0					
84	Sutiakehi 50 MW Solar PP	Solar (IPP)	1x50	50	50	16	0	50	0					
85	Tangail 22 MW PP(PPLGL)	HFO (IPP)	4x6.7	22	22	4	6	6	6					
Mymensingh Zone Total			622	614	244	276	227	269	131	0				

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	04.11.23 (Yesterday)		05.11.23 (Today)		04.11.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)		
86	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	0	0	0	0	70	GT-1 Under maint.	
87	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	36	36	36	36	54	GT-4 Under maint.	
88	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	0	0	0	0			
89	Kushara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0			
90	Hobiganj 11MW PP Confidence-E	Gas (SI/PP, REB)	4x2.90	11	11	0	0	0	2	2		
91	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	57	56	60	60			
92	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0	330	Under maint.	
93	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	0	0	0	0			
94	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	200	204	205	205			
95	Sylhet 20 MW GTTP	Gas (PDB)	1x20	20	20	16	17	17	17			
96	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10			
97	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	8	16	16			
98	Bibiyan-I 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	310	290	290	300			
99	Bibiyan-II 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	402	403	400	400			
100	Bibiyan South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	260	260	260	260			
101	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0	100	Under project work	
102	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	46	48	48	48			
Sylhet Zone Total					2472	2427	1345	1332	1344	1354	0	554
103	Bheramara GTTP Unit-3	HSD (PDB)	1 x 20	20	16	0	0	0	0			
104	Bheramara 410 MW CCPP	Gas (NWP/CGCL)	1 x 278+1 x 132	410	410	0	0	0	0	410	Gas Shortage	
105	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	30	0	25			
106	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	25	0	60			
107	Khulna 225 MW CCPP	HSD Gas (NWP/CGCL)	1 x 150+1x75	230	230	0	0	0	0			
108	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	8x18.445	105	105	13	48	53	72			
109	Machumati 100 MW PP	HFO (NWP/CGCL)	6x18.415	105	105	0	50	15	32			
110	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	71	0	100	0			
111	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	48	40	66			
112	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	0	0	8			
113	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	369	577	0	0			
114	Khulna 330 MW CCPP (GT)	Gas/HSD (BPDB)	1x220+1x116	336	336	0	0	0	0			
**	Bheramara (HVDCL) India			1000	1000	897	602	902	902			
Khulna Zone Total					3241	3237	1350	1380	1110	1165	410	0
115	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	16	16	110			
116	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	17	23	21	25			
117	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	130	130	130	130			
118	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	790	1110	1244	1244			
119	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	35	38	150			
120	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	140	140	140	140			
121	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	220	220	220			
Barishal Zone Total					2265	2265	1297	1674	1809	2019	0	0
122	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71	Gas Shortage	
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100	Under maint.	
123	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	0	30			
124	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0			
125	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	16			
126	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	81	50	94			
127	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	38	30	40			
128	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	25	34	42			
129	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	38	24	38			
130	Sirajgonj 225MW CCPP Unit-1	Gas (NWP/CGCL)	1x150+1x75	210	210	146	0	0	0	210	Gas Shortage	
131	Sirajgonj 225MW CCPP Unit-2	Gas (NWP/CGCL)	1x150+1x75	220	220	0	0	0	0	220	Gas Shortage	
132	Sirajgonj 225MW CCPP Unit-3	Gas (NWP/CGCL)	1x141+1x79	220	220	0	0	0	0	220	Gas Shortage	
133	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	143	246	414	414	168	Gas Shortage	
134	Ullapara 11 MW PP (Summit)	Gas (SI/PP, REB)	4x2.90	11	11	11	11	11	11			
135	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	35	52	52			
136	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	95	113	113			
137	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	50	35	50			
138	Ammura 50 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	0	0	28	28			
139	Sirajgonj 6.55 MW Solar	Solar (NWP/CGCL)	1x6	6	4	0	0	6	0			
**	Adani Power Jharkhand Ltd	(Import)	2x748	1496	1496	1011	1319	1200	1300			
Rajshahi Zone Total					3653	3631	1315	1938	1997	2228	889	100
140	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Under Overhauling	
141	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	170	170	170	170			
142	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
143	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	0	105	34	113			
144	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
145	Majpara Talsila 1 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	6	0	0	8	0			
146	Thakurgaon 119MW PP (Energyrac)	HFO (IPP)	6*20	119	8	115	0	89	70	115		
147	Lalmoinhat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	31	0	30	0			
148	Treaste Solar Limited	Solar (IPP)	1 x 200	200	200	148	0	130	0			
Rangpur Zone Total					1030	950	355	364	442	398	85	85
Sub-total: Plants in operation					25059	24599	10302.0	12247	11929	13604	3294	1832
(B) Plants under long term maintenance/ contract expired												
149	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			
150	Bosilla 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			
151	Boogra 22 MW PP (GGB)	Gas (RPP)	6x4.0	22	0	0	0	0	0			
152	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	0	0	0	0	0			
Sub-Total: Plants under long term maintenance/ contract expired					280	0	0	0	0	0	0	0
Gross Total					25339	24599	10302	12247	11929	13604	3294	1832
(C) Actual data of 04.11.23 (Yesterday) Saturday :												
01.	Max. Demand at eve. peak (Generation end)	:	12270 MW, at =	18:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	11910 MW, at =	18:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	12247 MW, at =	18:00 hrs	Dhaka	4574	4574	0	Mymensingh	972	972	0
04.	Minimum Generation (Generation end)	:	8659 MW, at =	6:00 hrs	Chattogram	1195	1195	0	Sylhet	474	464	10
05.	Day-peak Generation (Generation end)	:	10302 MW, at =	12:00 hrs	Khulna	1340	1340	0	Barishal	360	360	0
06.	Evening-peak Generation (Generation end)	:	12247 MW, at =	18:00 hrs	Rajshahi	1130	1130	0	Rangpur	715	715	0
07.	Evening Peak Load-shed (Sub-station end)	:	22 MW, at =	18:00 hrs	Cumilla	1151	1139	12				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	8894 MW, at =	5:00 hrs					Total	11910	11888	22
09.	Generation shortfall at evening peak due to :	:			13.	Fuel cost :	(a) Gas = 126874541 Taka (b) Oil = 342080996 Taka		(c) Coal = 583456292 Taka Total = 1052411829 Taka			
	a) Gas/LF limitation	:	3209 MW		14.	Maximum Temperature in Dhaka was :	32.5°C					
	d) Coal supply Limitation	:	85 MW		15.	Export through East-West interconnections :						
	b) Low water level in Kaptai lake	:	0 MW			At evening peak-hour	:	10302 MW, at	18:00 hrs			
	c) Plants under shut down/ maintenance	:	1832 MW			Maximum	:	1180 MW, at	7:00 hrs			
	10. Total Energy (Generation + India Import)	:	249.24 MKWh			Energy	:	0 MKWh				
	By Gas = 114.547 MKWh			By Oil = 25.882 MKWh								
	By Coal = 81.206 MKWh			By Hydro = 3.196 MKWh								
	By Solar = 2.118 MKWh											
11.	Total Gas Supplied	:	901.49 MMCFD									
(D) Forecast of 05.11.23 (Today) Sunday :												
01.	Maximum Demand	:	12800 MW (Generation end)		04.	Maximum Load-shed	:	0 MW At evening peak (Sub-station end)				
02.	Maximum Generation	:	13604 MW (Generation end)		05.	Total Generation	:	260.50 MKWh				
03.	Reserve / Shortage	:	804 MW (Generation end)		06.	Probable Max. Temperature in Dhaka :	32.5°C					

* Captive Power ** Imported Power
#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation