

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month November, 2023				Day : Thursday				Date : 09.11.23				
Probable Maximum Demand : 11500 MW				Probable Maximum Generation : 12382 MW								
Water Level of Kapitai Lake at 06:00 AM				Yesterday = 100.69 ft		Today = 100.45 ft		Rule Curve = 108.20 ft				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	08.11.23 (Yesterday)		09.11.23 (Today)		08.11.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)		Description/ Remarks
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	120	120	120	120			
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190		Gas Shortage
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0			
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	75	80	80	80			
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0			
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	182	167	200	200	193		Gas Shortage
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225	225		Gas Shortage
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	337	323	320	330	89		Gas Shortage
11	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	242	250	260	260	85		Gas Shortage
13	Meghnaghat 335MW CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	135	134	140	140	201		Gas Shortage
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	15	15	15			
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	8	8	8	8			
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	18	18	18	18			
17	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	31	31	31	31			
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	33	33	33			
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	24	24	25	25			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	25	8	25			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	35	105	35	105			
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	16	132	16	132			
23	Kamalghat 54 MW PP (Barco Energy)	HFO (IPP)	3x18.69	54	54	0	17	0	17			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	82	105	80	130			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	17	47	17	80			
26	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	17	0	50			
27	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	17	0	17			
28	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	0	17	17			
29	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	17	35	17	35			
30	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	29	0	35	0			
31	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	35	17	34			
32	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	9	22	17	25			
33	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	8	8	8	9			
34	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	33	80	95	95			
35	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	25	47	50	50			
36	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			
	Meghnaghat Unique Power	Gas			0	0	0	0	0			
	Meghnaghat 589 MW CCPP(Summit)	Gas			0	0	0	0	0			
Dhaka Zone Total				5655	5422	1750	2120	1887	2306	1298	375	
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	125	126	124	126			
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	70	0	0	0	180		Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0			
40	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	15	8	17			
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	19	0	20	0			
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	17	6	17			
43	Sikalbaha 105 MW PP (Baraka Sikabaha)	HFO (IPP)	6x18.415	105	105	17	17	17	17			
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150		Under maint.
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	93	140	140	132		Under maint.
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.94	300	300	66	235	90	230			
47	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	12	12	12	12			
48	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	0	0	0			
49	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	2	17	8	17			
50	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	11	12	12	12			
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			2	2	10	10			
51	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0			
52	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	17			
53	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	17	17	17			
54	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	12	12	12	12			
55	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	12	12	12	12			
56	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	18	34	17	34			
57	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	17	23	35	163			
58	SS Power Unit-1	Coal (IPP)	1x612	612	612	0	0	0	0			
	Matarbari 2*600 MW (CPGCL)	Coal				194	344	350	350			Test run
	Cox's Bazar Wind PP	(Wind) (IPP)				6	6	10	10			Test run
Chattogram Zone Total				3217	3157	635	1011	922	1213	180	462	
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	0	0	0	0	45		Gas Shortage
60	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	163	181	180	200			
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	265	290	280	280	70		Gas Shortage
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	285	290	280	280	70		Gas Shortage
63	Ashuganj 420 MW CCPP(East)	Gas (APSCCL)	1x284+1x116	400	400	230	230	240	240	170		Gas Shortage
64	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*116	195	195	0	8	0	0	187		Gas Shortage
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51			
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	13	23	50	140			
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	0			
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163		Under maint.
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	18	17	17			
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	18	18	18			
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	10	11	11			
72	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33			
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	25	52	52			
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	12	12	12	12			
75	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	52	17	52			
76	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	13	48	28	48			
77	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17			
78	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	17	54	17	72			
**	Impoort (Tripura)	India		160	160	124	136	143	166			
Cumilla Zone Total				2904	2896	1283	1496	1446	1689	542	163	
79	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	28	33	45	50	169		Gas Shortage
80	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	19	18	18			
81	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	59	79	40	85			
82	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	67	106	84	100			
83	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
84	Sutiakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	44	0	50	0			
85	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	6	6	6	6			
Mymensing Zone Total				622	614	224	243	245	259	169	0	

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	08.11.23 (Yesterday)		09.11.23 (Today)		08.11.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	Gas/Coal/Water Limitation MW	Machines shut down (MW)		
86	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	0	30	30	30	40	GT-1 Under maint.	
87	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	20	0	0	0	90	GT-4 Under maint.	
88	Fenchugonj 51 MW PP (Barakattullah)	Gas (RPP)	19x2.90	51	51	50	50	45	50			
89	Kushiara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0			
90	Hobigunj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	2	2	2			
91	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	59	59	60	62			
92	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0	330	Under maint.	
93	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	0	0	0	0			
94	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	202	202	205	205			
95	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	16	17	17	17	17			
96	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10			
97	Shahjibazar 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16			
98	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	120	290	290	300			
99	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	402	403	400	400			
100	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	265	260	260	260			
101	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0	100	Under project work	
102	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	0	0	0	0	50	Gas Shortage	
Sylhet Zone Total					2472	2427	1165	1339	1335	1352	50	560
103	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0			
104	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0	410	Gas Shortage	
105	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	50	0	50			
106	Gopalgunj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	55	0	55			
107	Khulna 225 MW CCPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0			
108	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	17	72	50	83			
109	Machumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	15	32	15	32			
110	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	73	0	100	0			
111	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	16	0	16			
112	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	0	0	0			
113	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	0	0	0	0			
114	Khulna 330 MW CCPP (GT)	Gas/HSD (BPDB)	1x220+1x116	336	336	0	0	0	0			
**	Bheramara (HVCDC) India			1000	1000	776	557	902	780			
Khulna Zone Total					3241	3237	881	782	1067	1016	410	0
115	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	48	110	16	110			
116	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	16	20	21	25			
117	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	127	130	130	130			
118	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	1244	1210	1244	1244			
119	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	35	35	38	150			
120	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	140	140	140	140			
121	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	220	220	220			
Barishal Zone Total					2265	2265	1830	1865	1809	2019	0	0
122	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71	Gas Shortage	
123	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100	Under maint.	
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	36	0	35			
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0			
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	4	0	20			
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	49	52	40	85			
128	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	32	39	30	40			
129	Katakhal 50 MW PP (Northern)	HFO (ORPP)	6x8.9	50	50	42	42	34	42			
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	38	24	38			
131	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210	Gas Shortage	
132	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220	Gas Shortage	
133	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0	220	Gas Shortage	
134	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	368	352	414	414	62	Gas Shortage	
135	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11			
136	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	52	8	52			
137	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	55	0	55			
138	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	30	50	35	50			
139	Ammura 50 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	0	28	28	28			
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	4	0	6	0	0			
**	Adani Power Jharkhand Ltd	(Import)	2x748	1496	1496	1222	1362	1200	1300			
Rajshahi Zone Total					3653	3631	1766	2121	1830	2170	783	100
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Coal Shortage	
142	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Under Overhauling	
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	170	170	170	170			
144	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	17	0	0			
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	6	91	34	113			
146	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
147	Majpara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	6	0	8	0	0			
148	Thakurgaon 158MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	60	70	75			
149	Lalmohar 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	0	30	0	0			
150	Tendra Solar Limited	Solar (IPP)	1 x 200	200	200	165	0	130	0			
Rangpur Zone Total					1030	950	377	338	442	358	85	85
Sub-total: Plants in operation					25059	24599	9911.0	11315	10983	12382	3517	1745
(B) Plants under long term maintenance/ contract expired												
151	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			
152	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			
153	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	0	0	0	0	0			
154	Ashugani 55 MW PP (Precision)	Gas (RPP)	15*4	55	0	0	0	0	0			
Sub-total: Plants under long term maintenance/ contract expired					280	0	0	0	0	0	0	0
Gross Total					25339	24599	9911	11315	10983	12382	3517	1745
(C) Actual data of 08.11.23 (Yesterday) Wednesday :												
01.	Max. Demand at eve. peak (Generation end)	:	11315 MW, at =	18:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	10954 MW, at =	18:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	11315 MW, at =	18:00 hrs	Dhaka	4420	4420	0	Mymensingh	858	858	0
04.	Minimum Generation (Generation end)	:	7970 MW, at =	5:00 hrs	Chattogram	1109	1109	0	Sylhet	407	407	0
05.	Day-peak Generation (Generation end)	:	9911 MW, at =	12:00 hrs	Khulna	1215	1215	0	Barishal	297	297	0
06.	Evening-peak Generation (Generation end)	:	11315 MW, at =	18:00 hrs	Rajshahi	1024	1024	0	Rangpur	677	677	0
07.	Evening Peak Load-shed (Sub-station end)	:	0 MW, at =	18:00 hrs	Cumilla	947	947	0				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	7938 MW, at =	5:00 hrs					Total	10954	10954	0
09.	Generation shortfall at evening peak due to :	:			13.	Fuel cost :	(a) Gas = 117585525 Taka (b) Oil = 319962036 Taka	(c) Coal = 530126736 Taka Total = 967674297 Taka				
	a) Gas/LF limitation	:	3432 MW		14.	Maximum Temperature in Dhaka was :	30.1°C					
	d) Coal supply Limitation	:	85 MW		15.	Export through East-West interconnections :						
	b) Low water level in Kaptai lake	:	0 MW			At evening peak-hour	:	9911 MW, at	18:00 hrs			
	c) Plants under shut down/ maintenance	:	1745 MW			Maximum	:	1020 MW, at	20:00 hrs			
	Total Energy (Generation + India Import)	:	231.13 MKWh			Energy	:	0 MKWh				
	By Gas = 112.656 MKWh			By Oil = 24.696 MKWh								
	By Coal = 66.807 MKWh			By Hydro = 2.998 MKWh								
	By Solar = 2.273 MKWh											
11.	Total Gas Supplied	:	874.61 MMCFD									
(D) Forecast of 09.11.23 (Today) Thursday :												
01.	Maximum Demand	:	11500 MW (Generation end)		04.	Maximum Load-shed	:	0 MW	At evening peak (Sub-station end)			
02.	Maximum Generation	:	12382 MW (Generation end)		05.	Total Generation	:	234.91 MKWh				
03.	Reserve / Shortage	:	882 MW (Generation end)		06.	Probable Max. Temperature in Dhaka :	30.1°C					

* Captive Power ** Imported Power
#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation