

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date : 11-Nov-23		Page -2					
No.	Name of the Power Stations	Producer	Installed Capacity	Capacity	Hour	Generated	Remarks
			Unit No. X Capacity	MW	Generati on	KWH	
1	Ghorasal Repowered CCPP-Unit-3 (GT)	PDB	1'260	260	0	0	Under maint.
2	Ghorasal Repowered CCPP Unit-4	PDB	1'210	180	0	0	
3	Ghorasal TPP Unit-5	PDB	1'210	190	180	4252500	Under maint.
3	Ghorasal 365 MW CCPP Unit-7	PDB	1'243+1'122	365	0	0	Air Compressor problem
4	Ghorasah 78.5 MW PPI(MAX)	QRPP	2'40	0	0	0	Contract Expired
4	Ghorasah 108 MW PP (Regent)	IPP	3'43'35	108	74	986909	Gas shortage
5	Haripur GTTP	SBU, PDB	2'32	20	0	0	Under maint.
6	Haripur 412 MW CCPP	EGCB	1'273+1'139	412	334	8148490	Gas shortage
7	Haripur 360 MW CCPP(HPL)	IPP	1'235+1'125	360	154	4426000	Gas shortage
8	Meghnaghat 450 MW CCPP(MPL)	IPP	2'150+1'150	450	225	4417300	GT-1 under S/D due to low demand
9	Meghnaghat 100 MW(UE)	NENP	1'28	100	20	109440	Low demand
10	Meghnaghat CCPP(Summit)	IPP	2'110+1'110	335	152	3273862	GT-1 under S/D due to gas shortage
11	Madanganj 102 PP(Summit)	NENP	6'17	102	34	224495	Fuel shortage
12	Madanganj-55 MW PP(Summit)	IPP	3'17.08+1'11.3	55	25	155541	Fuel shortage
13	Keraniganj 100 MW PP (Powerpac)	NENP	8'13.45	75	25	36992	Fuel shortage
14	Narsinghdi 22 MW PP (Doreen)	SIPP, REB	8'2.90	22	14	239328	Engine problem
15	210 MW Siddhirganj TPP	PDB	1'210	115	0	0	Under maint.
16	Siddhirganj 2'120 MW GTTP	EGCB	2'105	210	0	0	Gas shortage
17	Siddhirganj 100 PP(Dutch Bangla)	NENP	12'8.9	100	50	238080	Fuel shortage
18	Siddhirganj 335 MW CCPP	EGCB	1'217+118	335	224	5581893	Gas shortage
19	Gagnagar 102 MW PP (Digital Power)	IPP	12'8.924	102	91	293472	Engine problem
20	Kalitotti 52 MW PP (Sinha)	IPP	1'77.9	0	0	0	Fuel shortage
21	Kamalaghat 54 MW PP(Banco Energy)	IPP	3'18	54	17	115920	Fuel shortage
22	Kodda 150 MW PP	BPDB-RPCL	9'17.06	149	32	201600	Low demand
23	Manikganj 55 MW PP (Northern)	IPP	3'19.3	55	35	134564	Fuel shortage
24	Nababganj 55 MW PP (Southern power)	IPP	3'19.3	55	55	140690	
25	Bosila 108 MW PP(GCL)	IPP	12'8.775+1'13.5	0	0	0	
26	Summit Power, (Madhabdi+Ashulia)	SIPP, REB	3'3.67+4'8.73	80	30	735000	Engine problem
27	Maona 33 MW PP(Summit)	SIPP, REB	4'8.73	33	25	628900	
28	Rugganj 33 MW PP(Summit)	SIPP, REB	4'8.73	33	25	614200	Engine problem
29	Gazipur 52 MW PP	RPCL	8'8.9	52	18	62890	Fuel shortage
30	Tongi 80 MW GTTP	PDB	1' 105	105	0	0	Gas shortage
31	Kodda 300 MW PP Unit-2 (Summit)	IPP	18'17.076	300	49	373855	Fuel shortage
33	Bramhanganj 100 MW PP (Aggreko)	IPP	11'40.959	0	0	0	Contract Expired
34	Aurahati 100MW PP (Aggreko)	IPP	0.85'23.05'39'91	0	0	0	Contract Expired
35	Kodda 149 MW PP Unit-1 (Summit)	IPP	8'18.45+8.97	149	51	536256	Fuel shortage
36	Gazipur 100 MW PP	RPCL	6'17.5	105	0	14400	Engine problem
37	Meghnaghat 104 MW PP (OPCL)	IPP	18'5.6	104	51	514560	Fuel shortage
38	Manikganj 162MW PP(MPL)	IPP	9'18	162	35	129600	Fuel shortage
39	Spectra Solar Plant Ltd.	IPP	35	35	0	208015	
40	Kanchan Purbatahal Power Generation Ltd.	IPP	18.43	55	35	123480	Fuel shortage
Meghnaghat Unique power		IPP	586	0	0	0	On test.
Summit Meghnaghat-2 589 MW(Gas)		IPP	589	0	0	0	On test.
Dhaka area Total				5422	2060	36931822	
41	Chattogram TPP-1	PDB	1'210	180	0	0	Gas shortage
41	Chattogram TPP-2	PDB	1'210	180	0	0	Gas shortage
42	Raozan 25 MW PP	RPCL	3'8.9	25	16	105269	Fuel shortage
43	Teknaf 20MW PP (Solarsat)	IPP	20	20	0	135000	
44	Palenga 50MW PP (Baraka)	IPP	6'6.98	50	26	340800	Fuel shortage
45	Kaptai Hydro 2,3,4, 5	PDB	2'40+3'50	230	132	3012800	Unit-2 under maint.
46	Sikalbaha 225MW	PDB	1'150+1'175	225	141	3171935	
47	Sikalbaha Peaking GT	PDB	1'150	150	0	0	Under maint.
48	Sikalbaha 105 MW PP (Baraka Sikalbaha)	IPP	6'17.5	105	17	387236	Fuel shortage
49	Hathazari 100 MW peaking PP	PDB	1'18.9	98	16	108432	Fuel shortage
50	Dohazari-Kalash 100 MW Peaking	PDB	6'17	102	17	195009	Fuel shortage
51	Julidah 100 MW Unit-1 (Acom)	NENP	8'13.45	100	12	168120	Fuel shortage
52	Julidah 100 MW PP Unit-3 (Acom)	IPP	8'13.5	100	12	206400	Fuel shortage
53	Barakunda 22 MW PP (Regent)	SIPP, PDB	8'2.90	22	12	210816	Engine problem
54	Matsencha, Ccp EPZ (United)	IPP	5'8.73+9.34	0	0	370890	
54	Chattogram 108 MW PP (ECPV)	IPP	16'7	108	0	0	Fuel shortage
55	Kaptai 7 MW Solar PP	PDB	7.4 MW	7	0	27242	
56	Anwara 300 MW PP (United)	IPP	17'17+24	300	240	1944545	Fuel shortage
57	Jodiad Power	IPP	3'18.55+1'13.6	54	17	228523	Fuel shortage
58	Karnaphuli Power Ltd.	IPP	18'45+6+6.5	110	19	409817	Fuel shortage
59	Julidah unit-2 (Acom)	IPP	8'13.6	100	12	189120	Fuel shortage
60	Anilma Energy Ltd.	IPP	6'21.2	116	17	270982	Fuel shortage
Mirsharai 150 MW		BPDB-RPCL	18.5'9	163	17	167272	Fuel shortage
SS Power I		SS Power	1'612	612	325	7641817	Machine problem
Cox's Bazar Wind		IPP	66	0	3	53760	On test.
Matarbari 2'600 MW (CPGCL)		CPGCL	0	0	201	4952727	On test.
Chattogram area Total				3157	1252	24297702	
61	Ashuganj TPP Unit- 3	APSCCL	1'150	0	0	0	Contract Expired
61	Ashuganj TPP Unit- 4	APSCCL	1'150	0	0	0	Contract Expired
61	Ashuganj TPP Unit- 5	APSCCL	1'150	0	0	0	Contract Expired
62	Ashuganj 225 MW CCPP	APSCCL	1'142+1'175	221	158	4142000	Gas shortage
63	Ashuganj 450 MW CCPP(North)	APSCCL	1'360	360	280	7283500	Gas shortage
64	Ashuganj 450 MW CCPP(South)	APSCCL	1'360	360	240	6140000	Gas shortage
64	Ashuganj 420 MW CCPP(East)	APSCCL	284'1+1'16'1	400	230	5886200	Gas shortage
65	Ashuganj 50 MW PP	APSCCL	14'3.968	45	0	0	Gas shortage
66	Ashuganj 55 MW PP (Precision)	QRPP	0	0	0	0	Contract Expired
67	Ashuganj 195 MW PP (APSCCL-United)	IPP	20'9.73+1'16	195	0	0	Gas shortage
68	Ashuganj 51 MW PP (Midland)	IPP	6'9.34	51	51	742532	
69	Ashuganj 150 MW PP (Midland)	IPP	23'7.015	150	80	259272	Fuel shortage
70	Titas 50 MW Peaking PP	PDB	6'8.92	52	0	0	Under maint.
71	Chandpur 150 MW CCPP	PDB	1'106+1'57	163	0	0	Under maint.
72	Chandpur 200 MW (Desh energy)	IPP	12'18.4	200	17	169440	Fuel shortage
73	Feni 22 MW PP (Doreen)	SIPP, PDB	8'2.90	22	16	262332	Engine problem
74	Feni 11 MW PP (Doreen)	SIPP, REB	4'2.90	11	10	178380	
**	Import (Tribuna)	Imported power	0	160	130	2749440	
75	Jangalia 33 MW PP (Summit)	SIPP, PDB	4'8.73	33	33	596800	
76	Jangalia 52 MW PP (Lakdawan)	IPP	6'8.92	52	28	93413	Fuel shortage
77	Cumilla 25 MW PP (Summit)	SIPP, REB	3'3.67+2'6.97	25	12	278500	Engine problem
78	Daudkandi 200 MW PP (B. Trac)	IPP	154'1.4	0	0	0	Contract Expired
79	Feni Lanka Power	IPP	7'18.415+1'9.78	114	17	79800	Fuel shortage
80	Chowmuhani 113 MW	IPP	12'9.78+2'3.1	113	57	462000	Fuel shortage
81	Bhairob 54.5 MW	IPP	3'18.2	54	17	120240	33 kV feeder problem
82	Chandpur 115 (Doreen)	IPP	4'18.5+2'22.5	115	88	683120	Fuel shortage
Cumilla Area Total				2896	1444	30136959	
83	RPCL 210MW CCPP	IPP	4'35+1'70	202	99	2229120	Gas shortage
84	Tangail 22 MW PP (Doreen)	SIPP, PDB	8'2.90	22	18	174096	Engine problem
85	Jamalpur 95 MW PP(Powerpac)	IPP	0	0	0	0	Under maint.
86	Sarishabari 3 MW Solar Plant	IPP	1'3	3	0	13500	
87	Mymensingh 200 MW PP (United)	IPP	9'78'21	200	93	352800	Fuel shortage
88	Jamalpur 115 MW PP (United)	IPP	9'78'12	115	85	538800	Fuel shortage
89	Sutiakhali 50 MW Solar PP	IPP	50	50	0	273190	
90	Tangail Pali Power Gen 22 MW	IPP	4'6.7	22	6	79440	Engine problem
Mymensingh Area Total				614	301	3660946	
91	Fenchuganj CCPP Phase-1	PDB	2'32+1'33	70	42	994000	Under maint.
92	Fenchuganj CCPP Phase-2	PDB	2'35+1'35	90	0	0	Machine problem
93	Kushlaria 163 MW CCPP (KP)	IPP	1'109+1'54	163	0	0	Gas shortage
94	Shajibazar 330 MW CCPP	PDB	3'110	330	0	0	Under maint.
95	Fenchuganj 51 MW PP (Barakotullah)	RPCL	10'2.90	51	50	616200	
Fenchuganj 44 MW (Energy/primar)		NENP	12'3.3+5'2	50	0	0	Gas shortage
96	Hobiganj 11 MW PP Confidence-E	SIPP, REB	4'2.90	11	5	89134	Engine problem
97	Shajibazar GTTP Unit- 8 & 9	PDB	2'35	66	62	1164864	
98	Shajibazar 86 MW PP (Shajibazar)	RPCL	32'2.90	86	0	0	Gas shortage
99	Shajibazar 100 MW GTTP	PDB	1'100	100	0	0	Under maint.
100	Sylhet 225 MW CCPP	PDB	1'142+1'89	231	205	5117740	Machine problem
101	Sylhet 20 MW GTTP	PDB	1'20	20	17	298000	
102	Sylhet 50 MW PP (EPL)	NENP	2'72	0	0	0	Contract Expired
102	Shajibazar 25 MW PP	SIPP, REB	3'9.34	25	16	258480	Engine problem
103	Bibiana-II 341 MW CCPP (Summit)	IPP	1'222+1'119	341	285	6994000	FGMO
104	Bibiyana-III 400 MW CCPP	PDB	285'1+1'34'1	400	402	8982000	
105	Sylhet 10MW PP (Desh)	RPCL	6'1.95	10	10	171720	
106	Bibiyana South 400 MW	PDB	400 MW	383	260	5688700	ST U/M
Sylhet Area Total				2427	1354	3078638	
107	Bheramara GTTP Unit-3	PDB	1'20	16	0	0	
**	Bheramara (HVDC)	Imported power	2'500	1000	912	20078545	
108	Khulna 115 PP MW (KPCL-2)	NENP	7'17	115	16	16320	High voltage
109	Fandpur 50 MW Peaking PP	PDB	6'8.98	54	0	0	Reserve
110	Khulna 225 MW CCPP	NWPGCL	1'150+1'175	230	0	0	Fuel shortage
111	Gopalganj 100 MW Peaking PP	PDB	16'6.98	109	0	0	Reserve
112	Bheramara 410 MW CCPP	NWPGCL	1'278+1'132	410	0	0	Gas shortage
113	Noapara 40 MW PP (Khanjahan Ali)	NENP	5'8.5	40	0	0	Fuel shortage
113	Noapara 100 MW PP (Bangla Trac)	IPP	10'1.4	0	0	0	Contract Expired
114	Rupsha 105 MW PP (Orion rupsha)	IPP	6'18.445	105	13	89760	High voltage
115	Madhumati 100 MW PP	NWPGCL	6'18	105	32	54144	Fuel shortage
116	Mongla Orion 100 MW Solar PP	IPP	100	100	0	455040	
Khulna 330 MW CCPP (OIL)		BPDB	1'220+1'110	336	0	0	
Rampal 132 MW (BPCL)		NTPC&BPDB	860'2	617	455	9338182	
Kulna 225 MW CCPP (GAS)		NWPGCL	0	0	0	0	
Khulna Area Total				3237	1428	30031991	
117	Barisal 110 MW PP (Summit)	IPP	7'17.076	110	12	27264	Low demand
118	Bhola 33 MW PP (Venture)	NEN					