

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9546667, 9551095

Month November, 2023					Day : Sunday				Date : 12.11.23			
Probable Maximum Demand : 11800 MW					Probable Maximum Generation : 13667 MW				Rule Curve = 107.90 ft.			
Water Level of Kapitai Lake at 06:00 AM					Yesterday = 100.07 ft	Today = 99.90 ft						
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	11.11.23 (Yesterday)		12.11.23 (Today)		11.11.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/Oil/Water Limitation MW			
					Day	Evening	Day	Evening		Machines shut down (MW)	Description/ Remarks	Probable start-up date
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0			Gas Shortage
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	170	180	180	180			
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0			
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	51	74	80	80			
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0			
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	167	154	150	150	206		Gas Shortage
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225	225		Gas Shortage
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	355	334	395	400	78		Gas Shortage
11	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	251	224	260	260	111		Gas Shortage
13	Meghnaghat 335MW CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	138	152	150	150	183		Gas Shortage
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	25	15	15			
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	0	91	91	91			
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	12	14	18	18			
17	Summit Power,Madhabdi+Ashulia	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	30	30	31	31			
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	33	33			
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	25	25			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	18	8	25			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	0	0	0	105			
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	16	32	16	132			
23	Kamalghat 54 MW PP (Barco Energy)	HFO (IPP)	3x18.69	54	54	0	17	0	17			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	49	80	130			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	17	51	17	80			
26	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	55	0	55			
27	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	35	0	35			
28	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	2	51	17	51			
29	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	0	35	17	35			
30	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	31	0	35	0			
31	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	35	17	35			
32	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	1	50	17	50			
33	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	0	20	8	50			
34	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	34	95	95			
35	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	25	50	50			
36	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			
	Meghnaghat Unique Power	Gas			0	0	0	0	0			
	Meghnaghat 589 MW CCPP(Summit)	Gas			0	0	0	0	0			
Dhaka Zone Total				5655	5422	1516	2060	2030	2603	1118	375	
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	132	132	132	132			
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0			
40	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	16	8	17			
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	0	20	0	0			
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	24	26	6	26			
43	Sikalbaha 105 MW PP (Baraka Sikabaha)	HFO (IPP)	6x18.415	105	105	24	17	17	17			
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	141	141	141	141			
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.94	300	300	85	240	100	260			
47	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	12	12	12	12			
48	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	17	17	0	17			
49	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	16	8	17			
50	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	12	12	12	12			
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			0	0	20	30			
51	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0			
52	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	5	17	17	17			
53	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	35	19	17	19			
54	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	12	12	12	12			
55	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	12	12	12	12			
56	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	17	17	17	34			
57	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	15	17	17	17			
58	SS Power Unit-1	Coal (IPP)	1x612	612	612	312	325	325	325			
	Matarbari 2*600 MW (CPGCL)	Coal				204	201	300	300			Test run
	Cox's Bazar Wind PP	(Wind) (IPP)				0	3	10	10			Test run
Chattogram Zone Total				3217	3157	1083	1252	1208	1427	180	330	
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	0	0	0	0	45		Gas Shortage
60	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	186	158	180	190			
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	240	240	280	280	120		Gas Shortage
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	275	280	280	280	80		Gas Shortage
63	Ashuganj 420 MW CCPP(East)	Gas (APSCCL)	1x284+1x116	400	400	230	230	300	300	170		Gas Shortage
64	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*116	195	195	0	0	0	0	195		Gas Shortage
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	26	51	51	51			
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	60	12	140			
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	0			
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0		163	Under maint.
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	0	17	17	17			
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	15	16	18	18			
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	10	10	10	10			
72	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33			
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	28	52	52			
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	6	12	12	12			
75	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	17	17	52			
76	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	0	57	28	58			
77	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	0	17	17	17			
78	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	4	88	34	95			
**	Impoqti (Tripura)	India		160	160	124	130	128	140			
Cumilla Zone Total				2904	2896	1149	1444	1469	1745	610	163	
79	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	97	99	100	100	103		Gas Shortage
80	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	18	18	18			
81	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	8	85	40	85			
82	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	8	93	84	100			
83	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
84	Sutiakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	49	0	50	0			
85	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	6	6	6	6			
Mymensingh Zone Total				622	614	170	301	300	309	103	0	

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	11.11.23 (Yesterday)		12.11.23 (Today)		11.11.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gas/Coal/Water Limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening				
86	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	42	42	42	28	GT-1 Under maint.	
87	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	0	0	0	0	90	GT-4 Under maint.	
88	Fenchugonj 51 MW PP (Barakattullah)	Gas (RPP)	19x2.90	51	51	42	50	45	50			
89	Kushiara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0	163	Gas Shortage	
90	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	5	2	2	6	Gas Shortage	
91	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	58	62	60	62			
92	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0	330	Under maint.	
93	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	0	0	0	0	86	Gas Shortage	
94	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	202	205	205	205			
95	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	16	17	17	17	17			
96	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10			
97	Shahjibazar 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	0	16	16	16			
98	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	285	290	300			
99	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	403	402	400	400			
100	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	250	260	230	260			
101	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0	100	Under project work	
102	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	0	0	0	0	50	Gas Shortage	
Sylhet Zone Total					2472	2427	1329	1354	1317	1364	305	548
103	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0			
104	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0	410	Gas Shortage	
105	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	50			
106	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	75			
107	Khulna 225 MW CCPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0			
108	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	13	50	83			
109	Machumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	32	15	32			
110	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	72	0	100	0			
111	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	16	0	16			
112	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	0	0	0			
113	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	345	455	400	570			
114	Khulna 330 MW CCPP (GT)	Gas/HSD (BPDB)	1x220+1x116	336	336	0	0	0	0			
**	Bheramara (HVCDC)	India		1000	1000	911	912	919	801			
Khulna Zone Total					3241	3237	1328	1428	1484	1627	410	0
115	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	12	16	110			
116	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	14	23	21	25			
117	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	130	120	130	130			
118	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	590	900	1244	1244			
119	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	54	38	150			
120	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	140	140	140	185			
121	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	220	220	220			
Barishal Zone Total					2265	2265	1094	1469	1809	2064	0	0
122	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71	Gas Shortage	
123	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100	Under maint.	
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	0	35			
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0			
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	20			
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	0	40	85			
128	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	30	40			
129	Katakhali 50 MW PP (Northern)	HFO (ORPP)	6x8.9	50	50	0	0	34	42			
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	24	38			
131	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210	Gas Shortage	
132	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220	Gas Shortage	
133	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0	220	Gas Shortage	
134	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	414	414	250	414			
135	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11			
136	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	0	8	52			
137	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	35	35	55			
138	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	45	35	50			
139	Ammura 50 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	0	0	28	28			
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0			
**	Adani Power Jharkhand Ltd	(Import)	2x748	1496	1496	922	1155	1200	1300			
Rajshahi Zone Total					3653	3631	1352	1660	1701	2170	721	100
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Coal Shortage	
142	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Under Overhauling	
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	170	170	170	170			
144	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	0	34	34	113			
146	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
147	Majpara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	6	0	0	8	0			
148	Thakurgaon 119MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	35	70	75			
149	Lalmoshai 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	34	0	30	0			
150	Tendra Solar Limited	Solar (IPP)	1 x 200	200	200	183	0	130	0			
Rangpur Zone Total					1030	950	393	239	442	358	85	85
Sub-total: Plants in operation					25059	24599	9414	11207	11760	13667	3532	1601
(B) Plants under long term maintenance/ contract expired												
151	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			
152	Bosilla 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			
153	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	0	0	0	0	0			
154	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	0	0	0	0	0			
Sub-Total: Plants under long term maintenance/ contract expired					280	0	0	0	0	0	0	0
Gross Total					25339	24599	9414	11207	11760	13667	3532	1601
(C) Actual data of 11.11.23 (Yesterday) Saturday :												
01.	Max. Demand at eve. peak (Generation end)	:	11207 MW, at =	18:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	10994 MW, at =	18:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	11207 MW, at =	18:00 hrs	Dhaka	4349	4349	0	Mymensingh	896	896	0
04.	Minimum Generation (Generation end)	:	7369 MW, at =	5:00 hrs	Chattogram	1144	1144	0	Sylhet	437	437	0
05.	Day-peak Generation (Generation end)	:	9414 MW, at =	12:00 hrs	Khulna	1198	1198	0	Barishal	297	297	0
06.	Evening-peak Generation (Generation end)	:	11207 MW, at =	18:00 hrs	Rajshahi	1006	1006	0	Rangpur	680	680	0
07.	Evening Peak Load-shed (Sub-station end)	:	0 MW, at =	18:00 hrs	Cumilla	988	988	0				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	7754 MW, at =	5:00 hrs					Total	10994	10994	0
09.	Generation shortfall at evening peak due to :	:			13.	Fuel cost :	(a) Gas = 114369596 Taka (b) Oil = 149963523 Taka	(c) Coal = 512916895 Taka Total = 777250014 Taka				
10.	Total Energy (Generation + India Import)	:	222.70 MKWh		14.	Maximum Temperature in Dhaka was :	31.6°C					
	By Gas = 111.204 MKWh		By Oil = 11.800 MKWh		15.	Export through East-West interconnections :						
	By Coal = 71.217 MKWh		By Hydro = 3.013 MKWh			At evening peak-hour :	9414 MW, at 18:00 hrs					
	By Solar = 2.581 MKWh					Maximum :	350 MW, at 19:00 hrs					
11.	Total Gas Supplied	:	870.73 MMCFD			Energy :	0 MKWh					
(D) Forecast of 12.11.23 (Today) Sunday :												
01.	Maximum Demand	:	11800 MW (Generation end)		04.	Maximum Load-shed	:	0 MW At evening peak (Sub-station end)				
02.	Maximum Generation	:	13667 MW (Generation end)		05.	Total Generation	:	234.48 MKWh				
03.	Reserve / Shortage	:	1867 MW (Generation end)		06.	Probable Max. Temperature in Dhaka :	31.6°C					

* Captive Power ** Imported Power
#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation