

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9546667, 9551095

Month November, 2023				Day : Tuesday				Date : 14.11.23			
Probable Maximum Demand : 12000 MW				Probable Maximum Generation : 14223 MW				Rule Curve = 107.80 ft.			
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 99.66 ft	Today = 99.42 ft						
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	13.11.23 (Yesterday)		14.11.23 (Today)		13.11.23 (Yesterday)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		
					Day	Evening	Day	Evening	Gas/Coal/Oil/Water Limitation MW	Machines shut down (MW)	
(A) Plants in operation:											
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0		Gas Shortage
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180		
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	73	79	40	40		
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0		
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	151	156	200	200	204	Gas Shortage
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225	225	Gas Shortage
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	365	333	340	360	79	Gas Shortage
11	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	236	243	230	230	92	Gas Shortage
13	Meghnaghat 335MW CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	152	125	150	150	210	Gas Shortage
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	24	15	30		
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	0	24	92	92		
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	15	18	18	18		
17	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	30	30	31	31		
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	33	33	33		
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	16	25	25	25		
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	20	8	25		
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	35	105	30	105		
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	32	82	32	149		
23	Kamalghat 54 MW PP (Barco Energy)	HFO (IPP)	3x18.69	54	54	0	17	0	17		
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	106	80	130		
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	17	71	17	100		
26	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	17	0	35		
27	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	35	0	35		
28	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	0	42	17	71		
29	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	0	35	17	35		
30	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	31	0	35	0		
31	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	34	17	35		
32	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	0	26	92	92		
33	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	0	18	100	100		
34	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	17	68	65	85		
35	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	36	30	45		
36	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0		
	Meghnaghat Unique Power	Gas				0	0	0	0		
	Meghnaghat 589 MW CCPP(Summit)	Gas				0	0	0	0		
Dhaka Zone Total			5655	5422	1623	2207	2119	2673	1125	375	
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	132	132	132	132		
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		Under maint.
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0		
40	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	1	8	8	17		
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	19	0	20	0		
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	14	6	19		
43	Sikalbaha 105 MW PP (Baraka Sikabaha)	HFO (IPP)	6x18.415	105	105	3	17	17	17		
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	204	201	200	200		
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.94	300	300	70	200	100	260		
47	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	12	12	12	12		
48	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	17	0	0	0		
49	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	4	17	60	60		
50	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	12	12	12	12		
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			0	2	7	20		
51	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0		
52	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	15	17	17	17		
53	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	17	17	17		
54	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	12	12	12	12		
55	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	12	12	12	12		
56	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	17	17	17	17		
57	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	18	17	17	17		
58	SS Power Unit-1	Coal (IPP)	1x612	612	612	306	306	330	330		
	Matarbari 2*600 MW (CPGCL)	Coal				548	546	390	600		Test run
	Cox's Bazar Wind PP	(Wind) (IPP)				0	0	10	10		Test run
Chattogram Zone Total			3217	3157	1429	1559	1401	1781	180	330	
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	49	51	51	51		
60	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	0	0	0	0	221	Under Maint.
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	305	270	280	310	90	Gas Shortage
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	310	290	280	310	70	Gas Shortage
63	Ashuganj 420 MW CCPP(East)	Gas (APSCCL)	1x284+1x116	400	400	270	240	250	250	160	Gas Shortage
64	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*116	195	195	8	8	0	0	187	Gas Shortage
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51		
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	100	12	120		
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	0		
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163	Under maint.
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	23	17	17	17		
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	15	14	15	17		
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	0	11	10	11		
72	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	25	33	33		
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	34	52	52		
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	12	12	12	12		
75	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	62	17	114		
76	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	0	58	28	75		
77	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	0	17	17	17		
78	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	11	69	34	95		
**	Impootti (Tripura)	India		160	160	122	148	128	140		
Cumilla Zone Total			2904	2896	1209	1477	1287	1675	507	384	
79	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	63	71	70	80	131	Gas Shortage
80	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0		
81	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	24	75	40	85		
82	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	49	106	84	100		
83	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0		
84	Sutiakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	0	50	0	0		
85	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	6	6	6	6		
Mymensingh Zone Total			622	614	194	258	252	271	131	0	

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	13.11.23 (Yesterday)		14.11.23 (Today)		13.11.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gas/Coal/Water Limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening				
86	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43	27	GT-1 Under maint.	
87	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	0	0	0	0	90	GT-4 Under maint.	
88	Fenchugonj 51 MW PP (Barakattallah)	Gas (RPP)	19x2.90	51	51	47	47	45	50			
89	Kushiara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0	163	Gas Shortage	
90	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	5	2	2	6	Gas Shortage	
91	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	58	57	60	62			
92	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0	330	Under maint.	
93	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	0	0	0	0	86	Gas Shortage	
94	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	203	201	205	205			
95	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	16	17	17	17	17			
96	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10			
97	Shahjibazar 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16			
98	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	280	290	300			
99	Bibiana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	404	402	400	400			
100	Bibiana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	205	242	310	310			
101	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0	100	Under project work	
102	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12'3.3+5'2	50	50	0	0	0	0	50	Gas Shortage	
Sylhet Zone Total					2472	2427	1307	1320	1398	1415	305	547
103	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0			
104	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0	410	Gas Shortage	
105	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	50			
106	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	70			
107	Khulna 225 MW CCPP	HSD Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0			
108	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	6	29	105	105			
109	Machumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	28	15	32			
110	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	82	0	100	0			
111	Khulna 115 MW PP (KPCCL-2)	HFO (NENP)	7x17	115	115	0	16	0	16			
112	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5'8.5	40	40	0	0	0	0			
113	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	378	455	400	570			
114	Khulna 330 MW CCPP (GT)	Gas/HSD (BPDB)	1x220+1x116	336	336	0	0	0	0			
**	Bheramara (HVCDC) India			1000	1000	918	918	918	918			
Khulna Zone Total					3241	3237	1384	1446	1538	1761	410	0
115	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	16	110			
116	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	18	24	21	25			
117	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	130	120	130	130			
118	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	720	820	1244	1244			
119	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	17	38	150			
120	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	140	140	140	200			
121	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	220	220	220			
Barishal Zone Total					2265	2265	1228	1341	1809	2079	0	0
122	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71	Gas Shortage	
123	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100	Under maint.	
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	0	35			
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0			
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	20			
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	0	40	85			
128	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	30	40			
129	Katakhali 50 MW PP (Northern)	HFO (ORPP)	6x8.9	50	50	0	0	34	42			
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	38	24	38			
131	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210	Gas Shortage	
132	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220	Gas Shortage	
133	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0	220	Gas Shortage	
134	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	370	400	360	414			
135	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	0	0	11	11			
136	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	8	8	52			
137	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6'18.55	113	113	0	35	35	55			
138	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	40	35	50			
139	Amnura 50 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	0	0	28	28			
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0			
**	Adani Power Jharkhand Ltd	(Import)	2x748	1496	1496	1013	1149	1200	1300			
Rajshahi Zone Total					3653	3631	1388	1670	1811	2170	721	100
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Coal Shortage	
142	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Under Overhauling	
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	170	170	170	170	104	Coal Shortage	
144	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	0	53	40	113			
146	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
147	Majpara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	6	0	8	0	0			
148	Thakurgaon 158MW PP (Energypac)	HFO (IPP)	6'2'20	115	115	0	52	70	115			
149	Lalmohini 30 MW Solar (Intraco)	Solar (IPP)	1 x 30	30	30	35	0	30	0			
150	Tendra Solar Limited	Solar (IPP)	1 x 200	200	200	184	0	130	0			
Rangpur Zone Total					1030	950	395	275	448	398	189	85
Sub-total: Plants in operation					25059	24599	10157.0	11553	12063	14223	3568	1821
(B) Plants under long term maintenance/ contract expired												
149	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			
150	Bosilla 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			
151	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	0	0	0	0	0			
152	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	0	0	0	0	0			
Sub-total: Plants under long term maintenance/ contract expired					280	0	0	0	0	0	0	0
Gross Total					25339	24599	10157	11553	12063	14223	3568	1821
(C) Actual data of 13.11.23 (Yesterday) Monday :												
01.	Max. Demand at eve. peak (Generation end)	:	11553 MW, at =	18:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	11207 MW, at =	18:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	11553 MW, at =	18:00 hrs	Dhaka	4477	4477	0	Mymensingh	891	891	0
04.	Minimum Generation (Generation end)	:	7806 MW, at =	5:00 hrs	Chattogram	1185	1185	0	Sylhet	432	432	0
05.	Day-peak Generation (Generation end)	:	10157 MW, at =	12:00 hrs	Khulna	1217	1217	0	Barishal	297	297	0
06.	Evening-peak Generation (Generation end)	:	11553 MW, at =	18:00 hrs	Rajshahi	1003	1003	0	Rangpur	693	693	0
07.	Evening Peak Load-shed (Sub-station end)	:	0 MW, at =	18:00 hrs	Cumilla	1012	1012	0				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	7882 MW, at =	5:00 hrs					Total	11207	11207	0
09.	Generation shortfall at evening peak due to :	:			13.	Fuel cost :	(a) Gas = 114527712 Taka (b) Oil = 196557171 Taka		(c) Coal = 503670485 Taka Total = 814755368 Taka			
a)	Gas/LF limitation	:	3379 MW		14.	Maximum Temperature in Dhaka was :	31.9°C					
d)	Coal supply Limitation	:	189 MW		15.	Export through East-West interconnections :						
b)	Low water level in Kaptai lake	:	0 MW		At evening peak-hour	:	10157 MW, at	18:00 hrs				
c)	Plants under shut down/ maintenance	:	1821 MW		Maximum	:	374 MW, at	7:00 hrs				
10.	Total Energy (Generation + India Import)	:	232.36 MKWh		Energy	:	0 MKWh					
	By Gas = 112.043 MKWh		By Oil = 15.155 MKWh									
	By Coal = 75.681 MKWh		By Hydro = 3.064 MKWh									
	By Solar = 2.718 MKWh											
11.	Total Gas Supplied	:	840.20 MMCFD									
(D) Forecast of 14.11.23 (Today) Tuesday :												
01.	Maximum Demand	:	12000 MW (Generation end)		04.	Maximum Load-shed	:	0 MW At evening peak (Sub-station end)				
02.	Maximum Generation	:	14223 MW (Generation end)		05.	Total Generation	:	241.35 MKWh				
03.	Reserve / Shortage	:	2223 MW (Generation end)		06.	Probable Max. Temperature in Dhaka :	:	31.9°C				

* Captive Power ** Imported Power
#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation