

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9546667, 9551095

Month November, 2023					Day : Friday					Date : 17.11.23				
Probable Maximum Demand : 10000 MW					Probable Maximum Generation : 13946 MW									
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 98.99 ft					Today = 98.79 ft				
					Rule Curve = 107.40 ft									
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	16.11.23 (Yesterday)		17.11.23 (Today)		16.11.23 (Yesterday)		17.11.23 (Today)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Machines shut down (MW)			
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW					
(A) Plants in operation:														
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0			260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0				Gas Shortage	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180					
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0					
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	61	43	60	75					
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0			105	Gas Shortage	
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0					
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	175	180	160	170			180	Gas Shortage	
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	180	225	225			270	Gas Shortage	
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0				115 Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	346	326	360	360			86	Gas Shortage	
11	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0			210	Gas Shortage	
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	253	230	250	250			105	Gas Shortage	
13	Meghnaghat 335MW CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	150	151	0	0			184	Gas Shortage	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	15	15	30					
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	0	16	92	92					
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	18	17	18	18					
17	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	31	31	31	31					
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	33	33	33					
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	25	25					
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	25	8	25					
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	35	105	30	105					
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	16	64	32	149					
23	Kamalaghat 54 MW PP (Barco Energy)	HFO (IPP)	3x18.69	54	54	0	17	0	17					
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	60	80	130					
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	17	69	17	100					
26	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	35	0	35					
27	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	35	0	35					
28	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	0	42	17	71					
29	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	35	17	17	35					
30	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	13	0	35	0					
31	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	17	17	35					
32	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	0	37	92	92					
33	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	0	13	100	100					
34	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	17	58	65	85					
35	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	0	30	45					
36	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0					
	Meghnaghat Unique Power	Gas				0	0	0	0					
	Meghnaghat 589 MW CCPP(Summit)	Gas				0	0	0	0					
Dhaka Zone Total				5655	5422	1630	2021	1989	2548		1140	375		
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	132	132	132	132					
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0			180	Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0				180 Under maint.	
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	1	0	5	0					
40	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	14	8	17					
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	3	0	20	0					
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	14	6	19					
43	Sikalbaha 105 MW PP (Baraka Sikabaha)	HFO (IPP)	6x18.415	105	105	17	17	17	17					
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0				150 Under maint.	
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	202	201	200	200					
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.94	300	300	0	150	245	245					
47	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	12	12	12	12					
48	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	0	0	0					
49	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	30	60	60					
50	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	10	10	12	12					
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			0	6	7	10					
51	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0					
52	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	17					
53	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	17	17	17					
54	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	12	10	12	12					
55	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	12	12	12	12					
56	Chattogram 116 MW PP (Anilma Energy Ltd.)	HFO (IPP)	6x21.06	116	116	17	34	17	17					
57	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	14	17	17	17					
58	Chattogram 2*612MW Coal Based PP (SS Powe	Coal (IPP)	2x612	1224	1224	420	450	420	420					
	Matbari 2*600 MW (CPGCL)	Coal				562	562	560	560				Test run	
	Cox's Bazar Wind PP	(Wind) (IPP)				14	8	10	10				Test run	
Chattogram Zone Total				3829	3769	1468	1713	1806	1806		180	330		
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	47	50	51	51					
60	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	0	0	0	0				221 Under Maint.	
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	305	250	280	300			110	Gas Shortage	
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	305	300	280	300			60	Gas Shortage	
63	Ashuganj 420 MW CCPP(East)	Gas (APSCCL)	1x284+1x116	400	400	350	250	340	340			150	Gas Shortage	
64	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	0	0	0			195	Gas Shortage	
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51					
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	50	12	120					
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	0					
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0				163 Under maint.	
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	17	17	17					
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	16	17	15	17					
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	10	10	10	11					
72	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33					
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	6	52	52					
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	6	6	12	12					
75	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	36	17	114					
76	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	28	57	28	75					
77	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	0	0	17	17					
78	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	18	65	34	95					
**	Imphott (Tripura)	India		160	160	128	130	128	140					
Cumilla Zone Total				2904	2896	1322	1328	1377	1745		515	384		
79	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	33	33	65	70			169	Gas Shortage	
80	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0					
81	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	59	88	47	85					
82	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	58	93	84	100					
83	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	0	0	1.6	0					
84	Suliakhali 50 MW Solar PP	Solar (IPP)	1x50	50	50	6	0	50	0					
85	Tangail 22 MW PP(PDGL)	HFO (IPP)	4x6.7	22	22	6	6	6	6					
Mymensingh Zone Total				622	614	162	220	254	261		169	0		

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	16.11.23 (Yesterday)		17.11.23 (Today)		16.11.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	Gas/Coal/Water Limitation MW	Machines shut down (MW)		
86	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	0	40	43	43	30	GT-1 Under maint.	
87	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	0	0	30	30	90	GT-4 Under maint.	
88	Fenchugonj 51 MW PP (Barakattullah)	Gas (RPP)	19x2.90	51	51	47	47	50	50			
89	Kushiara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0	163	Gas Shortage	
90	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	5	2	2	6	Gas Shortage	
91	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	57	51	62	62			
92	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0	330	Under maint.	
93	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	0	0	0	0	86	Gas Shortage	
94	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	201	205	205	205			
95	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	16	17	17	17	17			
96	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10			
97	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16			
98	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	260	290	300			
99	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	403	362	400	400			
100	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	380	340	350	383			
101	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0	100	Under project work	
102	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12'3.3+5'2	50	50	0	0	0	0	50	Gas Shortage	
Sylhet Zone Total					2472	2427	1435	1353	1475	1518	305	550
103	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0			
104	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0	410	Gas Shortage	
105	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	50			
106	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	70			
107	Khulna 225 MW CCPP	HSD Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0			
108	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	17	109	105	105			
109	Machumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	15	32			
110	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	21	0	100	0			
111	Khulna 115 MW PP (KPCCL-2)	HFO (NENP)	7x17	115	115	0	49	0	16			
112	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5'8.5	40	40	0	0	0	0			
113	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	0	403	400	400			
114	Khulna 330 MW CCPP (GT)	Gas+HSD (BPDB)	1x220+1x116	336	336	0	0	0	0			
**	Bheramara (HVCDC) India			1000	1000	918	918	700	918			
Khulna Zone Total					3241	3237	956	1479	1320	1591	410	0
115	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	16	110			
116	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	12	20	21	25			
117	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	127	80	130	130			
118	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	740	740	1244	1244			
119	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	35	38	150			
120	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	140	140	140	140			
121	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas+HSD (IPP)	2x75+1x70	220	220	109	110	110	110			
Barishal Zone Total					2265	2265	1128	1125	1699	1909	0	0
122	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71	Gas Shortage	
123	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100	Under maint.	
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	0	35			
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0			
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	20			
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	0	40	85			
128	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	30	40			
129	Katakhali 50 MW PP (Northern)	HFO (ORPP)	6x8.9	50	50	0	0	34	42			
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	24	38			
131	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210	Gas Shortage	
132	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220	Gas Shortage	
133	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0	220	Gas Shortage	
134	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	414	280	400	414	134	Gas Shortage	
135	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11			
136	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	0	8	52			
137	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6'18.55	113	113	0	54	35	55			
138	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	50	35	50			
139	Ammura 50 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	0	0	28	28			
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	1	0	6	0			
**	Adani Power Jharkhand Ltd	(Import)	2x748	1496	1496	962	1224	1200	1300			
Rajshahi Zone Total					3653	3631	1388	1619	1851	2170	855	100
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Coal Shortage	
142	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Under Overhauling	
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	170	170	170	170	104	Coal Shortage	
144	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	0	40	40	113			
146	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
147	Majpara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	6	0	8	0	0			
148	Thakurgaon 158MW PP (Energypac)	HFO (IPP)	6'2'20	115	115	0	20	70	115			
149	Lalmohini 30 MW Solar (Intraco)	Solar (IPP)	1 x 30	30	30	33	0	30	0			
150	Tendra Solar Limited	Solar (IPP)	1 x 200	200	200	107	0	130	0			
Rangpur Zone Total					1030	950	316	230	448	398	189	85
Sub-total: Plants in operation					25671	25211	9805	11088	12219	13946	3763	1824
(B) Plants under long term maintenance/ contract expired												
151	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			
152	Bosilla 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			
153	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	0	0	0	0	0			
154	Ashugani 55 MW PP (Precision)	Gas (RPP)	15'4	55	0	0	0	0	0			
Sub-total: Plants under long term maintenance/ contract expired					280	0	0	0	0	0	0	0
Gross Total					25951	25211	9805	11088	12219	13946	3763	1824
(C) Actual data of 16.11.23 (Yesterday) Thursday :												
01.	Max. Demand at eve. peak (Generation end)	:	11088 MW, at =	18:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	10675 MW, at =	18:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	11088 MW, at =	18:00 hrs	Dhaka	4402	4402	0	Mymensingh	757	757	0
04.	Minimum Generation (Generation end)	:	8260 MW, at =	5:00 hrs	Chattogram	1180	1180	0	Sylhet	428	428	0
05.	Day-peak Generation (Generation end)	:	9805 MW, at =	12:00 hrs	Khulna	1094	1094	0	Barishal	277	277	0
06.	Evening-peak Generation (Generation end)	:	11088 MW, at =	18:00 hrs	Rajshahi	941	941	0	Rangpur	657	657	0
07.	Evening Peak Load-shed (Sub-station end)	:	0 MW, at =	18:00 hrs	Cumilla	939	939	0				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	6877 MW, at =	5:00 hrs					Total	10675	10675	0
09.	Generation shortfall at evening peak due to :	:			13.	Fuel cost :	(a) Gas = 112318001 Taka (b) Oil = 158152561 Taka	(c) Coal = 497291758 Taka Total = 767762321 Taka				
	a) Gas/LF limitation	:	3574 MW		14.	Maximum Temperature in Dhaka was :	27.4°C					
	d) Coal supply Limitation	:	189 MW		15.	Export through East-West interconnections :						
	b) Low water level in Kaptai lake	:	0 MW			At evening peak-hour	:	9805 MW, at	18:00 hrs			
	c) Plants under shut down/ maintenance	:	1824 MW			Maximum	:	450 MW, at	7:00 hrs			
	Total Energy (Generation + India Import)	:	233.21 MKWh			Energy	:	0 MKWh				
	By Gas = 111.176 MKWh			By Oil = 12.280 MKWh								
	By Coal = 81.209 MKWh			By Hydro = 3.175 MKWh								
	By Solar = 1.436 MKWh											
11.	Total Gas Supplied	:	790.48 MMCFD									
(D) Forecast of 17.11.23 (Today) Friday :												
01.	Maximum Demand	:	10000 MW (Generation end)		04.	Maximum Load-shed	:	0 MW	At evening peak (Sub-station end)			
02.	Maximum Generation	:	13946 MW (Generation end)		05.	Total Generation	:	210.32 MKWh				
03.	Reserve / Shortage	:	3946 MW (Generation end)		06.	Probable Max. Temperature in Dhaka :	27.4°C					

* Captive Power ** Imported Power
#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation