

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9549567, 9551095

Month November, 2023				Day : Saturday				Date : 18.11.23				
Probable Maximum Demand : 10500 MW				Probable Maximum Generation : 13121 MW				Rule Curve = 10740 ft.				
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 98.79 ft Today = 98.86 ft								
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	17.11.23 (Yesterday)		18.11.23 (Today)		17.11.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)		Description/ Remarks
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0			Gas Shortage
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	160	180	180	180			
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0			
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	72	60	72			
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0			
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	141	297	160	300	63		Gas Shortage
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	170	0	0	225	450		Gas Shortage
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	299	399	360	412	13		Gas Shortage
11	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	160	0	0	200	335		Gas Shortage
13	Meghnaghat 335MW CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0	335		Gas Shortage
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	0	15	25			
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	0	0	80	90			
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	0	18	18			
17	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	19	19	31	31			
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	17	33	33			
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	0	17	25	25			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	0	8	25			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	0	0	30	105			
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	0	0	32	149			
23	Kamalghat 54 MW PP (Barco Energy)	HFO (IPP)	3x18.69	54	54	0	0	0	17			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	0	80	130			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	0	0	17	100			
26	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	0	0	55			
27	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	0	0	35			
28	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	0	0	17	71			
29	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	0	0	17	35			
30	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	13	0	35	0			
31	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	0	17	35			
32	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	0	0	92	92			
33	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	0	0	80	85			
34	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	65	85			
35	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	0	30	30			
36	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			
	Meghnaghat Unique Power	Gas				0	0	0	0			
	Meghnaghat 589 MW CCPP(Summit)	Gas				0	0	0	0			
Dhaka Zone Total			5655	5422	987	1001	1482	2660	1511	375		
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	46	86	86	86			
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	0	0	5	0			
40	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	0	8	17			
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	0	0	20	0			
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	0	6	19			
43	Sikalbaha 105 MW PP (Baraka Sikabaha)	HFO (IPP)	6x18.415	105	105	0	0	17	17			
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150		Under maint.
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	143	188	200	200			
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.94	300	300	0	0	245	245			
47	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	0	0	12	12			
48	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	0	0	0			
49	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	40	50			
50	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	0	8	12	12			
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			2	0	7	10			
51	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0			
52	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	0	17	17			
53	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	0	0	17	17			
54	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	0	0	12	12			
55	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	0	0	12	12			
56	Chattogram 116 MW PP (Anilma Energy Ltd.)	HFO (IPP)	6x21.06	116	116	0	0	17	17			
57	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	0	0	17	17			
58	Chattogram 2*612MW Coal Based PP (SS Powe	Coal (IPP)	2x612	1224	1224	265	400	420	480			
	Matlabari 2*600 MW (CPGCL)	Coal				210	210	560	560			Test run
	Cox's Bazar Wind PP	(Wind) (IPP)				6	6	10	10			Test run
Chattogram Zone Total			3829	3769	672	898	1740	1810	180	330		
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	0	49	51	51			
60	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	0	0	0	0	221		Under Maint.
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	295	0	0	0	360		Gas Shortage
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	310	295	280	300	65		Gas Shortage
63	Ashuganj 420 MW CCPP(East)	Gas (APSCCL)	1x284+1x116	400	400	230	380	350	360	20		Gas Shortage
64	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*16	195	195	0	0	0	0	195		Gas Shortage
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	0	51	51	51			
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	0	12	130			
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	0			
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163		Under maint.
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	0	0	17	17			
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	15	17			
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	0	0	10	11			
72	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	0	0	33	33			
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	0	52	52			
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	0	0	12	12			
75	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	0	17	114			
76	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	0	0	28	55			
77	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	0	0	17	17			
78	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	0	0	34	95			
**	Impootti (Tripura)	India		160	160	58	32	128	140			
Cumilla Zone Total			2904	2896	893	807	1107	1455	640	384		
79	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	32	101	100	100	101		Gas Shortage
80	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0			
81	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	0	0	47	85			
82	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	0	0	84	100			
83	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0			
84	Sutiakehal 50 MW Solar PP	Solar (IPP)	1x50	50	50	24	0	50	0			
85	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	0	0	6	6			
Mymensingh Zone Total			622	614	57	101	289	291	101	0		

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	17.11.23 (Yesterday)		18.11.23 (Today)		17.11.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	Gas/Coal/Water Limitation MW	Machines shut down (MW)		
86	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	35	43	43	43		27	GT-1 Under maint.
87	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	0	0	0	0		90	GT-4 Under maint.
88	Fenchugonj 51 MW PP (Barakattullah)	Gas (RPP)	19x2.90	51	51	0	50	50	50			
89	Kushiara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0	163		Gas Shortage
90	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	2	2	11		Gas Shortage
91	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	20	32	32	32		330	Under maint.
92	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0			Gas Shortage
93	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	0	0	0	0	86		
94	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	190	194	200	200			
95	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	0	18	17	18			
96	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	0	10	10	10			
97	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	0	0	16	16	25		Gas Shortage
98	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	295	280	290	300			
99	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	365	367	400	400			
100	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	285	400	350	383			
101	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0	100		Under project work
102	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12'3.3+5'2	50	50	0	0	0	0	50		Gas Shortage
Sylhet Zone Total					2472	2427	1190	1394	1410	1454	335	547
103	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0			
104	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0	410		Gas Shortage
105	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	50			
106	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	70			
107	Khulna 225 MW CCPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0			
108	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	0	105	105			
109	Machumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	15	32			
110	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	4	0	100	0			
111	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	0	0	66			
112	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5'8.5	40	40	0	0	0	0			
113	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	355	408	400	400			
114	Khulna 330 MW CCPP (GT)	Gas/HSD (BPDB)	1x220+1x116	336	336	0	0	0	0			
**	Bheramara (HVCDC) India			1000	1000	675	333	700	918			
Khulna Zone Total					3241	3237	1034	741	1320	1641	410	0
115	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	16	110			
116	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	9	3	21	25			
117	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	60	0	130	130			
118	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	500	490	622	622			
119	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	38	150			
120	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	140	0	140	140			
121	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	110	110	110	110			
Barishal Zone Total					2265	2265	819	603	1077	1287	0	0
122	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage
123	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Under maint.
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	0	35			
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0			
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	20			
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	0	40	85			
128	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	30	40			
129	Katakhali 50 MW PP (Northern)	HFO (ORPP)	6x8.9	50	50	0	0	34	42			
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	24	38			
131	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage
132	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage
133	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0	220		Gas Shortage
134	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	250	370	400	414	44		Gas Shortage
135	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	0	0	11	11			
136	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	0	8	52			
137	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6'18.55	113	113	0	0	35	55			
138	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	0	35	50			
139	Ammura 50 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	0	0	28	28			
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	2	0	0	6	0			
**	Adani Power Jharkhand Ltd	(Import)	2x748	1496	1496	816	812	1200	1300			
Rajshahi Zone Total					3653	3631	1068	1182	1851	2170	765	100
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage
142	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Under Overhauling
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	170	170	170	170	104		Coal Shortage
144	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	0	0	40	113			
146	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
147	Majpara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	5	0	0	8	0			
148	Thakurgaon 118MW PP (Energypac)	HFO (IPP)	6'20	115	115	0	0	70	70			
149	Lalmohini 30 MW Solar (Intraco)	Solar (IPP)	1'30	30	30	20	0	30	0			
150	Tendra Solar Limited	Solar (IPP)	1 x 200	200	200	193	0	130	0			
Rangpur Zone Total					1030	950	378	170	448	353	189	85
Sub-total: Plants in operation					25671	25211	7098	6897	10724	13121	4131	1821
(B) Plants under long term maintenance/ contract expired												
151	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			
152	Bosilla 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			
153	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	0	0	0	0	0			
154	Ashugani 55 MW PP (Precision)	Gas (RPP)	15'4	55	0	0	0	0	0			
Sub-total: Plants under long term maintenance/ contract expired					280	0	0	0	0	0	0	0
Gross Total					25951	25211	7098	6897	10724	13121	4131	1821
(C) Actual data of 17.11.23 (Yesterday) Friday :												
01.	Max. Demand at eve. peak (Generation end)	:	6897 MW, at =	21:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	6620 MW, at =	21:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	8827 MW, at =	1:00 hrs	Dhaka	2780	2780	0	Mymensingh	619	619	0
04.	Minimum Generation (Generation end)	:	6845 MW, at =	9:00 hrs	Chattogram	709	709	0	Sylhet	153	153	0
05.	Day-peak Generation (Generation end)	:	7098 MW, at =	12:00 hrs	Khulna	845	845	0	Barishal	69	69	0
06.	Evening-peak Generation (Generation end)	:	6897 MW, at =	21:00 hrs	Rajshahi	822	822	0	Rangpur	523	523	0
07.	Evening Peak Load-shed (Sub-station end)	:	0 MW, at =	21:00 hrs	Cumilla	100	100	0				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	5719 MW, at =	5:00 hrs					Total	6620	6620	0
09.	Generation shortfall at evening peak due to :	:			13.	Fuel cost :	(a) Gas = 85007124 Taka (b) Oil = 3359823 Taka	(c) Coal = 413305865 Taka Total = 501672812 Taka				
a)	Gas/LF limitation	:	3942 MW		14.	Maximum Temperature in Dhaka was :	22.6°C					
d)	Coal supply Limitation	:	189 MW		15.	Export through East-West interconnections :						
b)	Low water level in Kaptai lake	:	0 MW		At evening peak-hour	:	7098 MW, at	21:00 hrs				
c)	Plants under shut down/ maintenance	:	1821 MW		Maximum	:	160 MW, at	17:00 hrs				
10.	Total Energy (Generation + India Import)	:	167.05 MKWh		Energy	:	0 MKWh					
	By Gas = 86.753 MKWh		By Oil = 0.263 MKWh									
	By Coal = 63.907 MKWh		By Hydro = 1.523 MKWh									
	By Solar = 1.443 MKWh											
11.	Total Gas Supplied	:	631.22 MMCFD									
(D) Forecast of 18.11.23 (Today) Saturday :												
01.	Maximum Demand	:	10500 MW (Generation end)		04.	Maximum Load-shed	:	0 MW At evening peak (Sub-station end)				
02.	Maximum Generation	:	13121 MW (Generation end)		05.	Total Generation	:	198.71 MKWh				
03.	Reserve / Shortage	:	2621 MW (Generation end)		06.	Probable Max. Temperature in Dhaka :	22.6°C					

* Captive Power ** Imported Power
#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation