

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9546667, 9551095

Month November, 2023				Day : Sunday				Date : 19.11.23				
Probable Maximum Demand : 11500 MW				Probable Maximum Generation : 13270 MW								
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 98.86 ft				Today = 98.97 ft				
				Rule Curve = 107.20 ft								
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	18.11.23 (Yesterday)		19.11.23 (Today)		18.11.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW			
					Day	Evening	Day	Evening	Machines shut down (MW)			
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0			Gas Shortage
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180			
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0			
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	72	77	77	77			
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0			
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	343	342	300	330			
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	0	225	225	225	225		Gas Shortage
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	406	403	380	412			
11	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	203	186	0	0			
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335		Gas Shortage
13	Meghnaghat 335MW CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0	335		Gas Shortage
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	25	15	25			
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	0	66	80	90			
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	16	18	18			
17	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	21	33	32	32			
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	30	33	33			
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	16	25	25	25			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	25	8	25			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	35	88	30	105			
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	16	98	32	149			
23	Kamalghat 54 MW PP (Barco Energy)	HFO (IPP)	3x18.69	54	54	0	17	0	17			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	82	80	130			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	17	21	17	100			
26	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	15	0	55			
27	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	35	0	35			
28	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	0	60	26	71			
29	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	0	54	17	54			
30	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	32	0	35	0			
31	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	34	17	35			
32	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	0	62	92	92			
33	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	0	54	80	85			
34	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	85	65	85			
35	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	37	30	40			
36	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			
	Meghnaghat Unique Power	Gas			0	0	0	0	0			
	Meghnaghat 589 MW CCPP(Summit)	Gas			0	0	0	0	0			
Dhaka Zone Total				5655	5422	1374	2375	1894	2525	1000	375	
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	86	86	86	86			
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	1	0	5	0			
40	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	15	8	17			
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	11	0	20	0			
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	15	6	19			
43	Sikalbaha 105 MW PP (Baraka Sikabaha)	HFO (IPP)	6x18.415	105	105	0	17	17	17			
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	195	0	200	200			
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.94	300	300	0	160	245	245			
47	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	6	12	12	12			
48	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	0	0	0			
49	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	58	40	70			
50	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	12	12	12	12			
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			0	0	7	10			
51	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0			
52	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	17	17	17			
53	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	0	17	17	17			
54	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	12	12	12	12			
55	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	12	12	12	12			
56	Chattogram 116 MW PP (Anilma Energy Ltd.)	HFO (IPP)	6x21.06	116	116	0	17	17	17			
57	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	0	17	17	17			
58	Chattogram 2*612MW Coal Based PP (SS Powe	Coal (IPP)	2x612	1224	1224	330	500	450	500			
	Matlabari 2*600 MW (CPGCL)	Coal				449	0	0	0			Test run
	Cox's Bazar Wind PP	(Wind) (IPP)				0	0	10	10			Test run
Chattogram Zone Total				3829	3769	1114	967	1210	1290	180	330	
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	47	51	51	51			
60	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	0	0	0	0		221	Under Maint.
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	0	0	0	0	360		Gas Shortage
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	310	305	305	300			
63	Ashuganj 420 MW CCPP(East)	Gas (APSCCL)	1x284+1x116	400	400	380	390	350	360			
64	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*116	195	195	0	11	8	11	184		Gas Shortage
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	34	51	51	51			
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	102	100	150			
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	0			
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0		163	Under maint.
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	1	17	17	17			
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	8	18	15	18			
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	0	0	10	11			
72	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	0	8	33	33			
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	40	52	52			
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	0	0	12	12			
75	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	17	17	114			
76	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	0	57	28	55			
77	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	0	17	17	17			
78	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	0	87	34	95			
**	Impoort (Tripura)	India		160	160	92	118	128	140			
Cumilla Zone Total				2904	2896	872	1289	1228	1487	544	384	
79	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	109	72	100	100	130		Gas Shortage
80	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0			
81	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	3	75	56	85			
82	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	17	104	84	104			
83	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
84	Sutakhalai 50 MW Solar PP	Solar (IPP)	1x50	50	50	53	0	50	0			
85	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	0	6	6	6			
Mymensingh Zone Total				622	614	184	257	298	295	130	0	

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	18.11.23 (Yesterday)		19.11.23 (Today)		18.11.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	Gas/Coal/Water Limitation MW	Machines shut down (MW)		
86	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	42	43	43	43	27	GT-1 Under maint.	
87	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	0	30	30	30	60	GT-4 Under maint.	
88	Fenchugonj 51 MW PP (Barakattullah)	Gas (RPP)	19x2.90	51	51	46	50	50	50			
89	Kushiara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0	163	Gas Shortage	
90	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	2	5	5	5	6	Gas Shortage	
91	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	31	32	32	32			
92	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0	330	Under maint.	
93	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	0	0	0	0	86	Gas Shortage	
94	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	195	195	200	200			
95	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	17	17	17	17	17			
96	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10			
97	Shahjibazar 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	8	16	16	17	Gas Shortage	
98	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	310	300	290	300			
99	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	396	402	400	400			
100	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	400	400	350	400			
101	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0	100	Under project work	
102	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	0	0	0	0	50	Gas Shortage	
Sylhet Zone Total					2472	2427	1465	1492	1443	1503	322	517
103	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0			
104	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0	410	Gas Shortage	
105	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	29	0	50			
106	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	11	0	70			
107	Khulna 225 MW CCPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0			
108	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	0	105	105			
109	Machumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	32	15	32			
110	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	90	0	100	0			
111	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	66	16	66			
112	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	16	0	16			
113	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	353	601	450	600			
114	Khulna 330 MW CCPP (GT)	Gas/HSD (BPDB)	1x220+1x116	336	336	0	0	0	0			
**	Bheramara (HVCDC) India		1000	1000	811	557	700	918				
Khulna Zone Total					3241	3237	1254	1312	1386	1857	410	0
115	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	10	16	110			
116	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	7	8	21	25			
117	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	65	105	130	130			
118	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	370	622	622	1220			
119	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	81	38	150			
120	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	0	0	0	0			
121	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	110	110	110	110			
Barishal Zone Total					2265	2265	552	936	937	1745	0	0
122	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71	Gas Shortage	
123	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100	Under maint.	
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	0	35			
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0			
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	20			
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	43	40	85			
128	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	30	40			
129	Katakhali 50 MW PP (Northern)	HFO (ORPP)	6x8.9	50	50	0	25	34	42			
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	20	24	38			
131	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210	Gas Shortage	
132	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220	Gas Shortage	
133	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0	220	Gas Shortage	
134	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	414	414	400	414			
135	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11			
136	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	52	8	52			
137	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.65	113	113	35	75	35	75			
138	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.65	113	113	0	50	35	50			
139	Amnura 50 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	0	0	28	28			
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	5	5	0	6	0			
**	Adani Power Jharkhand Ltd	(Import)	2x748	1496	1496	813	946	1200	1300			
Rajshahi Zone Total					3653	3631	1275	1636	1851	2190	721	100
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Coal Shortage	
142	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Under Overhauling	
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	170	170	170	170	104	Coal Shortage	
144	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	93	70	40	113			
146	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
147	Majpara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	6	0	8	0	0			
148	Thakurgaon 158MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	90	70	90			
149	Lalmoshai 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	36	0	30	0			
150	Tendra Solar Limited	Solar (IPP)	1 x 200	200	200	193	0	130	0			
Rangpur Zone Total					1030	950	498	330	448	373	189	85
Sub-total: Plants in operation					25671	25211	8588	10594	10695	13265	3496	1791
(B) Plants under long term maintenance/ contract expired												
151	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			
152	Bosilla 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			
153	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	0	0	0	0	0			
154	Ashugani 55 MW PP (Precision)	Gas (RPP)	15*4	55	0	0	2	5	5			
Sub-total: Plants under long term maintenance/ contract expired					280	0	2	5	5	0	0	
Gross Total					25951	25211	8588	10596	10700	13270	3496	1791
(C) Actual data of 18.11.23 (Yesterday) Saturday :												
01.	Max. Demand at eve. peak (Generation end)	:	10596 MW, at =	18:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	10100 MW, at =	18:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	10596 MW, at =	18:00 hrs	Dhaka	4108	4108	0	Mymensingh	783	783	0
04.	Minimum Generation (Generation end)	:	5719 MW, at =	5:00 hrs	Chattogram	1067	1067	0	Sylhet	387	387	0
05.	Day-peak Generation (Generation end)	:	8588 MW, at =	12:00 hrs	Khulna	1170	1170	0	Barishal	229	229	0
06.	Evening-peak Generation (Generation end)	:	10596 MW, at =	18:00 hrs	Rajshahi	982	982	0	Rangpur	694	694	0
07.	Evening Peak Load-shed (Sub-station end)	:	0 MW, at =	18:00 hrs	Cumilla	681	681	0				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	7338 MW, at =	5:00 hrs					Total	10100	10100	0
09.	Generation shortfall at evening peak due to :	:			13.	Fuel cost :	(a) Gas = 97189534 Taka (b) Oil = 229742611 Taka	(c) Coal = 393376427 Taka Total = 726308572 Taka				
10.	Total Energy (Generation + India Import)	:	195.63 MKWh		14.	Maximum Temperature in Dhaka was :	29.4°C					
	By Gas = 96.373 MKWh		By Oil = 17.862 MKWh		15.	Export through East-West interconnections :						
	By Coal = 58.379 MKWh		By Hydro = 1.900 MKWh			At evening peak-hour :	8588 MW, at 18:00 hrs					
	By Solar = 2.596 MKWh					Maximum :	230 MW, at 1:00 hrs					
11.	Total Gas Supplied	:	769.98 MMCFD			Energy :	0 MKWh					
(D) Forecast of 19.11.23 (Today) Sunday :												
01.	Maximum Demand	:	11500 MW (Generation end)		04.	Maximum Load-shed	:	0 MW At evening peak (Sub-station end)				
02.	Maximum Generation	:	13270 MW (Generation end)		05.	Total Generation	:	212.32 MKWh				
03.	Reserve / Shortage	:	1770 MW (Generation end)		06.	Probable Max. Temperature in Dhaka :	34.6°C					

#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation