

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9546667, 9551095

Month November, 2023					Day : Monday					Date : 20.11.23				
Probable Maximum Demand : 11500 MW					Probable Maximum Generation : 13360 MW									
Water Level of Kapitai Lake at 06:00 AM					Yesterday = 98.97 ft					Today = 99.09 ft				
					Rule Curve = 107.10 ft									
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	19.11.23 (Yesterday)		20.11.23 (Today)		19.11.23 (Yesterday)		20.11.23 (Today)			
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Status of Machines under shut-down/ Maintenance			
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date		
(A) Plants in operation:														
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work		
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0			Gas Shortage		
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180					
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0					
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	73	77	77	77					
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage		
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0					
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	303	313	300	330					
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	170	225	225	225	225		Gas Shortage		
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling		
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	332	344	400	412					
11	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage		
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335		Gas Shortage		
13	Meghnaghat 335MW CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0	335		Gas Shortage		
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	15	15	30					
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	0	24	100	100					
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	14	14	18	18					
17	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	31	35	32	32					
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	30	33	33					
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	25	25					
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	25	8	25					
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	35	105	30	105					
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	32	82	16	149					
23	Kamalghat 54 MW PP (Barco Energy)	HFO (IPP)	3x18.69	54	54	0	54	0	17					
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	80	90	80	130					
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	5	46	18	100					
26	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	35	0	35					
27	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	17	0	35					
28	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	53	68	26	71					
29	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	17	35	35	35					
30	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	11	0	35	0					
31	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	17	17	35					
32	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	41	40	92	92					
33	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	8	34	92	92					
34	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	95	65	85	85					
35	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	25	30	40					
36	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0					
	Meghnaghat Unique Power	Gas			0	0	0	0	0					
	Meghnaghat 589 MW CCPP(Summit)	Gas			0	0	0	0	0					
Dhaka Zone Total			5655	5422	1553	2020	1969	2508	1210	375				
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	121	121	121	121					
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage		
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.		
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	1	0	5	0					
40	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	13	8	17					
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	19	0	20	0					
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	19	6	19					
43	Sikalbaha 105 MW PP (Baraka Sikabaha)	HFO (IPP)	6x18.415	105	105	17	17	17	17					
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150		Under maint.		
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	208	208	210	210					
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.94	300	300	70	135	245	245					
47	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	12	12	12	12					
48	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	0	0	0					
49	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	40	65	40	70					
50	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	12	12	12	12					
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			0	2	7	10					
51	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0					
52	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	17					
53	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	17	17	17					
54	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	12	12	12	12					
55	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	12	12	12	12					
56	Chattogram 116 MW PP (Anilma Energy Ltd.)	HFO (IPP)	6x21.06	116	116	18	34	17	17					
57	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	0	26	17	17					
58	Chattogram 2*612MW Coal Based PP (SS Powe	Coal (IPP)	2x612	1224	1224	470	490	500	500					
	Matlabari 2*600 MW (CPGCL)	Coal				18	560	180	600			Test run		
	Cox's Bazar Wind PP	(Wind) (IPP)				0	0	10	10			Test run		
Chattogram Zone Total			3829	3769	1070	1772	1485	1935	180	330				
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	47	47	50	50					
60	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	0	0	0	0	221		Under Maint.		
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	0	0	0	0	360		Gas Shortage		
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	305	310	300	300					
63	Ashuganj 420 MW CCPP(East)	Gas (APSCCL)	1x284+1x116	400	400	360	360	360	360					
64	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*116	195	195	45	16	16	16	179		Gas Shortage		
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	51	51	51					
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	97	117	100	150					
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	0					
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163		Under maint.		
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	17	17	17					
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	18	18	18					
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	5	8	10	11					
72	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	25	33	33	33					
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	9	52	52					
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	6	6	12	12					
75	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	17	17	114					
76	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	28	66	28	68					
77	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	13	17	17					
78	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	18	63	18	96					
**	Import (Tripura)	India		160	160	122	132	128	140					
Cumilla Zone Total			2904	2896	1153	1283	1227	1505	539	384				
79	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	34	35	35	45	167		Gas Shortage		
80	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0					
81	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	59	75	56	85					
82	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	58	105	84	104					
83	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0					
84	Sutiakehal 50 MW Solar PP	Solar (IPP)	1x50	50	50	53	0	50	0					
85	Tangail 22 MW PP(PPLGL)	HFO (IPP)	4x6.7	22	22	6	6	6	6					
Mymensing Zone Total			622	614	211	221	233	240	167	0				

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	19.11.23 (Yesterday)		20.11.23 (Today)		19.11.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	Gas/Coal/Water Limitation MW	Machines shut down (MW)		
86	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 Under maint.
87	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	28	20	20	20		70	GT-4 Under maint.
88	Fenchugonj 51 MW PP (Barakattullah)	Gas (RPP)	19x2.90	51	51	47	50	50	50			
89	Kushiara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0	163		Gas Shortage
90	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	5	5	5	6		Gas Shortage
91	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	30	32	32	32			
92	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.
93	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	0	0	0	0	86		Gas Shortage
94	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	198	193	200	200			
95	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	16	17	17	17			
96	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10			
97	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	12	16	16	13		Gas Shortage
98	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	290	270	310	310			
99	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	399	377	400	400			
100	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	388	380	400	400			
101	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work
102	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12'3.3+5'2	50	50	0	0	0	0	50		Gas Shortage
Sylhet Zone Total					2472	2427	1470	1503	1503	318	527	
103	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0			
104	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0	410		Gas Shortage
105	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	36	0	50			
106	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	41	0	70			
107	Khulna 225 MW CCPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0			
108	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	87	35	105	105			
109	Machumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	15	32			
110	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	43	0	100	0			
111	Khulna 115 MW PP (KPCCL-2)	HFO (NENP)	7x17	115	115	32	32	32	32			
112	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5'8.5	40	40	0	16	0	16			
113	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	366	513	300	600			
114	Khulna 330 MW CCPP (GT)	Gas/HSD (BPDB)	1x220+1x116	336	336	0	0	0	0			
**	Bheramara (HVCDC) India			1000	1000	918	879	918	918			
Khulna Zone Total					3241	3237	1446	1552	1470	1823	410	0
115	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	16	16	110			
116	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	16	21	21	25			
117	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	130	100	100	130			
118	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	570	910	400	1220			
119	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	35	38	150			
120	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	0	0	0	0			
121	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	110	110	110	110			
Barishal Zone Total					2265	2265	843	1192	685	1745	0	0
122	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage
123	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	0	35			
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0			
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	20			
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	51	40	85			
128	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	30	40			
129	Katakhal 50 MW PP (Northern)	HFO (ORPP)	6x8.9	50	50	0	8	34	42			
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	38	24	38			
131	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage
132	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage
133	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0	220		Gas Shortage
134	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	368	290	414	414	124		Gas Shortage
135	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11			
136	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	8	8	52			
137	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6'18.55	113	113	35	35	55	113			
138	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	38	50	50			
139	Ammura 50 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	0	0	28	28			
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0			
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	862	818	800	800			
Rajshahi Zone Total					3653	3631	1316	1297	1500	1728	845	100
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage
142	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Under Overhauling
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	170	170	170	170	104		Coal Shortage
144	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	34	55	34	113			
146	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
147	Majpara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	6	0	8	0			
148	Thakurgaon 158MW PP (Energypac)	HFO (IPP)	6'20	115	115	55	54	70	90			
149	Lalmoshai 30 MW Solar (Intraco)	Solar (IPP)	1x30	30	30	37	0	30	0			
150	Tendra Solar Limited	Solar (IPP)	1 x 200	200	200	188	0	130	0			
Rangpur Zone Total					1030	950	490	279	442	373	189	85
Sub-total: Plants in operation					25671	25211	9552.0	11025	10514	13360	3858	1801
(B) Plants under long term maintenance/ contract expired												
149	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			
150	Bosilia 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			
151	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	0	0	0	0	0			
152	Ashugani 55 MW PP (Precision)	Gas (RPP)	15'4	55	0	5	8	0	0			
Sub-total: Plants under long term maintenance/ contract expired					280	0	5	8	0	0	0	0
Gross Total					25951	25211	9557	11033	10514	13360	3858	1801
(C) Actual data of 19.11.23 (Yesterday) Sunday :												
01.	Max. Demand at eve. peak (Generation end)	:	11033 MW, at =	18:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	10661 MW, at =	18:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	11033 MW, at =	18:00 hrs	Dhaka	4270	4270	0	Mymensingh	844	844	0
04.	Minimum Generation (Generation end)	:	7338 MW, at =	5:00 hrs	Chattogram	1106	1106	0	Sylhet	414	414	0
05.	Day-peak Generation (Generation end)	:	9557 MW, at =	12:00 hrs	Khulna	1228	1228	0	Barishal	281	281	0
06.	Evening-peak Generation (Generation end)	:	11033 MW, at =	18:00 hrs	Rajshahi	998	998	0	Rangpur	669	669	0
07.	Evening Peak Load-shed (Sub-station end)	:	0 MW, at =	18:00 hrs	Cumilla	851	851	0				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	7592 MW, at =	5:00 hrs					Total	10661	10661	0
09.	Generation shortfall at evening peak due to :	:			13.	Fuel cost :	(a) Gas = 105387549 Taka (b) Oil = 260310715 Taka	(c) Coal = 440925927 Taka Total = 806624191 Taka				
a)	Gas/LF limitation	:	3669 MW		14.	Maximum Temperature in Dhaka was :	30.2°C					
d)	Coal supply Limitation	:	189 MW		15.	Export through East-West interconnections :						
b)	Low water level in Kaptai lake	:	0 MW		At evening peak-hour	:	9557 MW, at	18:00 hrs				
c)	Plants under shut down/ maintenance	:	1801 MW		Maximum	:	310 MW, at	7:00 hrs				
10.	Total Energy (Generation + India Import)	:	221.75 MKWh		Energy	:	0 MKWh					
	By Gas = 106.291 MKWh		By Oil = 19.833 MKWh									
	By Coal = 68.711 MKWh		By Hydro = 2.315 MKWh									
	By Solar = 2.644 MKWh											
11.	Total Gas Supplied	:	759.80 MMCFD									
(D) Forecast of 20.11.23 (Today) Monday :												
01.	Maximum Demand	:	11500 MW (Generation end)		04.	Maximum Load-shed	:	0 MW At evening peak (Sub-station end)				
02.	Maximum Generation	:	13360 MW (Generation end)		05.	Total Generation	:	231.14 MKWh				
03.	Reserve / Shortage	:	1860 MW (Generation end)		06.	Probable Max. Temperature in Dhaka :	:	30.2°C				

* Captive Power ** Imported Power
#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation