

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 3564667, 3551095

Month November, 2023					Day : Sunday					Date : 26.11.23				
Probable Maximum Demand : 11000 MW					Probable Maximum Generation : 13406 MW									
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 98.58 ft		Today = 98.50 ft		Rule Curve = 106.50 ft					
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	25.11.23 (Yesterday)		26.11.23 (Today)		25.11.23 (Yesterday)		26.11.23 (Today)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW		Machines shut down (MW)			
					Day	Evening	Day	Evening						
(A) Plants in operation:														
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0			260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0				Gas Shortage	
3	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180					
4	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0					
5	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	39	70	77	77					
6	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0			105	Gas Shortage	
7	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0					
8	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	291	341	330	330					
9	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	170	225	225	225			225	Gas Shortage	
10	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0			115	Under Overhauling	
11	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	363	392	412	412					
12	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0			210	Gas Shortage	
13	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	280	335	335	335					
14	Meghnaghat 335MW CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0			335	Gas Shortage	
15	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	15	15	30					
16	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	0	0	100	100					
17	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	12	0	18	18					
18	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	31	32	38	38					
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	0	33	33	33					
20	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	33	33					
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	20	8	25					
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	17	88	30	105					
23	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	0	32	16	149					
24	Kamalaghat 54 MW PP (Barco Energy)	HFO (IPP)	3x18.69	54	54	0	35	0	35					
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	40	80	130					
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	0	0	18	100					
27	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	17	0	35					
28	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	35	0	35					
29	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	0	68	26	88					
30	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	0	72	17	35					
31	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	0	0	35	0					
32	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	34	17	35					
33	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	0	15	92	92					
34	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	0	13	92	100					
35	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	10	85	85					
36	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	0	30	40					
37	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0					
38	Meghnaghat Unique Power	Gas				0	0	0	0					
39	Meghnaghat 589 MW CCPP(Summit)	Gas				0	0	0	0					
Dhaka Zone Total					5655	5422	1408	2127	2342	2900	875	375		
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	46	46	46	46					
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0			180	Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0			180	Under maint.	
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0					
40	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	11	8	17					
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	20	0	20	0					
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	19	6	10					
43	Sikalbaha 105 MW PP (Baraka Sikabaha)	HFO (IPP)	6x18.415	105	105	0	17	17	17					
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0			150	Under maint.	
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	216	214	212	212					
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.94	300	300	0	80	260	260					
47	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	0	12	12	12					
48	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	0	0	0					
49	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	40	64					
50	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	12	12	12	12					
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			0	0	10	25					
51	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0					
52	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	17	17	17					
53	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	10	17	17	17					
54	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	0	0	12	12					
55	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	0	12	12	12					
56	Chattogram 116 MW PP (Anilma Energy Ltd.)	HFO (IPP)	6x21.06	116	116	12	17	17	17					
57	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	18	17	0	0					
58	Chattogram 2*612MW Coal Based PP (SS Powe	Coal (IPP)	2x612	1224	1224	400	500	400	500					
	Matlabari 2*600 MW (CPGCL)	Coal				0	0	0	300				Test run	
	Cox's Bazar Wind PP	(Wind) (IPP)				1	4	10	10				Test run	
Chattogram Zone Total					3829	3769	739	995	1133	1560	180	330		
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	47	46	51	51					
60	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	0	0	0	0			221	Under Maint.	
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	0	0	0	0			360	Under Maint.	
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	345	280	320	320					
63	Ashuganj 420 MW CCPP(East)	Gas (APSCCL)	1x284+1x116	400	400	300	395	395	395					
64	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*116	195	195	8	102	55	102			93	Gas Shortage	
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	5	51	51	51					
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	36	150	150					
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	0					
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0			163	Under maint.	
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	10	17	17	17					
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	7	16	18	18					
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11					
72	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33					
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	31	52	52					
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	6	8	10	10					
75	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	42	114	114					
76	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	8	46	28	65					
77	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17					
78	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	0	60	36	72					
**	Imphott (Tripura)	India		160	160	116	104	128	140					
Cumilla Zone Total					2904	2896	913	1295	1486	1618	93	744		
79	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	84	94	80	90			108	Gas Shortage	
80	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0					
81	Jamailpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	8	56	56	85					
82	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	16	112	84	104					
83	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0					
84	Suliakhali 50 MW Solar PP	Solar (IPP)	1x50	50	50	47	0	50	0					
85	Tangail 22 MW PP(PDGL)	HFO (IPP)	4x6.7	22	22	0	6	6	6					
Mymensingh Zone Total					622	614	157	268	278	285	108	0		

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	25.11.23 (Yesterday)		26.11.23 (Today)		25.11.23 (Yesterday)		Status of Machines under shut-down/ Maintenance				
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date			
						Day	Evening	Day	Evening							
86	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 Under maint.				
87	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	26	26	28	28		64	GT-4 Under maint.				
88	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	0	0	0	0	51		Gas Shortage				
89	Kushara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0	163		Gas Shortage				
90	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	2	0	5	5	11		Gas Shortage				
91	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	0	0	0	0							
92	Shajibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.				
93	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	78	40	40	40	46		Gas Shortage				
94	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	196	197	200	200							
95	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	16	17	17	17							
96	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10							
97	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	16	16	16	9		Gas Shortage				
98	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	290	305	310	310							
99	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	402	402	400	400							
100	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	390	400	400	400							
101	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work				
102	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	0	35	44	44							
Sylhet Zone Total						2472	2427	1461	1491	1513	280	521				
103	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0							
104	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0	410		Gas Shortage				
105	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	0	50						
106	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	0	70						
107	Khulna 225 MW CCPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0							
108	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	8x18.445	105	105	0	17	105	105							
109	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	15	32							
110	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	74	0	100	0							
111	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	16	32	48							
112	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	0	0	16							
113	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	352	604	450	550							
114	Khulna 330 MW CCPP (GT)	Gas/HSD (BPDB)	1x220+1x116	336	336	0	0	0	0							
**	Bheramara (HVCDC) India			1000	1000	447	354	453	453							
Khulna Zone Total						3241	3237	873	991	1155	1324	410	0			
115	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	16	110							
116	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	14	18	21	25							
117	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	50	50	130	130							
118	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	600	1190	1000	1220							
119	Potukhalhi 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	45	0	150							
120	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	140	200	150	200							
121	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	110	110	110	110							
Barishal Zone Total						2265	2265	914	1613	1427	1945	0	0			
122	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage				
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Under maint.				
123	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	0	0	35						
124	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0							
125	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	20							
126	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	0	40	85							
127	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	30	40							
128	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	34	42							
129	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	38							
130	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage				
131	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	0	0	0	0	220		Gas Shortage				
132	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0	220		Gas Shortage				
133	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	300	414	414	414	0		Gas Shortage				
134	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	11	11							
135	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	0	52	52							
136	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	100	35	113							
137	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	69	35	50							
138	Ammura 50 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	0	0	28	28							
139	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0							
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	822	819	850	900							
Rajshahi Zone Total						3653	3631	1135	1410	1535	1828	721	100			
140	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage				
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Under Overhauling				
141	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	170	170	170	170	104		Coal Shortage				
142	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0							
143	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	113	111	113	113							
144	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0							
145	Majpara, Talsila 9 MW Solar PP (Sympha Power)	Solar (IPP)	1 x 8	8	8	5	0	8	0							
146	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	70	70	110							
147	Lalmohitha 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	34	0	30	0							
148	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	177	0	130	0							
Rangpur Zone Total						1030	950	499	351	521	393	189	85			
Sub-total: Plants in operation						25671	25211	8099.0	10541	11390	13366	2856	2155			
(B) Plants under long term maintenance/ contract expired																
149	Jamulpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0							
150	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0							
151	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	0	0	0	0	0							
152	Ashugani 55 MW PP (Precision)	Gas (RPP)	15*4	55	0	41	42	40	40							
Sub-total: Plants under long term maintenance/ contract expired						280	41	42	40	40	0	0				
Gross Total						25951	25211	8140	10583	11430	13406	2856	2155			
(C) Actual data of 25.11.23 (Yesterday) Saturday :																
01.	Max. Demand at eve. peak (Generation end)	:	10583	MW, at =	18:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :										
02.	Max. Demand at eve. peak (Sub-station end)	:	10154	MW, at =	18:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed			
03.	Highest Generation (Generation end)	:	10583	MW, at =	18:00 hrs		MW	MW	MW		MW	MW	MW			
04.	Minimum Generation (Generation end)	:	6700	MW, at =	5:00 hrs	Dhaka	3890	3890	0	Mymensingh	812	812	0			
05.	Day-peak Generation (Generation end)	:	8140	MW, at =	12:00 hrs	Chattogram	1073	1073	0	Sylhet	413	413	0			
06.	Evening-peak Generation (Generation end)	:	10583	MW, at =	18:00 hrs	Khulna	1142	1142	0	Barishal	282	282	0			
07.	Evening Peak Load-shed (Sub-station end)	:	0	MW, at =	18:00 hrs	Rajshahi	948	948	0	Rangpur	707	707	0			
08.	Minimum Generation Forecast up to 8:00 hrs.	:	7092	MW, at =	5:00 hrs	Cumilla	887	887	0							
09.	Generation shortfall at evening peak due to :	:				Total						10154	10154	0		
a)	Gas/LF limitation	:	2667	MW		13. Fuel cost :										
d)	Coal supply Limitation	:	189	MW		(a) Gas =	109498154	Taka	(c) Coal =	501307483	Taka					
b)	Low water level in Kaptai lake	:	0	MW		(b) Oil =	142127087	Taka	Total =	752932725	Taka					
c)	Plants under shut down/ maintenance	:	2155	MW		14. Maximum Temperature in Dhaka was :								30.1°C		
10.	Total Energy (Generation + India Import)	:	202.70	MKWh		15. Export through East-West interconnections :										
	By Gas =	109.493	MKWh	By Oil =	10.979	At evening peak-hour :								8140	MW, at	18:00 hrs
	By Coal =	66.194	MKWh	By Hydro =	1.115	Maximum :								216	MW, at	22:00 hrs
	By Solar=	2.330	MKWh			Energy :								0.0165	MKWh	
11. Total Gas Supplied						:	814.34	MMCFD								
(D) Forecast of 26.11.23 (Today) Sunday :																
01.	Maximum Demand	:	11000	MW	(Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)					
02.	Maximum Generation	:	13406	MW	(Generation end)	05.	Total Generation	:	210.69	MKWh						
03.	Reserve / Shortage	:	2406	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	:	30.1°C							

* Captive Power ** Imported Power
#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation