

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9364667, 9551095

Month November, 2023					Day : Monday					Date : 27.11.23				
Probable Maximum Demand : 11000 MW					Probable Maximum Generation : 13772 MW					Rule Curve = 106.50 ft.				
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 98.50 ft					Today = 98.43 ft.				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	26.11.23 (Yesterday)		27.11.23 (Today)		26.11.23 (Yesterday)		27.11.23 (Today)			
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Status of Machines under shut-down/ Maintenance			
					Day	Evening	Day	Evening	Gas/Coal/Oil/Water Limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date		
(A) Plants in operation:														
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work		
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0			Gas Shortage		
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180					
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0					
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	68	71	77	77					
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage		
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0					
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	222	191	330	330					
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225	225		Gas Shortage		
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling		
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	402	378	412	412					
11	Siddhirganj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage		
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	310	263	335	335	72		Gas Shortage		
13	Meghnaghat 335MW CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0	335		Gas Shortage		
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	7	15	30					
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	0	0	100	100					
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	16	17	18	18					
17	Sumit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	37	40	38	38					
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	33	33					
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	28	33	33					
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	17	8	25					
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	17	105	30	105					
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	0	55	16	149					
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	17	0	35					
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	38	80	130					
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	17	36	18	100					
26	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	35	0	35					
27	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	17	0	35					
28	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	0	25	26	88					
29	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	0	54	17	35					
30	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	31	0	35	0					
31	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	33	17	35					
32	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	0	27	92	92					
33	Meghnaghat 100 MW(IEEL)	HFO (NENP)	12x8.9	100	100	0	13	92	100					
34	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	37	85	85					
35	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	0	30	40					
36	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0					
	Meghnaghat Unique Power	Gas				0	0	0	0					
	Meghnaghat 589 MW CCPP(Summit)	Gas				0	0	0	0					
Dhaka Zone Total			5655	5422	1583	1934	2342	2900	947	375				
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	40	40	86	86					
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage		
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.		
39	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	4	0	5	0	0					
40	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	17	8	17					
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	19	0	20	0					
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	18	6	10					
43	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	5	17	17	17					
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150		Under maint.		
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	163	182	212	212					
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	0	200	260	260					
47	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	12	12	12	12					
48	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	0	0	0					
49	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	43	40	64					
50	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	12	12	12	12					
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			0	0	10	25					
51	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0					
52	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	17	17	17					
53	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	12	17	17	17					
54	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	0	0	12	12					
55	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	12	12	12	12					
56	Chattogram 116 MW PP (Anilma Energy Ltd.)	HFO (IPP)	6x21.06	116	116	15	17	17	17					
57	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	17	0	0	0					
58	Chattogram 2*612MW Coal Based PP (SS Powe	Coal (IPP)	2x612	1224	1224	490	490	0	500					
	Matarbari 2*600 MW (CPGCL)	Coal				0	270	560	560			Test run		
	Cox's Bazar Wind PP	(Wind) (IPP)				0	0	10	10			Test run		
Chattogram Zone Total			3829	3769	807	1364	1333	1860	180	330				
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	43	45	51	51					
60	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	0	0	0	0	221		Under Maint.		
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	0	0	0	0	360		Under Maint.		
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	335	280	320	320					
63	Ashuganj 420 MW CCPP(East)	Gas (APSCCL)	1x284+1x116	400	400	393	393	395	395					
64	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*16	195	195	83	185	55	102					
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51					
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	76	150	150					
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	0					
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163		Under maint.		
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	17	17	17					
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	15	17	18	18					
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11					
72	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33					
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	13	52	52					
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	8	8	10	10					
75	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	34	114	114					
76	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	6	47	28	65					
77	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	0	17	17	17					
78	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	9	39	36	72					
**	Import (Tripura)	India		160	160	120	122	128	140					
Cumilla Zone Total			2904	2896	1124	1388	1486	1618	0	744				
79	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	61	45	80	90	157		Gas Shortage		
80	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0					
81	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	8	56	56	85					
82	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	45	124	84	104					
83	Sarishabani 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0					
84	Sutiakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	52	0	50	0					
85	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	0	6	6	6					
Mymensingh Zone Total			622	614	168	231	278	285	157	0				

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	26.11.23 (Yesterday)		27.11.23 (Today)		26.11.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening				
86	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 Under maint.	
87	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	26	27	28	28		63	GT-4 Under maint.	
88	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)		19x2.90	51	51	0	0	0	0	51	Gas Shortage	
89	Kushiara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0	0	163	Gas Shortage	
90	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)		4x2.90	11	11	5	8	5	5			
91	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)		2x35	70	66	0	0	0	0			
92	Shajibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0	0	330	Under maint.	
93	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)		32x2.90	86	83	40	40	40	40	46	Gas Shortage	
94	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	196	192	200	200				
95	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	16	17	17	17				
96	Sylhet 10MW PP (Desh)	Gas (RPP)		6x1.95	10	10	10	10	10	10			
97	Shahjahanulla 25 MW PP	Gas (CIPP, REB)		3x9.34	25	25	16	16	16	16	9	Gas Shortage	
98	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	305	295	310	310				
99	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	403	402	400	400				
100	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	390	400	400	400				
101	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
102	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	0	20	44	44				
Sylhet Zone Total						2472	2427	1493	1470	1513	269	520	
103	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0	0			
104	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0	0	410	Gas Shortage	
105	Faridpur 50 MW Peaking PP	HFO (PDB)		8x6.98	54	54	0	30	0	50			
106	Gopalganj 100 MW Peaking PP	HFO (PDB)		16x6.98	109	109	0	0	0	70			
107	Khulna 225 MW CCPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0				
108	Kushtia 105 MW PP (Orion rupsha)	HFO (IPP)		8x18.445	105	105	0	17	105	105			
109	Madhumati 100 MW PP	HFO (NWPGL)		6x18.415	105	105	0	15	32				
110	Mongla Orion 100 MW Solar PP	Solar (IPP)			100	100	76	0	100	0			
111	Khulna 115 MW PP (KPCL-2)	HFO (NENP)		7x17	115	115	0	32	32	48			
112	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)		5*8.5	40	40	0	0	0	16			
113	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)		1x617	617	435	619	500	619				
114	Khulna 330 MW CCPP (GT)	Gas/HSD (BPDB)	1x220+1x116	336	336	0	0	0	0				
**	Bheramara (HVCDC) India			1000	1000	444	444	450	450				
Khulna Zone Total						3241	3237	955	1142	1202	1390	410	0
115	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	16	16	16	110			
116	Bhola 33 MW PP (Venture)	Gas (NENP)		1x34.50	40	40	15	21	21	25			
117	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	130	0	130	130	130			
118	Payra 1320 MW TPP	Coal (BCPCL)		2x622	1244	1244	1040	1200	1000	1220			
119	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	17	0	150				
120	Barisal Electric 307 MW	Coal (IPP)		1x307	307	307	150	234	150	200			
121	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	109	0	110	110				
Barishal Zone Total						2265	2265	1444	1488	1427	1945	0	0
122	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	0	71	Gas Shortage	
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	0		100	Under maint.
123	Baghabari 50 MW Peaking PP	HFO (PDB)		6x8.9	52	52	0	0	0	35			
124	Baghabari 200 MW PP (Paramount)	HSD (IPP)		135x1.6	200	200	0	0	0	0			
125	Bera 70 MW Peaking PP	HFO (PDB)		9x8.29	71	71	0	0	0	20			
126	Chapainawabganj 100 MW Peaking PP	HFO (PDB)		12x8.924	104	104	0	42	40	85			
127	Katakhali 50 MW Peaking PP	HFO (PDB)		6x8.7	50	50	0	0	30	40			
128	Katakhali 50 MW PP (Northern)	HFO (QRPP)		6x8.9	50	50	0	0	34	42			
129	Santahar 50 MW Peaking PP	HFO (PDB)		6x8.7	50	50	0	0	0	38			
130	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)		1x150+1x75	210	210	0	0	0	0	210	Gas Shortage	
131	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)		1x150+1x75	220	220	0	0	0	0	220	Gas Shortage	
132	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)		1x141+1x79	220	220	0	0	0	0	220	Gas Shortage	
133	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)		1x282+1x132	414	414	414	305	414	414	109	Gas Shortage	
134	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)		4x2.90	11	11	5	5	11	11			
135	Natore 52 MW PP (Rajlanka)	HFO (IPP)		6x8.92	52	52	0	0	52	52			
136	Bagura 113 MW (Confidence) U-1	HFO (IPP)		6*18.55	113	113	0	95	35	113			
137	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)		6x18.55	113	113	29	37	35	50			
138	Ammura 50 MW PP(Sinha)	HFO (NENP)		7x7.79	50	28	0	0	28	28			
139	Sirajgonj 6.55 MW Solar	Solar (NWPGL)		1x6	6	6	5	0	6	0			
**	Adani Power Jharkhanda Ltd	(Import)		2x748	1496	1496	867	858	850	900			
Rajshahi Zone Total						3653	3631	1320	1342	1535	1828	830	100
140	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	0	85	Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	0		85	Under Overhauling
141	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	170	170	170	170	170	104	Coal Shortage	
142	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0	0			
143	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	0	107	113	113	113			
144	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0	0			
145	Majpara, Talsila 9 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	5	0	8	8	0			
146	Thakurgaon 19MW PP (Energypac)	HFO (IPP)		6*20	115	115	0	45	70	110			
147	Lalmohitha 30 MW Solar (Intraco)	Solar (IPP)		1*30	30	30	37	0	30	0			
148	Teesta Solar Limited	Solar (IPP)		1 x 200	200	200	188	0	130	0			
Rangpur Zone Total						1030	950	400	322	521	393	189	85
Sub-total: Plants in operation						25671	25211	9294.0	10681	11637	13732	2982	2154
(B) Plants under long term maintenance/ contract expired													
149	Jamulpur 95 MW PP(Powerpac)	HFO (IPP)		12x8.924	95	0	0	0	0	0			
150	Bosila 108MW PP(CLC)	HFO (IPP)		12x8.775+1x3.5	108	0	0	0	0	0			
151	Bogra 22 MW PP (GBB)	Gas (RPP)		6x4.0	22	0	0	0	0	0			
152	Ashugani 55 MW PP (Precision)	Gas (RPP)		15*4	55	0	31	40	40	40			
Sub-total: Plants under long term maintenance/ contract expired						280	31	40	40	40	0	0	
Gross Total						25951	25211	9325	10721	11677	13772	2982	2154
(C) Actual data of 26.11.23 (Yesterday) Sunday :													
01.	Max. Demand at eve. peak (Generation end)	:	10721	MW, at =	18:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	10481	MW, at =	18:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	10721	MW, at =	18:00 hrs	Dhaka	4125	4125	0	Mymensingh	800	800	0
04.	Minimum Generation (Generation end)	:	7092	MW, at =	5:00 hrs	Chattogram	1168	1168	0	Sylhet	388	388	0
05.	Day-peak Generation (Generation end)	:	9325	MW, at =	12:00 hrs	Khulna	1175	1175	0	Barishal	271	271	0
06.	Evening-peak Generation (Generation end)	:	10721	MW, at =	18:00 hrs	Rajshahi	975	975	0	Rangpur	689	689	0
07.	Evening Peak Load-shed (Sub-station end)	:	0	MW, at =	18:00 hrs	Cumilla	890	890	0				0
08.	Minimum Generation Forecast up to 8:00 hrs.	:	7273	MW, at =	5:00 hrs					Total	10481	10481	0
09.	Generation shortfall at evening peak due to :	:											
a)	Gas/LF limitation	:	2793	MW		13. Fuel cost :			(a) Gas = 109498154 Taka	(c) Coal = 501307483 Taka			
d)	Coal supply Limitation	:	189	MW					(b) Oil = 142127087 Taka	Total = 752932725 Taka			
b)	Low water level in Kaptai lake	:	0	MW									
c)	Plants under shut down/ maintenance	:	2154	MW									
10.	Total Energy (Generation + India Import)	:	202.70	MKWh		14. Maximum Temperature in Dhaka was : 31.4°C							
	By Gas = 109.493 MKWh			By Oil = 10.979 MKWh		15. Export through East-West interconnections :							
	By Coal = 66.194 MKWh			By Hydro = 1.115 MKWh		At evening peak-hour : 9325 MW, at 18:00 hrs							
	By Solar= 2.330 MKWh					Maximum : 216 MW, at 22:00 hrs							
11.	Total Gas Supplied	:	802.11	MMCFD		Energy : 0.0165 MKWh							
(D) Forecast of 27.11.23 (Today) Monday :													
01.	Maximum Demand	:	11000	MW	(Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)		
02.	Maximum Generation	:	13772	MW	(Generation end)	05.	Total Generation	:	207.97	MKWh			
03.	Reserve / Shortage	:	2772	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	:	31.4°C				

* Captive Power ** Imported Power
#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation