

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

| Date :                |                                         | 27-Nov-23      |                     | Page -2          |                      |                  |                                    |
|-----------------------|-----------------------------------------|----------------|---------------------|------------------|----------------------|------------------|------------------------------------|
| Sl. No.               | Name of the Power Stations              | Producer       | Installed Capacity  | Present Capacity | Peak Hour Generation | Energy Generated | Remarks                            |
|                       |                                         |                | Unit No. X Capacity | MW               | MW                   | KWH              |                                    |
| 1                     | Ghorasal Repowered CCPP-Unit-3 (GT)     | PDB            | 1*260               | 260              | 0                    | 0                | Under maint.                       |
| 2                     | Ghorasal Repowered CCPP Unit-4          | PDB            | 1*210               | 180              | 0                    | 0                | Under maint.                       |
| 3                     | Ghorasal TPP Unit-5 [                   | PDB            | 1*210               | 180              | 0                    | 4221000          |                                    |
|                       | Ghorasal 365 MW CCPP Unit-7             | PDB            | 1*243+1*122         | 365              | 0                    | 0                | Air Compressor problem             |
|                       | Ghorashal 78.5 MW PPI(MAX)              | QRPP           | 2*40                | 0                | 0                    | 0                | Contract Expired                   |
| 4                     | Ghorashal 108 MW PP (Regent)            | IPP            | 3*43.35             | 108              | 76                   | 1350727          | Engine problem                     |
| 5                     | Haripur GTPP                            | SBUL PDB       | 2*32                | 20               | 0                    | 0                | Under maint.                       |
| 6                     | Haripur 412 MW CCPP                     | EGCB           | 1*273+1*139         | 412              | 386                  | 9181180          | Gas shortage                       |
| 7                     | Haripur 360 MW CCPP(HPL)                | IPP            | 1*235+1*125         | 360              | 196                  | 5374000          | Gas shortage                       |
| 8                     | Meghnaghat 450 MW CCPP(MPL)             | IPP            | 2*150+1*150         | 450              | 225                  | 4789300          | GT-1 under S/D due to gas s        |
| 9                     | Meghnaghat 100 MW(IEI)                  | NENP           | 12*8.9              | 100              | 13                   | 34560            | Low demand                         |
| 10                    | Meghnaghat CCPP(Summit)                 | IPP            | 2*110+1*110         | 335              | 0                    | 0                | GT-1 under S/D due to gas shortage |
| 11                    | Madanganj 102 PP(Summit)                | NENP           | 6*17                | 102              | 34                   | 50026            | Low demand                         |
| 12                    | Madanganj-55 MW PP(Summit)              | IPP            | 3*17.08+1*11.3      | 55               | 15                   | 133321           | Low demand                         |
| 13                    | Keraniganj 100 MW PP (Powerpac)         | NENP           | 8*13.45             | 75               | 0                    | 0                | Reserve                            |
| 14                    | Narsinghdi 22 MW PP (Doreen)            | SIPP, REB      | 8*2.90              | 22               | 15                   | 286560           | Engine problem                     |
| 15                    | 210 MW Siddhirgonj TPP                  | PDB            | 1*210               | 115              | 0                    | 0                | Under maint.                       |
| 16                    | Siddhirgonj 2*120 MW GTPP               | EGCB           | 2*105               | 210              | 0                    | 0                | Gas shortage                       |
| 17                    | Siddhirgonj 100 PP(Dutch Bangla)        | NENP           | 12*8.9              | 100              | 52                   | 100800           | Low demand                         |
| 18                    | Siddhirgonj 335 MW CCPP                 | EGCB           | 1*217+118           | 335              | 240                  | 6254330          | Gas shortage                       |
| 19                    | Gazipur 102 MW PP (Digital Power)       | IPP            | 12*8.924            | 102              | 64                   | 133776           | Low demand                         |
| 20                    | Katpottli 52 MW PP (Sinha)              | IPP            | 7*7.9               | 0                | 0                    | 0                | Fuel shortage                      |
| 21                    | Kamalaghat 54 MW PPI(Banco Energy)      | IPP            | 3*18                | 54               | 17                   | 129960           | Fuel shortage                      |
| 22                    | Kodda 150 MW PP [                       | BPDB-RPCL      | 9*17.06             | 149              | 149                  | 279840           |                                    |
| 23                    | Kodda 33 MW PP (Northern)               | IPP            | 3*19.3              | 55               | 35                   | 134519           | Fuel shortage                      |
| 24                    | Nababganj 55 MW PP (Southern power )    | IPP            | 3*19.3              | 55               | 17                   | 122953           | Fuel shortage                      |
| 25                    | Bosilla 108 MW PP(CLC)                  | IPP            | 12*8.775+1*3.5      | 0                | 0                    | 0                |                                    |
| 26                    | Summit Power (Madhabadi+Ashulia)        | SIPP, REB      | 3*3.67+*8.73        | 80               | 38                   | 929280           | Engine problem                     |
| 27                    | Masra 33 MW PP(Summit)                  | SIPP, REB      | 4*8.73              | 33               | 33                   | 695500           |                                    |
| 28                    | Rupganj 33 MW PP(Summit)                | SIPP, REB      | 4*8.73              | 33               | 30                   | 733700           | Engine problem                     |
| 29                    | Gazipur 52 MW PP [                      | RPCL           | 6*8.9               | 52               | 17                   | 145920           | Fuel shortage                      |
| 30                    | Tong 80 MW GTPP                         | PDB            | 1*105               | 105              | 0                    | 0                | Gas shortage                       |
| 31                    | Kodda 300 MW PP Unit-2 (Summit)         | IPP            | 18*17.076           | 300              | 30                   | 148940           | Low demand                         |
| 33                    | Bramhanagan 100 MW PP (Aggreko)         | IPP            | 11*40.959           | 0                | 0                    | 0                | Contract Expired                   |
| 34                    | Aurahati 100MW PP (Aggreko)             | IPP            | 0.85*23+0.95*91     | 0                | 0                    | 0                | Contract Expired                   |
| 35                    | Kodda 149 MW PP Unit-1 (Summit)         | IPP            | 8*18.45+8.97        | 149              | 70                   | 533376           | Low demand                         |
| 36                    | Gazipur 100 MW PP                       | RPCL           | 6*17.5              | 105              | 105                  | 689280           |                                    |
| 37                    | Meghnaghat 104 MW PP (POCL)             | IPP            | 18.5*6              | 104              | 34                   | 180480           | Low demand                         |
| 38                    | Manikgonj 162MW PP(MPGCL)               | IPP            | 9*18                | 162              | 55                   | 360000           | Fuel shortage                      |
| 39                    | Spectra Solar Plant Ltd.                | IPP            | 35                  | 35               | 0                    | 179981           |                                    |
| 40                    | Kanchan Purbachal Power Generation Ltd. | IPP            | 18.4*3              | 55               | 17                   | 228240           | Fuel shortage                      |
|                       | Meghnaghat Unique power                 | IPP            | 588                 | 0                | 0                    | 0                | On test.                           |
|                       | Summit Meghnaghat-2 589 MW(Gas)         | IPP            | 589                 | 0                | 0                    | 0                | On test.                           |
| Dhaka area Total      |                                         |                |                     | 5422             | 2143                 | 37314649         |                                    |
| 41                    | Chattogram TPP-1                        | PDB            | 1*210               | 180              | 0                    | 0                | Gas shortage                       |
|                       | Chattogram TPP-2                        | PDB            | 1*210               | 180              | 0                    | 0                | Gas shortage                       |
| 42                    | Razcan 25 MW PP                         | RPCL           | 3*8.9               | 25               | 17                   | 42616            | Fuel shortage                      |
| 43                    | Teknaf 20MW PP (Solartech)              | IPP            | 20                  | 20               | 0                    | 122040           |                                    |
| 44                    | Patanga 50MW PP (Baraka)                | IPP            | 6*6.98              | 50               | 19                   | 120960           | Fuel shortage                      |
| 45                    | Kapali Hydro Unit-1,2,3,4, 5            | PDB            | 2*40+3*50           | 230              | 86                   | 2062660          | Unit-2 under maint.                |
| 46                    | Sikalbaha 225MW [                       | PDB            | 1*150+1*75          | 225              | 215                  | 4938280          | Machine problem                    |
| 47                    | Sikalbaha Peaking GT                    | PDB            | 1*150               | 150              | 0                    | 0                | Under maint.                       |
| 48                    | Sikalbaha 105 MW PP (Baraka Sikalbaha)  | IPP            | 6*17.5              | 105              | 17                   | 224981           | Fuel shortage                      |
| 49                    | Hafazani 100 MW peaking PP              | PDB            | 11*8.9              | 98               | 64                   | 318624           | Engine problem                     |
| 50                    | Dohazani -Kalaisah 100 MW Peaking       | PDB            | 6*17                | 102              | 0                    | 0                | Fuel shortage                      |
| 51                    | Juldah 100 MW Unit-1 (Accom)            | NENP           | 8*13.45             | 100              | 12                   | 116640           | Fuel shortage                      |
| 52                    | Juldah 100 MW PP Unit-3 (Accom)         | IPP            | 8*13.5              | 100              | 12                   | 153500           | Fuel shortage                      |
| 53                    | Barakunda 22 MW PP (Regent)             | SIPP, PDB      | 8*2.90              | 22               | 12                   | 270480           | Fuel shortage                      |
| *                     | Malancha, Ctg. EPZ (United)             |                | 5*8.73+3*9.34       | 0                | 2                    | 243840           |                                    |
| 54                    | Chattogram 108 MW PP (ECPV)             | IPP            | 16*7                | 108              | 0                    | 0                | Fuel shortage                      |
| 55                    | Kapra 7 MW Solar PP                     | PDB            | 7.4 MW              | 7                | 0                    | 26879            |                                    |
| 56                    | Anwara 300 MW PP (United)               | IPP            | 17*17.424           | 300              | 160                  | 1653491          | Low demand                         |
| 57                    | Jodiao Power                            | IPP            | 3*18.55+1*3.6       | 54               | 17                   | 220783           | Fuel shortage                      |
| 58                    | Karnaphuli Power Ltd.                   | IPP            | 18.415*6+6.5        | 110              | 17                   | 287708           | Fuel shortage                      |
| 59                    | Juldah unit-2 (Accom)                   | IPP            | 8*13.6              | 100              | 0                    | 0                | Fuel shortage                      |
| 60                    | Anlima Energy Ltd.                      | IPP            | 6*21.2              | 116              | 34                   | 424036           | Fuel shortage                      |
|                       | Mirshara 150 MW                         | BPDB-RPCL      | 18.5*9              | 163              | 0                    | 0                | Fuel shortage                      |
|                       | SS Power I                              | SS Power       | 2*612               | 1224             | 150                  | 5803635          |                                    |
|                       | Cox's Bazar Wind                        | IPP            | 66                  | 0                | 8                    | 26880            | On test.                           |
|                       | Matarban 2*600 MW (CPGCL)               | CPGCL          | 0                   | 0                | 153                  | 9367272          | On test.                           |
|                       | Mirshara 150 MW (Gas)                   | BPDB-RPCL      | 18.5*9              | 0                | 17                   | 322836           |                                    |
| Chattogram area Total |                                         |                |                     | 3789             | 1012                 | 26748241         |                                    |
| 61                    | Ashuganj TPP Unit-3                     | APSCL          | 1*150               | 0                | 0                    | 0                | Contract Expired                   |
|                       | Ashuganj TPP Unit- 4                    | APSCL          | 1*150               | 0                | 0                    | 0                | Contract Expired                   |
|                       | Ashuganj TPP Unit- 5                    | APSCL          | 1*150               | 0                | 0                    | 0                | Contract Expired                   |
| 62                    | Ashuganj 225 MW CCPP                    | APSCL          | 1*142+1*75          | 221              | 0                    | 0                | Under maint.                       |
| 63                    | Ashuganj 450 MW CCPP(North)             | APSCL          | 1*360               | 360              | 310                  | 7441600          |                                    |
| 64                    | Ashuganj 450 MW CCPP(South)             | APSCL          | 1*360               | 360              | 0                    | 0                | Under maint.                       |
|                       | Ashuganj 420 MW CCPP(East)              | APSCL          | 284*1+116*1         | 400              | 380                  | 8340900          |                                    |
| 65                    | Ashuganj 50 MW PP [                     | APSCL          | 14*3.968            | 45               | 47                   | 862704           |                                    |
| 66                    | Ashuganj 55 MW PP (Precision)           | QRPP           | 0                   | 0                | 40                   | 773280           |                                    |
| 67                    | Ashuganj 195 MW PP (RPCL-United)        | IPP            | 20*9.73+1*16        | 195              | 148                  | 1706182          |                                    |
| 68                    | Ashuganj 51 MW PP (Midland)             | IPP            | 6*9.34              | 51               | 51                   | 961240           |                                    |
| 69                    | Ashuganj 150 MW PP (Midland)            | IPP            | 23*7.015            | 150              | 63                   | 473381           | Low demand                         |
| 70                    | Titas 50 MW Peaking PP                  | PDB            | 6*8.92              | 52               | 20                   | 62320            |                                    |
| 71                    | Chandpur 150 MW CCPP                    | PDB            | 12*18.157           | 163              | 0                    | 0                | Under maint.                       |
| 72                    | Chandpur 200 MW (Dash energy)           | IPP            | 12*18.4             | 200              | 17                   | 300480           | Fuel shortage                      |
| 73                    | Feni 22 MW PP (Doreen)                  | SIPP, PDB      | 8*2.90              | 22               | 18                   | 432576           | Engine problem                     |
|                       | Feni 11 MW PP (Doreen)                  | SIPP, REB      | 4*2.90              | 11               | 11                   | 235620           |                                    |
| **                    | Import (Tripura)                        | Imported power | 0                   | 160              | 126                  | 2603640          |                                    |
| 75                    | Jangalia 33 MW PP (Summit)              | SIPP, PDB      | 4*8.73              | 33               | 25                   | 593000           |                                    |
| 76                    | Jangalia 52 MW PP (Lakdanani)           | IPP            | 6*8.92              | 52               | 25                   | 118186           | Low demand                         |
| 77                    | Cumilla 25 MW PP (Summit)               | SIPP, REB      | 3*3.67+2*6.97       | 25               | 8                    | 188160           | Engine problem                     |
| 78                    | Daulkandi 200 MW PP (B.Trac)            | IPP            | 15*41.4             | 0                | 0                    | 0                | Contract Expired                   |
| 79                    | Feni Lanka Power                        | IPP            | 7*18.154+1*9.175    | 114              | 55                   | 183540           | Low demand                         |
| 80                    | Chowmuhani 113 MW                       | IPP            | 12*9.78+2*23.1      | 113              | 44                   | 463680           | Fuel shortage                      |
| 81                    | Bhairab 54.5 MW [                       | IPP            | 3*18.2              | 54               | 17                   | 136800           | 33 kV feeder problem.              |
| 82                    | Chandpur 115(Doreen)                    | IPP            | 4*18.5+2*22.5       | 115              | 54                   | 401280           | Fuel shortage                      |
| Cumilla Area Total    |                                         |                |                     | 2896             | 1459                 | 26275569         |                                    |
| 83                    | RPCL 210MW CCPP [                       | IPP            | 4*35+1*70           | 210              | 34                   | 1446720          | Gas shortage                       |
| 84                    | Tangail 22 MW PP (Doreen)               | SIPP, PDB      | 8*2.90              | 22               | 0                    | 0                | Contract Expired                   |
| 85                    | Jamulpur 95 MW PP(Powerpac)             | IPP            | 0                   | 0                | 0                    | 0                | Under maint.                       |
| 86                    | Sarishabani 3 MW Solar Plant            | IPP            | 1*3                 | 3                | 0                    | 11750            |                                    |
| 87                    | Mymensingh 200 MW PP (United)           | IPP            | 9*78.21             | 200              | 95                   | 1070400          | Fuel shortage                      |
| 88                    | Jamulpur 115 MW PP (United)             | IPP            | 9*78.12             | 115              | 15                   | 588000           | Fuel shortage                      |
| 89                    | Sutahkahi 50 MW Solar PP                | IPP            | 50                  | 50               | 0                    | 326940           |                                    |
| 90                    | Tangail Palli Power Gen 22 MW           | IPP            | 4*6.7               | 22               | 6                    | 25440            | Engine problem                     |
| Mymensingh Area Total |                                         |                |                     | 614              | 220                  | 3469250          |                                    |
| 91                    | Fenchugong CCPP Phase-1                 | PDB            | 2*32+1*33           | 70               | 43                   | 1010000          |                                    |
| 92                    | Fenchugong CCPP Phase-2                 | PDB            | 2*35+1*36           | 90               | 26                   | 675000           | Engine problem                     |
| 93                    | Kushara 163 MW CCPP (KP)                | IPP            | 1*109+1*54          | 163              | 0                    | 0                | Gas shortage                       |
| 94                    | Shajibazar 330 MW CCPP                  | PDB            | 3*110               | 330              | 0                    | 0                | Under maint.                       |
| 95                    | Fenchugong 51 MW PP (Barakatalulah)     | RPP            | 19*2.90             | 51               | 0                    | 0                | Gas shortage                       |
| 96                    | Fenchuganj 44 MW (Energyprime)          | NENP           | 12*3.3+5*2          | 50               | 0                    | 373968           | Gas shortage                       |
| 97                    | Hobiganj 11 MW PP Confidence-E          | SIPP, REB      | 4*2.90              | 11               | 8                    | 192384           | Engine problem                     |
| 98                    | Shajibazar GTPP Unit- 8 & 9             | PDB            | 2*35                | 66               | 0                    | 0                | Under maint.                       |
| 99                    | Shajibazar 86 MW PP (Shajibazar)        | RPP            | 32*2.90             | 86               | 80                   | 1097280          | Gas shortage                       |
| 100                   | Shajibazar 100 MW GTPP                  | PDB            | 1*100               | 100              | 0                    | 0                | Under maint.                       |
| 100                   | Sylhet 225 MW CCPP                      | PDB            | 1*142+1*199         | 231              | 192                  | 4994510          | Machine problem                    |
| 101                   | Sylhet 20 MW GTPP [                     | PDB            | 1*20                | 20               | 17                   | 414000           |                                    |
|                       | Sylhet 50 MW PP (EPL)                   | NENP           | 27*2                | 0                | 0                    | 0                | Contract Expired                   |
| 102                   | Shahjahanulla 25 MW PP                  | SIPP, REB      | 3*9.34              | 25               | 0                    | 354432           | Engine problem                     |
| 103                   | Bibiana-1 341 MW CCPP (Summit)          | IPP            | 1*222+1*119         | 341              | 290                  | 7665500          | FGMO                               |
| 104                   | Bibiyana-II 400 MW CCPP                 | PDB            | 285*1+1*341         | 400              | 402                  | 9184000          |                                    |
| 105                   | Sylhet 10MW PP (Desh)                   | RPP            | 6*1.95              | 10               | 10                   | 248400           |                                    |
| 106                   | Bibiyana South 400 MW                   | PDB            | 400 MW              | 383              | 400                  | 6246700          |                                    |
| Sylhet Area Total     |                                         |                |                     | 2427             | 1468                 | 34857174         |                                    |
| 107                   | Bheramara GTPP Unit-3                   | PDB            | 1*20                | 0                | 0                    | 0                |                                    |
| **                    | Bheramara (HVDC) [                      | Imported power | 2*500               | 1000             | 202                  | 10235636         | Block-1 under maintenance          |
| 108                   | Khulna 115 PP MW (KPCL-2)               | NENP           | 7*17                | 115              | 16                   | 32640            | Low demand                         |
| 109                   | Faridpur 50 MW Peaking PP               | PDB            | 8*6.89              | 54               | 0                    | 0                | Reserve                            |
| 110                   | Khulna 225 MW CCPP                      | NWP/PGCL       | 1*150+1*75          | 230              | 0                    | 0                | Fuel shortage                      |
| 111                   | Copalganj 100 MW Peaking PP             | PDB            | 1*6.98              | 100              | 0                    | 0                | Reserve                            |
| 112                   | Bheramara 410 MW CCPP                   | NWP/PGCL       | 1*278+1*132         | 410              | 0                    | 0                | Gas shortage                       |
|                       | Noapara 40 MW PP (Khanjahan Ali)        | NENP           | 5*8.5               | 40               | 8                    | 11250            | Low demand                         |
| 113                   | Noapara 100 MW PP (Bangla Trac)         | IPP            | 70*1.4              | 0                | 0                    | 0                | Contract Expired                   |
| 114                   | Rupsha 105 MW PP (Orion rupsha)         | IPP            | 6*18.445            | 105              | 17                   | 40800            | Low demand                         |
| 115                   | Madhumati 100 MW PP                     | NWP/PGCL       | 8*16                | 105              | 0                    | 0                | Reserve                            |
| 116                   | Mongla Orion 100 MW Solar PP            | IPP            | 100                 | 100              | 0                    | 433440           |                                    |