

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 8564667, 9551095

Month November, 2023					Day : Tuesday					Date : 28.11.23				
Probable Maximum Demand : 11100 MW					Probable Maximum Generation : 13408 MW									
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 98.43 ft					Today = 98.34 ft				
					Rule Curve = 106.50 ft									
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derailed/ Present Capacity (MW)	27.11.23 (Yesterday)		28.11.23 (Today)		27.11.23 (Yesterday)		28.11.23 (Today)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :					
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date		
(A) Plants in operation:														
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	0	0	0	0		260		Under project work		
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0				Gas Shortage		
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180						
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0						
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	71	76	70	76					
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage		
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0					
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	243	196	200	200					
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225	225				
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115		Under Overhauling		
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	376	386	412	412					
11	Siddhirganj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage		
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	297	240	250	250	95		Gas Shortage		
13	Meghnaghat 335MW CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0	335		Gas Shortage		
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	15	15	55					
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	0	64	100	100					
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	15	15	15	15					
17	Summit Power(Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	38	38	38	38					
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	33	33	33					
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	31	30	33	33					
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	17	8	25					
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	35	105	30	105					
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	0	149	16	149					
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	17	0	35					
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	30	80	130					
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	17	70	18	100					
26	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	17	0	35					
27	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	35	0	35					
28	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	0	34	26	72					
29	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	17	55	17	55					
30	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	31	0	35	0					
31	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	17	17	17					
32	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	0	52	90	90					
33	Meghnaghat 100 MW(IEEL)	HFO (NENP)	12x8.9	100	100	0	13	90	90					
34	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	34	85	85					
35	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	0	30	40					
36	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0					
	Meghnaghat Unique Power	Gas			0	0	0	0	0					
	Meghnaghat 589 MW CCPP(Summit)	Gas			0	0	0	0	0					
Dhaka Zone Total					5655	5422	1626	2143	2113	2680	970	375		
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	86	86	86	86					
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage		
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.		
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0					
40	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	17	8	17					
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	19	0	20	0					
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	19	6	19					
43	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	12	17	17	17					
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150		Under maint.		
45	Sikalbaha 225 MW CAPP	Gas (PDB)	1 x 150+1 x 75	225	225	214	215	212	215					
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	115	160	260	260					
47	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	12	12	12	12					
48	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	0	0	0					
49	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	24	64	40	64					
50	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	12	12	12	12					
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			0	2	10	20					
51	Chattogram 108 MW PP (EGPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0					
52	Sikalbaha 54 MW PP (Jodiach Power)	HFO (IPP)	3x18.5+1x3.6	54	54	17	17	17	17					
53	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	17	17	17					
54	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	0	0	12	12					
55	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	12	12	12	12					
56	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	26	34	17	17					
57	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	48	17	0	0					
58	Chattogram 2*612MW Coal Based PP (SS Power)	Coal (IPP)	2x612	1224	1224	0	150	500	500					
	Matarbari 2*600 MW (CPGCL)	Coal				562	153	600	300			Test run		
	Cox's Bazar Wind PP	(Wind) (IPP)				0	8	10	10			Test run		
Chattogram Zone Total					3829	3769	1180	1012	1873	1607	180	330		
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	44	47	47	47					
60	Ashuganj 225 MW CAPP	Gas (APSCCL)	1x142+1*75	221	221	0	0	0	0	221		Under Maint.		
61	Ashuganj 450 MW CAPP(South)	Gas (APSCCL)	1x360	360	360	0	0	0	0	360		Under Maint.		
62	Ashuganj 450 MW CAPP(North)	Gas (APSCCL)	1x361	360	360	305	310	320	320					
63	Ashuganj 420 MW CAPP(East)	Gas (APSCCL)	1x284+1x116	400	400	393	380	250	380					
64	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*116	195	195	110	148	55	102					
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51					
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	3	63	150	150					
67	Titus 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	20	0	20					
68	Chandpur 150 MW CAPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163		Under maint.		
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	17	17	17					
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	17	18	18	18					
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11					
72	Jangalia 33 MW PP (Summit))	Gas (SIPP, PDB)	4x8.73	33	33	0	25	33	33					
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	25	52	52					
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	8	8	10	10					
75	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	55	114	114					
76	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	36	44	28	55					
77	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	0	17	17	17					
78	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	18	54	36	53					
79	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	0	40	40	40	46					
**	Import (Tripura)	India		160	160	122	126	128	140					
Cumilla Zone Total					2959	2896	1200	1459	1377	1636	0	744		
80	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	30	34	80	80	168		Gas Shortage		
81	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0					
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	8	85	56	85					
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	57	95	84	100					
84	Saishabani 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0					
85	Sutiakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	48	0	50	0					
86	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	0	6	6	6					
Mymensingh Zone Total					622	614	144	220	278	271	168	0		

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	27.11.23 (Yesterday)		28.11.23 (Today)		27.11.23 (Yesterday)		Status of Machines under shut-down/ Maintenance			
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW		Description/ Remarks	Probable start-up date		
					Day	Evening	Day	Evening	Machines shut down (MW)					
87	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43	27	OT-1 Under maint.			
88	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	28	26	28	28	64	OT-4 Under maint.			
89	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	0	0	0	0	51	Gas Shortage			
90	Kushara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0	163	Gas Shortage			
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8					
92	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	0	0	0	0					
93	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0	330	Under maint.			
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	80	80	60	80	6	Gas Shortage			
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	197	192	200	200					
96	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	17	17	17	17					
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10					
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	0	16	16	25	Gas Shortage			
99	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	280	290	280	300					
100	Bibiya-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	400	402	400	400					
101	Bibiya South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	393	400	400	400					
102	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0	100	Under project work			
103	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12'3.3x5'2	50	50	0	0	44	47					
Sylhet Zone Total					2472	2427	1472	1468	1506	1549	245	521		
104	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0					
105	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0	410	Gas Shortage			
106	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	50					
107	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	70					
108	Khulna 225 MW CCPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0					
109	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	17	90	90					
110	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	0					
111	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	81	0	100	0					
112	Khulna 115 MW PP (KPCCL-2)	HFO (NENP)	7x17	115	115	0	16	32	48					
113	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5'8.5	40	40	0	8	0	16					
114	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIPCL)	1x617	617	617	408	626	500	620					
115	Khulna 330 MW CCPP (GT)	Gas/HSD (BIPDB)	1x220+1x116	336	336	0	0	0	0					
**	Bheramara (HVDc)	India		1000	1000	439	202	450	450					
Khulna Zone Total					3241	3237	928	869	1172	1344	410	0		
116	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	16	110					
117	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	15	18	21	25					
118	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	130	122	130	130					
119	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	760	1220	1000	1220					
120	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	55	0	150					
121	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	140	250	200	250					
122	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	144	185	130	220					
Barishal Zone Total					2265	2265	1189	1850	1497	2105	0	0		
123	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71	Gas Shortage			
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100	Under maint.			
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	0	30					
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0					
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	20					
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	0	40	85					
128	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	30	40					
129	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	34	42					
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	38					
131	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	210	0	210	Gas Shortage			
132	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220	Gas Shortage			
133	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0	220	Gas Shortage			
134	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	400	376	0	414	38	Gas Shortage			
135	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11					
136	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	0	52	52					
137	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6'18.55	113	113	0	70	35	113					
138	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6'18.55	113	113	0	50	35	50					
139	Aminura 50 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	0	0	28	28					
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0					
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	820	968	850	900					
Rajshahi Zone Total					3653	3631	1236	1475	1331	1823	759	100		
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Coal Shortage			
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Under Overhauling			
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	283	170	170	170	104	Coal Shortage			
143	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	34	95	113	113					
145	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
146	Majpara, Tabula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	6	0	8	0					
147	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6'20	115	115	36	70	70	110					
148	Lalmohithal 30 MW Solar (Intraco)	Solar (IPP)	1'30	30	30	36	0	30	0					
149	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	183	0	130	0					
Rangpur Zone Total					1030	950	578	335	521	393	189	85		
Sub-total: Plants in operation					25726	25211	9553.0	10831	11668	13408	2921	2155		
(B) Plants under long term maintenance/ contract expired														
150	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0					
151	Bosilia 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0					
152	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	0	0	0	0	0					
Sub-total: Plants under long term maintenance/ contract expired					225	0	0	0	0	0	0	0		
Gross Total					25951	25211	9553	10831	11668	13408	2921	2155		
(C) Actual data of 27.11.23 (Yesterday) Monday :														
01.	Max. Demand at eve. peak (Generation end)	:	10831	MW, at =	18:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :								
02.	Max. Demand at eve. peak (Sub-station end)	:	10746	MW, at =	18:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed	
03.	Highest Generation (Generation end)	:	10831	MW, at =	18:00 hrs	MW	MW	MW	MW	MW	MW	MW	MW	
04.	Minimum Generation (Generation end)	:	7273	MW, at =	5:00 hrs	Dhaka	4337	4337	0	Mymensingh	813	813		
05.	Day-peak Generation (Generation end)	:	9553	MW, at =	12:00 hrs	Chattogram	1159	1159	0	Sylhet	396	396	0	
06.	Evening-peak Generation (Generation end)	:	10831	MW, at =	18:00 hrs	Khulna	1142	1142	0	Barisal	274	274	0	
07.	Evening Peak Load-shed (Sub-station end)	:	0	MW, at =	18:00 hrs	Rajshahi	976	976	0	Rangpur	715	715	0	
08.	Minimum Generation Forecast up to 8:00 hrs.	:	7508	MW, at =	5:00 hrs	Cumilla	933	933	0					
09.	Generation shortfall at evening peak due to :	:				Total						10746	10746	0
a)	Gas/LF limitation	:	2732	MW		(a) Gas = 111947819 Taka						(c) Coal = 548095197 Taka		
d)	Coal supply Limitation	:	189	MW		(b) Oil = 168454846 Taka						828497863 Taka		
b)	Low water level in Kaptai lake	:	0	MW		Maximum Temperature in Dhaka was : 32.4°C								
c)	Plants under shut down/ maintenance	:	2155	MW		Export through East-West interconnections :								
10.	Total Energy (Generation + India Import)	:	220.02	MKWh		At evening peak-hour : 9553 MW, at 18:00 hrs								
	By Gas = 112.022 MKWh			By Oil = 12.885 MKWh		Maximum : 260 MW, at 7:00 hrs								
	By Coal = 77.611 MKWh			By Hydro = 2.063 MKWh		Energy : 0.3135 MKWh								
	By Solar= 2.574 MKWh													
11.	Total Gas Supplied	:	834.78	MMCFD										
(D) Forecast of 28.11.23 (Today) Tuesday :														
01.	Maximum Demand	:	11100	MW	(Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)			
02.	Maximum Generation	:	13408	MW	(Generation end)	05.	Total Generation	:	225.48	MKWh				
03.	Reserve / Shortage	:	2308	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	:	32.4°C					

#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation