

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 8564667, 9551095

Month November, 2023				Day : Wednesday				Date : 29.11.23				
Probable Maximum Demand : 11000 MW				Probable Maximum Generation : 14048 MW								
Water Level of Kapital Lake at 06:00 AM				Yesterday = 98.34 ft	Today = 98.22 ft			Rule Curve = 106.20 ft				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	28.11.23 (Yesterday)		29.11.23 (Today)		28.11.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)		
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0			Gas Shortage
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180			
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0			
4	Ghorashal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	76	74	70	76			
5	Tong 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0			
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	213	162	200	200			
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225	225		Gas Shortage
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	394	354	412	412			
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	240	227	250	250	108		Gas Shortage
13	Meghnaghat 335MW CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0	335		Gas Shortage
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	20	15	55			
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	8	32	100	100			
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	13	14	15	15			
17	Summit Power(Madhabdi-Ashulia)	Gas (SIPP, REB)	6x3.57+7x8.73	80	80	38	38	38	38			
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33			
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	31	3	33	33			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	13	8	25			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	52	105	30	105			
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	48	48	16	149			
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	17	0	35			
24	Kodda 300 MW PP Unit-3 (Summit)	HFO (IPP)	18x17.076	300	300	0	125	80	130			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	24	51	18	100			
26	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	35	0	35			
27	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	35	0	35			
28	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	0	55	26	72			
29	Manikgonj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	17	55	17	55			
30	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	29	0	35	0			
31	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	17	17	17			
32	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	0	16	90	90			
33	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	0	12	90	90			
34	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	17	17	85	85			
35	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	0	30	40			
36	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			
	Meghnaghat Unique Power	Gas			0	0	0	0	0			
	Meghnaghat 589 MW CCPP(Summit)	Gas			0	0	0	0	0			
Dhaka Zone Total				5655	5422	1663	1963	2113	2680	983	375	
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	86	86	86	86			
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0			
40	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	1	17	8	17			
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	18	0	20	0			
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	20	6	19			
43	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	17	17	17			
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150		Under maint.
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	142	141	212	215			
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	20	120	260	260			
47	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	12	12	12	12			
48	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	3	13	0	0			
49	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	2	18	40	64			
50	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	12	0	12	12			
	* Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			0	2	10	20			
51	Chattogram 108 MW PP (EGPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0			
52	Sikalbaha 54 MW PP (Jodiach Power)	HFO (IPP)	3x18.55+1x3.6	54	54	10	36	17	17			
53	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	17	17	17			
54	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	0	0	12	12			
55	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	12	12	12	12			
56	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	17	17	17	17			
57	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	31	0	0	0			
58	Chattogram 2*612MW Coal Based PP (SS Powe	Coal (IPP)	2x612	1224	1224	500	480	500	500			
	Metarbari 2*600 MW (CPGCL)	Coal				565	273	270	270			Test run
	Cox's Bazar Wind PP	(Wind) (IPP)				4	1	10	10			Test run
Chattogram Zone Total				3829	3769	1479	1282	1543	1577	180	330	
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	44	43	47	47			
60	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	0	0	0	0	221		Under Maint.
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	0	0	0	0	360		Under Maint.
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	310	310	320	320			
63	Ashuganj 420 MW CCPP(East)	Gas (APSCCL)	1x284+1x116	400	400	225	390	300	380			
64	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*116	195	195	102	130	55	130			
65	Ashuganj 51 MW PP (Midland)	Gas (APSCCL)	6x9.34	51	51	51	51	51	51			
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	41	150	150			
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	20			
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163		Under maint.
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	67	140	17	17			
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	18	18	18			
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	10	11	11			
72	Jangalia 33 MW PP (Summit))	Gas (SIPP, PDB)	4x8.73	33	33	25	33	33	33			
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	0	52	52			
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	8	6	10	10			
75	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	0	114	114			
76	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	34	48	28	55			
77	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17			
78	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	18	36	36	53			
79	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	0	44	42	40	46			
**	Import (Tripura)	India		160	160	114	126	128	140			
Cumilla Zone Total				2959	2896	1085	1441	1427	1664	0	744	
80	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	34	47	80	80	155		Gas Shortage
81	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0			
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	10	75	56	85			
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	56	104	84	100			
84	Saishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
85	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	47	0	50	0			
86	Tangail 22 MW PP(PPLG)	HFO (IPP)	4x6.7	22	22	0	6	6	6			
Mymensingh Zone Total				622	614	149	232	278	271	155	0	

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	28.11.23 (Yesterday)		29.11.23 (Today)		28.11.23 (Yesterday)		Status of Machines under shut-down/ Maintenance		
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date	
						Day	Evening	Day	Evening					
87	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	OT-1 Under maint.		
88	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	22	30	28	28		60	OT-4 Under maint.		
89	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	0	0	0	0	51		Gas Shortage		
90	Kushara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0	163		Gas Shortage		
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	3	8	8					
92	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	0	0	0	0	66		Gas Shortage		
93	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.		
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	82	83	60	80					
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	199	193	200	200					
96	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	17	17	17	17					
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10					
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	8	16	16	17		Gas Shortage		
99	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	285	270	280	300					
100	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	397	402	400	400					
101	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	398	400	400	400					
102	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work		
103	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	0	0	44	47	50		Gas Shortage		
Sylhet Zone Total						2472	2427	1474	1459	1506	1549	347	517	
104	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0					
105	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0			Gas Shortage		
106	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	50					
107	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	70					
108	Khulna 225 MW CCPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0					
109	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	17	90	90					
110	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	0					
111	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	71	0	100	0					
112	Khulna 115 MW PP (KPCCL-2)	HFO (NENP)	7x17	115	115	0	32	32	48					
113	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8	40	40	0	0	0	16					
114	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIPCL)	1x617	617	617	446	460	500	620					
115	Khulna 330 MW CCPP (GT)	Gas/HSD (BIPCL)	1x220+1x116	336	336	0	0	0	0					
**	Bheramara (HVDCL)	India		1000	1000	440	757	928	928					
Khulna Zone Total						3241	3237	957	1266	1650	1822	0	0	
116	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	16	110					
117	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	12	18	21	25					
118	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	130	130	130	130					
119	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	930	1080	1000	1220					
120	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	55	0	150					
121	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	200	200	200	200					
122	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	144	110	220	220					
Barishal Zone Total						2265	2265	1416	1593	1587	2055	0	0	
123	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage		
124	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Under maint.		
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	0	30					
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0					
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	20					
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	0	40	85					
129	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	30	40					
129	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	34	42					
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	38					
131	Sirajganj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	221	187	190	214	23		Gas Shortage		
132	Sirajganj 225MW CCPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	0	0	0	0	220		Gas Shortage		
133	Sirajganj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0	220		Gas Shortage		
134	Sirajganj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	0	91	300	414	323		Gas Shortage		
135	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11					
136	Natore 52 MW PP (Rajalanka)	HFO (IPP)	6x8.92	52	52	0	0	52	52					
137	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	90	35	113					
138	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6*18.55	113	113	0	45	35	50					
139	Aminura 50 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	0	0	28	28					
140	Sirajganj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0					
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	816	873	850	900					
Raishahi Zone Total						3653	3631	1053	1297	1611	2037	857	100	
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage		
142	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Under Overhauling		
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	170	170	170	170	104		Coal Shortage		
144	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	0	98	113	113					
146	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
147	Majpara, Tabula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	3	0	8	0					
148	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	46	70	110					
149	Lalmohona 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	27	0	30	0					
149	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	175	0	130	0					
Rangpur Zone Total						1030	950	375	314	521	393	189	85	
Sub-total: Plants in operation						25726	25211	9651.0	10847	12236	14048	2711	2151	
(B) Plants under long term maintenance/ contract expired														
150	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0					
151	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0					
152	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	0	0	0	0	0					
Sub-total: Plants under long term maintenance/ contract expired						225	0	0	0	0	0	0	0	
Gross Total						25951	25211	9651	10847	12236	14048	2711	2151	
(C) Actual data of 28.11.23 (Yesterday) Tuesday :														
01.	Max. Demand at eve. peak (Generation end)	:	10847	MW, at =	18:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	10745	MW, at =	18:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed	
03.	Highest Generation (Generation end)	:	10847	MW, at =	18:00 hrs	MW	MW	MW	MW	MW	MW	MW	MW	
04.	Minimum Generation (Generation end)	:	7508	MW, at =	5:00 hrs	Dhaka	4343	4343	0	Mymensingh	813	813	0	
05.	Day-peak Generation (Generation end)	:	9651	MW, at =	12:00 hrs	Chattogram	1089	1089	0	Sylhet	385	385	0	
06.	Evening-peak Generation (Generation end)	:	10847	MW, at =	18:00 hrs	Khulna	1182	1182	0	Barishal	286	286	0	
07.	Evening Peak Load-shed (Sub-station end)	:	0	MW, at =	18:00 hrs	Rajshahi	1002	1002	0	Rangpur	727	727	0	
08.	Minimum Generation Forecast up to 8:00 hrs.	:	7400	MW, at =	5:00 hrs	Cumilla	918	918	0					
09.	Generation shortfall at evening peak due to :	:				Total						10745	10745	0
a)	Gas/LF limitation	:	2522	MW		(a) Gas = 109101489 Taka						(c) Coal = 556624780 Taka		
d)	Coal supply Limitation	:	189	MW		(b) Oil = 150057350 Taka						Total = 815783619 Taka		
b)	Low water level in Kaptai lake	:	0	MW		Maximum Temperature in Dhaka was :						32.5°C		
c)	Plants under shut down/ maintenance	:	2151	MW		Export through East-West interconnections :								
10.	Total Energy (Generation + India Import)	:	220.22	MKWh		At evening peak-hour	:	9651	MW, at	18:00 hrs				
	By Gas = 106.625 MKWh			By Oil = 11.402 MKWh		Maximum	:	194	MW, at	8:00 hrs				
	By Coal = 81.718 MKWh			By Hydro = 2.077 MKWh		Energy	:	0	MKWh					
11.	Total Gas Supplied	:	823.27	MMCFD										
(D) Forecast of 29.11.23 (Today) Wednesday :														
01.	Maximum Demand	:	11000	MW	(Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)			
02.	Maximum Generation	:	14048	MW	(Generation end)	05.	Total Generation	:	223.33	MKWh				
03.	Reserve / Shortage	:	3048	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	:	32.5°C					

#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation