

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 8564667, 9551095

Month November, 2023					Day : Thursday					Date : 30.11.23				
Probable Maximum Demand : 11000 MW					Probable Maximum Generation : 13713 MW									
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 98.22 ft		Today = 98.10 ft		Rule Curve = 106.10 ft					
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	29.11.23 (Yesterday)		30.11.23 (Today)		29.11.23 (Yesterday)		Status of Machines under shut-down/ Maintenance			
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/Oil/Water Limitation MW		Machines shut down (MW)		Description/ Remarks	
					Day	Evening	Day	Evening			Probable start-up date			
(A) Plants in operation:														
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work		
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage		
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180						
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		365	Awaiting for HGPI		
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	75	75	75	75					
5	Tongi 80 MW GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage		
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0					
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	181	202	300	300	158		Gas Shortage		
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225	225		Gas Shortage		
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling		
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	377	372	412	412					
11	Siddhirgonj 2*120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage		
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	217	247	250	250	88		Gas Shortage		
13	Meghnaghat 335MW CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0	335		Gas Shortage		
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	20	55	55					
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	103	8	100	100					
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	10	16	15	15					
17	Summit Power,Madhabdi-Ashulia	Gas (SIPP, REB)	6x3.57+7x8.73	80	80	39	39	38	38					
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	33	33					
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	32	30	33	33					
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	17	8	25					
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	52	105	30	105					
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	48	48	48	48					
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	17	54	17					
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	95	80	130					
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	35	61	35	100					
26	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	35	0	35					
27	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	35	0	35					
28	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	0	29	26	72					
29	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	0	17	35	54					
30	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	12	0	35	0					
31	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	34	17	17					
32	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	0	19	90	90					
33	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	0	14	90	90					
34	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	34	85	85					
35	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	0	30	40					
36	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0					
	Meghnaghat Unique Power	Gas			0	0	0	0	0					
	Meghnaghat 589 MW CCPP(Summit)	Gas			0	0	0	0	0					
Dhaka Zone Total					5655	5422	1619	1999	2380	2659	1301	740		
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	86	86	86	86					
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage		
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.		
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	2	0	5	0					
40	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	8	8	17					
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	14	0	20	0					
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	19	6	19					
43	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	17	17	17					
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.		
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	190	191	212	215					
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	0	60	300	300					
47	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	0	12	12	12					
48	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	17	0	17					
49	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	56	80	80					
50	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	12	11	12	12					
	* Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			0	0	10	20					
51	Chattogram 108 MW PP (EGPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0					
52	Sikalbaha 54 MW PP (Jodiad Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	36	17	17					
53	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	17	17	17					
54	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	0	0	12	12					
55	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	0	12	12	12					
56	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	17	17	17	17					
57	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	0	0	0	0					
58	Chattogram 2*612MW Coal Based PP (SS Powe	Coal (IPP)	2x612	1224	1224	465	480	500	500					
	Metarbari 2*600 MW (CPGCL)	Coal				272	273	390	180			Test run		
	Cox's Bazar Wind PP	(Wind) (IPP)				2	4	10	10			Test run		
Chattogram Zone Total					3829	3769	1094	1316	1743	1560	180	330		
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	44	41	47	47					
60	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	0	0	0	0		221	Under Maint.		
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	0	0	0	0		360	Under Maint.		
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	305	310	320	320					
63	Ashuganj 420 MW CCPP(East)	Gas (APSCCL)	1x284+1x116	400	400	393	393	300	380					
64	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*116	195	195	73	73	73	73					
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	45	51	51					
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	70	150	150					
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	20					
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0		163	Under maint.		
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	20	105	17	17					
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	18	18	18					
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	10	10	11	11					
72	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	25	33	33	33					
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	8	52	52					
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	8	8	10	10					
75	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	17	114	114					
76	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	0	34	28	55					
77	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	0	17	17	17					
78	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	3	36	17	54					
79	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	0	43	40	40	46					
**	Import (Tripura)	India		160	160	108	122	128	140					
Cumilla Zone Total					2959	2896	1101	1380	1426	1608	0	744		
80	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	34	33	80	80	169		Gas Shortage		
81	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0					
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	24	66	56	85					
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	56	105	84	100					
84	Saishatabi 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0					
85	Sutiakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	23	0	50	0					
86	Tangail 22 MW PP(PPLG)	HFO (IPP)	4x6.7	22	22	0	6	6	6					
Mymensingh Zone Total					622	614	138	210	278	271	169	0		

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	29.11.23 (Yesterday)		30.11.23 (Today)		29.11.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date
						Day	Evening	Day	Evening				
87	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	OT-1 Under maint.	
88	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	28	28	28	28		62	OT-4 Under maint.	
89	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	0	0	0	0	51		Gas Shortage	
90	Kushara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0	163		Gas Shortage	
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	7	7	8	8				
92	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	0	0	0	0	66		Gas Shortage	
93	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	80	84	60	80				
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	200	197	200	200				
96	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	17	17	17	17				
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	16	16	16	9		Gas Shortage	
99	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	285	275	280	300				
100	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	402	401	400	400				
101	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	400	400	400	400				
102	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0	100		Under project work	
103	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	0	0	0	0	50		Gas Shortage	
Sylhet Zone Total						2472	2427	1480	1478	1462	1502	339	519
104	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
105	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0			Gas Shortage	
106	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	0	50			
107	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	0	70			
108	Khulna 225 MW CCPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0				
109	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	17	90	90				
110	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	0				
111	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	55	0	100	0				
112	Khulna 115 MW PP (KPCCL-2)	HFO (NENP)	7x17	115	115	0	16	32	48				
113	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8	40	40	0	0	0	0	16			
114	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIPCL)	1x617	617	617	404	600	620	620				
115	Khulna 330 MW CCPP (GT)	Gas/HSD (BIPCL)	1x220+1x116	336	336	0	0	0	0				
**	Bheramara (HVCDC) India			1000	1000	909	717	928	928				
Khulna Zone Total						3241	3237	1368	1350	1770	1822	0	0
116	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	16	110				
117	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	15	19	21	25				
118	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	130	0	130	130				
119	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	750	1060	1000	1220				
120	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	150				
121	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	150	200	200	200				
122	Bhola 220MW CCPP (Nutan Bidyt BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	220	220	220				
Barishal Zone Total						2265	2265	1265	1499	1587	2055	0	0
123	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
124	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Under maint.	
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	0	0	30			
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0				
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	0	20			
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	0	40	85				
129	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	30	40				
129	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	34	42				
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	0	38			
131	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	140	140	0	0	70		Gas Shortage	
132	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	0	0	0	0	220		Gas Shortage	
133	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0	220		Gas Shortage	
134	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	382	246	300	414	168		Gas Shortage	
135	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
136	Natore 52 MW PP (Rajalanka)	HFO (IPP)	6x8.92	52	52	0	0	52	52				
137	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	45	35	113				
138	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	24	35	70				
139	Aminura 50 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	0	0	28	28				
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	2	0	6	0				
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	597	813	748	900				
Raishahi Zone Total						3653	3631	1132	1279	1319	1843	749	100
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
141	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Under Overhauling	
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	170	170	170	170	104		Coal Shortage	
143	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	0	70	40	113				
145	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
146	Majpara, Tabula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	6	0	8	0				
147	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	35	70	110				
148	Lalmohona 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	27	0	30	0				
149	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	168	0	130	0				
Rangpur Zone Total						1030	950	371	275	448	393	189	85
Sub-total: Plants in operation						25726	25211	9568.0	10786	12413	13713	2927	2518
(B) Plants under long term maintenance/ contract expired													
150	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
151	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
152	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	0	0	0	0	0				
Sub-total: Plants under long term maintenance/ contract expired						225	0	0	0	0	0	0	0
Gross Total						25951	25211	9568	10786	12413	13713	2927	2518
(C) Actual data of 29.11.23 (Yesterday) Wednesday :													
01.	Max. Demand at eve. peak (Generation end)	:	10786 MW, at =	18:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :								
02.	Max. Demand at eve. peak (Sub-station end)	:	10576 MW, at =	18:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW	
03.	Highest Generation (Generation end)	:	10786 MW, at =	18:00 hrs	Dhaka	4237	4237	0	Mymensingh	784	784	0	
04.	Minimum Generation (Generation end)	:	7400 MW, at =	5:00 hrs	Chattogram	1195	1195	0	Sylhet	386	386	0	
05.	Day-peak Generation (Generation end)	:	9568 MW, at =	12:00 hrs	Khulna	1143	1143	0	Barisal	274	274	0	
06.	Evening-peak Generation (Generation end)	:	10786 MW, at =	18:00 hrs	Rajshahi	964	964	0	Rangpur	708	708	0	
07.	Evening Peak Load-shed (Sub-station end)	:	0 MW, at =	18:00 hrs	Cumilla	884	884	0					
08.	Minimum Generation Forecast up to 8:00 hrs.	:	7398 MW, at =	5:00 hrs					Total	10576	10576	0	
09.	Generation shortfall at evening peak due to :	:							(a) Gas =	111709637 Taka	(c) Coal =	497607393 Taka	
a) Gas/LF limitation	:	2738 MW							(b) Oil =	128578758 Taka	Total =	737895788 Taka	
d) Coal supply Limitation	:	189 MW											
b) Low water level in Kaptai lake	:	0 MW											
c) Plants under shut down/ maintenance	:	2518 MW											
10.	Total Energy (Generation + India Import)	:	220.22 MKWh										
	By Gas =	110.958 MKWh	By Oil =	9.388 MKWh									
	By Coal =	73.407 MKWh	By Hydro =	1.882 MKWh									
	By Solar =	1.858 MKWh											
11.	Total Gas Supplied	:	813.46 MMCFD										
(D) Forecast of 30.11.23 (Today) Thursday :													
01.	Maximum Demand	:	11000 MW (Generation end)		04.	Maximum Load-shed	:	0 MW	At evening peak (Sub-station end)				
02.	Maximum Generation	:	13713 MW (Generation end)		05.	Total Generation	:	224.59 MKWh					
03.	Reserve / Shortage	:	2713 MW (Generation end)		06.	Probable Max. Temperature in Dhaka	:	29.2°C					

#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation