

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 8564667, 9551095

Month December, 2023				Day : Saturday				Date : 02.12.23				
Probable Maximum Demand : 10500 MW				Probable Maximum Generation : 13655 MW								
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 97.98 ft	Today = 97.83 ft			Rule Curve = 105.91 ft				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	01.12.23 (Yesterday)		02.12.23 (Today)		01.12.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)		
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180				
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Awaiting for HGI	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	71	75	75	75			
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0			
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	0	0	0	0	360	Gas Shortage	
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	400	450	0	Gas Shortage	
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	399	400	412	412			
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage	
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	331	330	335	335	5	Gas Shortage	
13	Meghnaghat 335MW CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0	335	Gas Shortage	
14	Madangari-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	15	55	55			
15	Gagragar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	0	0	100	100			
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	13	13	15	15			
17	Summit Power(Madhabdi-Ashulia)	Gas (SIPP, REB)	6x3.57+7x8.73	80	80	27	35	38	38			
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	33	33			
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	32	32	33	33			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	0	8	25			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	0	34	30	105			
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	0	0	48	48			
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	17	54	17			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	0	80	130			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	0	24	36	100			
26	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	35	0	55			
27	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	35	0	35			
28	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	0	0	26	72			
29	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	0	35	35	54			
30	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	31	0	35	0			
31	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	17	17	35			
32	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	0	0	90	90			
33	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	0	0	90	90			
34	Madangari 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	17	85	85			
35	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	0	30	40			
36	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			
	Meghnaghat Unique Power	Gas			0	0	0	0	0			
	Meghnaghat 589 MW CCPP(Summit)	Gas			0	0	0	0	0			
Dhaka Zone Total				5655	5422	1559	1769	2340	2707	1195	740	
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	86	86	86	86			
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0			
40	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	0	8	17			
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	19	0	20	0			
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	6	6	19			
43	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	0	17	17	17			
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	190	192	200	200			
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	0	30	300	300			
47	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	0	0	12	12			
48	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	0	0	17			
49	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	80	80			
50	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	11	9	12	12			
	* Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			21	30	10	20			
51	Chattogram 108 MW PP (EGPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0			
52	Sikalbaha 54 MW PP (Jodiad Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	35	17	17			
53	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	0	17	17	17			
54	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	0	0	12	12			
55	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	0	12	12	12			
56	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	0	17	17	17			
57	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	0	0	0	0			
58	Chattogram 2*612MW Coal Based PP (SS Powe	Coal (IPP)	2x612	1224	1224	345	482	500	500			
	Metarbari 2*600 MW (CPGCL)	Coal				0	0	0	540		Test run	
	Cox's Bazar Wind PP	(Wind) (IPP)				0	0	10	10		Test run	
Chattogram Zone Total				3829	3769	676	933	1341	1905	180	330	
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	44	44	47	47			
60	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1x75	221	221	0	0	0	0	221	Under Maint.	
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	0	0	0	0	360	Under Maint.	
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	310	310	320	320			
63	Ashuganj 420 MW CCPP(East)	Gas (APSCCL)	1x284+1x116	400	400	370	393	400	400			
64	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*116	195	195	130	158	100	100			
65	Ashuganj 51 MW PP (Midland)	Gas (APSCCL)	6x9.34	51	51	24	51	51	51			
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	40	150	150			
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	20			
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163	Under maint.	
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	216	130	160	160			
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	10	18	18	18			
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	0	11	11	11			
72	Jangalia 33 MW PP (Summit))	Gas (SIPP, PDB)	4x8.73	33	33	14	25	33	33			
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	0	52	52			
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	10	6	10	10			
75	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	0	114	114			
76	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	0	38	28	55			
77	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	0	0	17	17			
78	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	0	38	17	54			
79	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	0	46	46	40	46			
**	Import (Tirupura)	India		160	160	100	106	128	140			
Cumilla Zone Total				2959	2896	1274	1414	1696	1798	0	744	
80	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	63	87	70	80	115	Gas Shortage	
81	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0			
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	0	32	56	85			
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	16	93	84	100			
84	Saishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
85	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	46	0	50	0			
86	Tangail 22 MW PP(PPLG)	HFO (IPP)	4x6.7	22	22	0	0	6	6			
Mymensingh Zone Total				622	614	127	212	268	271	115	0	

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	01.12.23 (Yesterday)		02.12.23 (Today)		01.12.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	Machines shut down (MW)	Machines shut down (MW)		
87	Fenchuganj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	OT-1 Under maint.
88	Fenchuganj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	26	28	28	28		62	OT-4 Under maint.
89	Fenchuganj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	25	25	25	25	26		Gas Shortage
90	Kushara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0	163		Gas Shortage
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8			Gas Shortage
92	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	0	0	0	0	66		Gas Shortage
93	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0	330		Under maint.
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	40	40	60	80			
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	124	128	128	128			
96	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	17	17			
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10			
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16	9		Gas Shortage
99	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	295	290	300	300			
100	Bibiana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	366	367	400	400			
101	Bibiana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	400	400	400	400			
102	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0	100		Under project work
103	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	22	25	20	35	25		Gas Shortage
Sylhet Zone Total					2472	2427	1375	1455	1490	289	519	
104	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0			
105	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0			Gas Shortage
106	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	50			
107	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	70			
108	Khulna 225 MW CCPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0			
109	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	17	90	90			
110	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	0			
111	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	79	0	100	0			
112	Khulna 115 MW PP (KPCCL-2)	HFO (NENP)	7x17	115	115	0	0	32	48			
113	Nospara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	0	0	15			
114	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIPCL)	1x617	617	617	452	522	620	620			
115	Khulna 330 MW CCPP (GT)	Gas/HSD (BIPCL)	1x220+1x116	336	336	0	0	0	0			
**	Bheramara (HVCDC)	India		1000	1000	918	625	449	449			
Khulna Zone Total					3241	3237	1449	1164	1291	1343	0	0
116	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	16	110			
117	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	12	18	21	25			
118	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	130	133	130	130			
119	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	580	1990	1000	1220			
120	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	150			
121	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	150	170	200	200			
122	Bhola 220MW CCPP (Nutan Bidyt BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	220	220	220			
Barisal Zone Total					2265	2265	1092	1631	1587	2055	0	0
123	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage
124	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Under maint.
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	0	30			
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0			
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	20			
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	0	40	85			
129	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	30	40			
130	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	34	42			
131	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	38			
132	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage
133	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	0	0	0	0	220		Gas Shortage
134	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0	220		Gas Shortage
135	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	350	400	414	414	14		Gas Shortage
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11			
137	Natore 52 MW PP (Rajalanka)	HFO (IPP)	6x8.92	52	52	0	0	52	52			
138	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	50	113	113			
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	35	35	70			
140	Aminura 30 MW PP (Sinha)	HFO (NENP)	7x7.79	50	28	0	0	28	28			
141	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0			
**	Adani Power, Jharkhand Ltd	(Import)	2x748	1496	0	0	0	0	750			
Rajshahi Zone Total					3653	3631	366	496	763	1693	735	100
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage
143	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Under Overhauling
144	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	170	170	170	170	104		Coal Shortage
145	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
146	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	0	34	40	113			
147	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
148	Majpara, Tabula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	4	0	8	0			
149	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	0	70	110			
150	Lalmohithal 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	34	0	30	0			
151	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	180	0	130	0			
Rangpur Zone Total					1030	950	388	204	448	393	189	85
Sub-total: Plants in operation					25726	25211	8306.0	9203	11189	13655	2703	2518
(B) Plants under long term maintenance/ contract expired												
152	Jamalpur 95 MW PP (Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			
153	Bosila 108MW PP (C)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			
154	Bosila 22 MW PP (GBS)	Gas (RPP)	6x4.0	22	0	0	0	0	0			
Sub-total: Plants under long term maintenance/ contract expired					225	0	0	0	0	0	0	0
Gross Total					25951	25211	8306	9203	11189	13655	2703	2518
(C) Actual data of 01.12.23 (Yesterday) Friday :												
01.	Max. Demand at eve. peak (Generation end)	:	9203 MW, at =	19:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	8805 MW, at =	19:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	9203 MW, at =	19:00 hrs	Dhaka	3202	3202	0	Mymensingh	694	694	0
04.	Minimum Generation (Generation end)	:	7361 MW, at =	9:00 hrs	Chattogram	1005	1005	0	Sylhet	350	350	0
05.	Day-peak Generation (Generation end)	:	8306 MW, at =	12:00 hrs	Khulna	1020	1020	0	Barisal	269	269	0
06.	Evening-peak Generation (Generation end)	:	9203 MW, at =	19:00 hrs	Rajshahi	870	870	0	Rangpur	575	575	0
07.	Evening Peak Load-shed (Sub-station end)	:	0 MW, at =	19:00 hrs	Cumilla	820	820	0				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	6874 MW, at =	5:00 hrs								
09.	Generation shortfall at evening peak due to :	:							Total	8805	8805	0
a)	Gas/LF limitation	:	2514 MW		13.	Fuel cost :	(a) Gas = 112284586 Taka	(c) Coal = 393612769 Taka				
d)	Coal supply Limitation	:	189 MW			(b) Oil = 76532057 Taka	Total = 582429412 Taka					
b)	Low water level in Kaptai lake	:	0 MW		14.	Maximum Temperature in Dhaka was :	31.7°C					
c)	Plants under shut down/ maintenance	:	2518 MW		15.	Export through East-West interconnections :						
10.	Total Energy (Generation + India Import)	:	198.18 MKWh			At evening peak-hour	:	8306 MW, at	19:00 hrs			
	By Gas = 111.473 MKWh					Maximum	:	320 MW, at	19:00 hrs			
	By Coal = 54.182 MKWh					Energy	:	0 MKWh				
	By Solar = 2.414 MKWh											
11.	Total Gas Supplied	:	824.28 MMCFD									
(D) Forecast of 02.12.23 (Today) Saturday :												
01.	Maximum Demand	:	10500 MW (Generation end)		04.	Maximum Load-shed	:	0 MW	At evening peak (Sub-station end)			
02.	Maximum Generation	:	13655 MW (Generation end)		05.	Total Generation	:	226.12 MKWh				
03.	Reserve / Shortage	:	3155 MW (Generation end)		06.	Probable Max. Temperature in Dhaka :	:	31.7°C				

#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation