

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month December, 2023				Day : Sunday				Date : 03.12.23				
Probable Maximum Demand : 10900 MW				Probable Maximum Generation : 13550 MW								
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 97.83 ft.		Today = 97.67 ft.		Rule Curve = 105.91 ft.				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Dered/ Present Capacity (MW)	02.12.23 (Yesterday)		03.12.23 (Today)		02.12.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
					Day	Evening	Day	Evening	Gas/Coal/Oil/Water Limitation MW	Machines shut down (MW)		Description/ Remarks
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180			
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Awaiting for HGPI	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	73	72	70	72			
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0			
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	0	0	0	0	360	Gas Shortage	
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	390	390	400	450	60	Gas Shortage	
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	404	357	350	360			
11	Siddhirganj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage	
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	271	277	275	280	58	Gas Shortage	
13	Meghnaghat 335MW CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0	335	Gas Shortage	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	13	25	55	55			
15	Gagragar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	0	0	100	100			
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	13	15	15			
17	Summit Power (Madhabdi-Ashulia)	Gas (SIPP, REB)	6x3.87+7x4.73	80	80	35	30	38	38			
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	6x4.73	33	33	0	0	33	33			
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	6x4.73	33	33	0	0	33	33			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	17	8	16			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	34	105	30	105			
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	48	48	48	48			
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	17	17	35			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	16	55	80	300			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	35	46	36	80			
26	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	35	0	55			
27	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	9	17	0	35			
28	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	4	27	26	52			
29	Manikganj 162MW PPMPL	HFO (IPP)	9x18	162	162	17	54	35	54			
30	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	27	0	35	0			
31	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	17	17	35			
32	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	0	0	90	90			
33	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	0	0	90	90			
34	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	20	0	85	85			
35	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	0	30	40			
36	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			
	Meghnaghat Unique Power	Gas			0	0	0	0	0			
	Meghnaghat 589 MW CCPP(Summit)	Gas			0	0	0	0	0			
Dhaka Zone Total				5655	5422	1601	1782	2176	2736	1308	740	
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	86	86	86	86			
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	2	0	5	0			
40	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	0	8	17			
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	11	0	20	0			
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	17	6	19			
43	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	2	17	17	17			
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	193	192	200	200			
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	30	115	200	260			
47	Juldah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	0	0	12	12			
48	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	17	0	17			
49	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	80	80			
50	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	13	13	12	12			
	* Malancha, Ctg.EPZ (United)	Gas	5x8.73+3x9.34			2	0	10	20			
51	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0			
52	Sikalbaha 54 MW PP (Jodiak Power)	HFO (IPP)	3x18.55+1x3.6	54	54	8	36	17	36			
53	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	17	17	17			
54	Juldah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	0	0	12	12			
55	Juldah 100 MW Unit-1 (Acorn)	HFO (QRPP)	8x13.45	100	100	12	0	12	12			
56	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	17	17	17	17			
57	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	6	17	0	0			
58	Chattogram 2*612MW Coal Based PP (SS Power)	Coal (IPP)	2x612	1224	1224	492	491	500	500			
	Matlabari 2*600 MW (CPGCL)	Coal				133	505	500	420		Test run	
	Cox's Bazar Wind PP	(Wind) (IPP)				0	4	10	10		Test run	
Chattogram Zone Total				3829	3769	1024	1544	1741	1764	180	330	
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	41	41	47	47			
60	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	0	0	0	0	221	Under Maint.	
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	0	0	0	0	360	Under Maint.	
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	330	310	320	320			
63	Ashuganj 420 MW CCPP(East)	Gas (APSCCL)	1x284+1x116	400	400	393	393	400	400			
64	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*16	195	195	83	170	100	100			
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	51	51	51			
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	26	92	150	150			
67	Titlas 50 MW Peaking PP	HFO (PDB)	6x6.92	52	52	0	0	0	20			
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163	Under maint.	
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	11	100	150			
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	18	18	18			
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	5	8	11	11			
72	Jangalia 33 MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	25	33	33	33			
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	14	52	52			
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	10	10	10	10			
75	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	17	114	114			
76	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	27	42	28	60			
77	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17			
78	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	18	51	17	54			
79	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	0	39	25	20	25			
**	Import (Tripura)	India		160	160	98	118	128	140			
Cumilla Zone Total				2959	2896	1190	1421	1616	1772	0	744	
80	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	69	68	60	70	134	Gas Shortage	
81	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0			
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	94	85	56	85			
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	18	93	84	100			
84	Saishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
85	Sutakhalai 50 MW Solar PP	Solar (IPP)	1x50	50	50	47	0	50	0			
86	Tangail 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	0	6	6	6			
Mymensingh Zone Total				622	614	230	252	258	261	134	0	

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	02.12.23 (Yesterday)		03.12.23 (Today)		02.12.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/Oil/Water Limitation MW			
						Day	Evening	Day	Evening	Machines shut down (MW)	Description/ Remarks	Probable start-up date	
87	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 Under maint.	
88	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	22	28	28	28		62	GT-4 Under maint.	
89	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	5	25	0	25	26	Gas Shortage		
90	Kushiera 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0	163	Gas Shortage		
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	3	3	8	8				
92	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	0	0	0	0	66	Gas Shortage		
93	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0	330	Under maint.		
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	40	40	60	60				
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	127	126	128	128				
96	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	0	0	17	17				
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	0	16	16	16	9	Gas Shortage		
99	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	310	290	300	300				
100	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	400	368	400	400				
101	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	392	400	400	400				
102	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0	100	Under project work		
103	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12'3+3*5'2	50	50	0	25	0	25	25	Gas Shortage		
Sylhet Zone Total				2472	2427	1352	1374	1410	1460	289	519		
104	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
105	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0		Gas Shortage		
106	Fardpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	50				
107	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	70				
108	Khulna 225 MW CCPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0				
109	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	0	0	90	90			
110	Machumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	0	0			
111	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	54	0	0	100	0			
112	Khulna 115 MW PP (KPCCL-2)	HFO (NENP)	7x17	115	115	0	0	32	48				
113	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5x8.5	40	40	0	0	0	8				
114	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	456	623	620	620				
115	Khulna 330 MW CCPP (GT)	Gas/HSD (BPDB)	1x220+1x116	336	336	0	0	0	0				
**	Bheramara (HVCDC)	India		1000	1000	437	443	449	449				
Khulna Zone Total				3241	3237	947	1066	1291	1335	0	0		
116	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	16	110				
117	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	11	16	21	25				
118	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	64	64	130	130				
119	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	1080	1210	1000	1220				
120	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	150				
121	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	150	286	200	300				
122	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	220	220	220				
Barishal Zone Total				2265	2265	1525	1796	1587	2155	0	0		
123	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71	Gas Shortage		
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100	Under maint.		
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	0	30				
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0				
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	20				
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	0	40	86				
128	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	30	40				
129	Katakali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	34	42				
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	38				
131	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210	Gas Shortage		
132	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	0	0	0	0	220	Gas Shortage		
133	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0	220	Gas Shortage		
134	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	414	306	414	414	108	Gas Shortage		
135	Ullapara 11 MW PP. (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
136	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	0	52	52				
137	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6x18.55	113	113	113	35	113	113				
138	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	35	20	50				
139	Aminura 50 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	0	0	28	28				
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	4	0	6	0				
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	0	739	600	750				
Raishahi Zone Total				3653	3631	542	1126	1348	1674	829	100		
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Coal Shortage		
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Under Overhauling		
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	170	170	170	170	104	Coal Shortage		
143	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	49	70	40	113				
145	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
146	Majpara, Tabula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	6	0	8	0				
147	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6x20	115	115	35	35	70	110				
148	Lalmorihat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	43	0	30	0				
149	Treesta Solar Limited	Solar (IPP)	1 x 200	200	200	119	0	130	0				
Rangpur Zone Total				1030	950	422	275	448	393	189	85		
Sub-total: Plants in operation				25726	25211	8833.0	10636	11875	13550	2929	2518		
(B) Plants under long term maintenance/ contract expired													
150	Jamshilpur 55 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
151	Bostila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
152	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	0	0	0	0	0				
Sub-Total: Plants under long term maintenance/ contract expired				225	0	0	0	0	0	0	0		
Gross Total				25951	25211	8833	10636	11875	13550	2929	2518		
(C) Actual data of 02.12.23 (Yesterday) Saturday :													
01.	Max. Demand at eve. peak (Generation end)	:	10636	MW, at =	18:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	10117	MW, at =	18:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	
03.	Highest Generation (Generation end)	:	10636	MW, at =	18:00 hrs	MW	MW	MW	MW	MW	MW	MW	
04.	Minimum Generation (Generation end)	:	6874	MW, at =	5:00 hrs	Dhaka	3797	3797	0	Myrmensingh	799	799	
05.	Day-peak Generation (Generation end)	:	8833	MW, at =	12:00 hrs	Chattogram	1151	1151	0	Sylhet	375	375	
06.	Evening-peak Generation (Generation end)	:	10636	MW, at =	18:00 hrs	Khulna	1173	1173	0	Barishal	277	277	
07.	Evening Peak Load-shed (Sub-station end)	:	0	MW, at =	18:00 hrs	Rajshahi	970	970	0	Rangpur	680	680	
08.	Minimum Generation Forecast up to 8:00 hrs.	:	7314	MW, at =	5:00 hrs	Cumilla	894	894	0				
09.	Generation shortfall at evening peak due to :	:				Total						0	
	a) Gas/LF limitation	:	2740	MW		13. Fuel cost : (a) Gas = 109741375 Taka (c) Coal = 455660839 Taka							
	d) Coal supply Limitation	:	189	MW		(b) Oil = 145485954 Taka Total = 710888169 Taka							
	b) Low water level in Kaptai lake	:	0	MW		14. Maximum Temperature in Dhaka was : 30.3°C							
	c) Plants under shut down/ maintenance	:	2518	MW		15. Export through East-West interconnections :							
10.	Total Energy (Generation + India Import)	:	202.25	MKWh		At evening peak-hour : 8833 MW, at 18:00 hrs							
	By Gas = 109.227 MKWh			By Oil = 10.931 MKWh		Maximum : 75 MW, at 11:00 hrs							
	By Coal = 62.984 MKWh			By Hydro = 2.064 MKWh		Energy : 0.396 MKWh							
	By Solar = 2.156 MKWh												
11.	Total Gas Supplied	:	806.73	MMCFD									
(D) Forecast of 03.12.23 (Today) Sunday :													
01.	Maximum Demand	:	10900	MW	(Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)		
02.	Maximum Generation	:	13550	MW	(Generation end)	05.	Total Generation	:	207.27	MKWh			
03.	Reserve / Shortage	:	2650	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	:	30.3°C				

*Gross Power Imported Power
#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helatur Rahman)
Deputy Secretary, Generation