

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 8564667, 9551095

Month December, 2023				Day : Wednesday				Date : 06.12.23					
Probable Maximum Demand : 11000 MW				Probable Maximum Generation : 12216 MW									
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 97.36 ft Today = 97.22 ft				Rule Curve = 105.55 ft					
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	05.12.23 (Yesterday)		06.12.23 (Today)		05.12.23 (Yesterday)		06.12.23 (Today)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW		Machines shut down (MW)		
					Day	Evening	Day	Evening	Description/ Remarks		Probable start-up date		
(A) Plants in operation:													
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260		Under project work
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180			Gas Shortage
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180					
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		365		Awaiting for H/GPI
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	70	73	74	74	38			Gas Shortage
5	Tong 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105			Gas Shortage
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0				
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	0	0	0	0	360			Gas Shortage
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450	0			Gas Shortage
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115		Under Overhauling
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	371	339	330	375				
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210			Gas Shortage
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	310	288	300	300	47			Gas Shortage
13	Meghnaghat 335MW CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0	335			Gas Shortage
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	18	55	55	55				
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	0	63	100	100				
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	10	15	15				
17	Summit Power(Madhabdi-Ashulia)	Gas (SIPP, REB)	6x3.57+7x8.73	80	80	35	34	38	38				
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	33	33				
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	26	26	33	33				
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	17	8	16				
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	35	105	52	105				
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	6	118	100	149				
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	17	17	17				
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	10	280	300	300				
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	35	67	35	60				
26	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	35	0	35				
27	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	35	0	35				
28	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	72	90	90				
29	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	54	17	18	54				
30	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	11	0	35	0				
31	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	35	17	35				
32	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	4	80	90	90				
33	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	0	40	92	92				
34	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	4	68	85	85				
35	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45	100	75	0	0	36	36				
36	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
	Meghnaghat Unique Power	Gas			0	0	0	0	0				
	Meghnaghat 589 MW CCPP(Summit)	Gas			0	0	0	0	0				
Dhaka Zone Total			5655	5422	1703	2529	2583	2852	1275	740			
37	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	86	86	86	86				
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180			Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180		Under maint.
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	2	0	5	0				
40	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	16	8	17				
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	11	0	20	0				
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	19	6	18				
43	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	17	17	17				
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150		Under maint.
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	179	194	190	190				
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	20	106	100	100				
47	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	0	0	0	0				
48	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	0	0	17				
49	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	40	50	65				
50	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	12	13	12	12				
	* Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			0	2	10	20				
51	Chattogram 108 MW PP (EGPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0				
52	Sikalbaha 54 MW PP(Jodiad Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	36	17	36				
53	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	17	17	17				
54	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	0	0	0	0				
55	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	12	12	12	12				
56	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	17	17	17	17				
57	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	163	163	35	33	150	150				
58	Chattogram 2*612MW Coal Based PP (SS Powe	Coal (IPP)	2x612	1224	1224	490	490	500	500				
	Matlabari 2*600 MW (CPGCL)	Coal				0	0	0	0				Test run
	Cox's Bazar Wind PP	(Wind) (IPP)				1	11	10	10				Test run
Chattogram Zone Total			3829	3769	905	1109	1227	1284	180	330			
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	34	47	47	47				
60	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	0	0	0	0		221		Under Maint.
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	265	295	300	300		65		Under Maint.
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	280	300	320	320				
63	Ashuganj 420 MW CCPP(East)	Gas (APSCCL)	1x284+1x116	400	400	320	230	390	390				
64	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*116	195	195	0	8	8	8				
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	51	51	51				
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	14	55	150	150				
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	20				
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0		163		Under maint.
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	100	20	200	200				
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	18	18	18				
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
72	Jangalia 33 MW PP (Summit))	Gas (SIPP, PDB)	4x8.73	33	33	25	33	33	33				
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	36	52	52				
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	10	8	10	10				
75	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.45+1*9.78	114	114	0	76	114	114				
76	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	27	47	28	55				
77	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	0	13	17	17				
78	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	18	40	17	53				
79	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	0	23	24	25	25				
**	Import (Tripura)	India		160	160	110	102	128	140				
Cumilla Zone Total			2959	2896	1298	1414	1919	2014	0	449			
80	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	34	35	75	50	167			Gas Shortage
81	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0				
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	9	28	8	25				
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	58	77	56	65				
84	Saishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0				
85	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	14	0	50	0				
86	Tangail 22 MW PP(PPLGL)	HFO (IPP)	4x6.7	22	22	0	6	6	6				
Mymensingh Zone Total			622	614	116	146	197	146	167	0			

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	05.12.23 (Yesterday)		06.12.23 (Today)		05.12.23 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW		Machines shut down (MW)	Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening					
87	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	OT-1 Under maint.	
88	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	27	28	28	28		62	OT-4 Under maint.	
89	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	25	25	25	25		26	Gas Shortage	
90	Kushara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0		163	Gas Shortage	
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	8	8	8				
92	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	19	59	60	60		7	Gas Shortage	
93	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	0	0	0	0				
95	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	158	164	163	163				
96	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0				
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	16	16	16		9	Gas Shortage	
99	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	315	290	300	300				
100	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	365	384	400	400				
101	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	310	400	400	400				
102	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
103	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	25	25	25	25		25	Gas Shortage	
Sylhet Zone Total					2472	2427	1310	1452	1478	1478	230	519	
104	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
105	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0			Gas Shortage	
106	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	45				
107	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	0				
108	Khulna 225 MW CCPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0				
109	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	0	90	90				
110	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	0				
111	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	23	0	100	0				
112	Khulna 115 MW PP (KPCCL-2)	HFO (NENP)	7x17	115	115	18	49	32	48				
113	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	8	0	16				
114	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIPCL)	1x617	617	617	380	375	370	370				
115	Khulna 330 MW CCPP (GT)	Gas/HSD (BPDB)	1x220+1x116	336	336	0	0	0	0				
**	Bheramara (HVCDC) India			1000	1000	438	428	449	449				
Khulna Zone Total					3241	3237	859	860	1041	1018	0	0	
116	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110				
117	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	15	19	21	25				
118	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	60	130	130	130				
119	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	1000	1244	622	622				
120	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	7	17	0	150				
121	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	140	140	140	140				
122	Bhola 220MW CCPP (Nutan Bidyt BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	222	220	220				
Barishal Zone Total					2265	2265	1442	1772	1243	1397	0	0	
123	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage	
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.	
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	0	30				
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0				
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	20				
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	0	40	86				
128	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	30	40				
129	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	42	34	42				
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	38				
131	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0		210	Gas Shortage	
132	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0		220	Gas Shortage	
133	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0		220	Gas Shortage	
134	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	256	246	414	414		168	Gas Shortage	
135	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
136	Natore 52 MW PP (Rajalanka)	HFO (IPP)	6x8.92	52	52	0	8	52	52				
137	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	35	55	35	70				
138	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6*18.55	113	113	35	50	35	55				
139	Aminura 50 MW PP(Sinha)	HFO (NENP)	7x7.79	50	28	0	0	28	28				
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	1	0	6	0				
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1496	758	760	748	748				
Rajshahi Zone Total					3653	3631	1096	1172	1433	1634	889	100	
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	170	170	170	170		104	Coal Shortage	
143	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	33	100	34	113				
145	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
146	Majpara, Tabula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	3	0	8	0				
147	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	114	70	110				
148	Lalmohithal 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	18	0	30	0				
149	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	86	0	130	0				
Rangpur Zone Total					1030	950	310	384	442	393	189	85	
Sub-total: Plants in operation					25726	25211	9039.0	10838	11563	12216	2930	2223	
(B) Plants under long term maintenance/ contract expired													
150	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
151	Bosilia 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
152	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	0	0	0	0	0				
Sub-total: Plants under long term maintenance/ contract expired					225	0	0	0	0	0	0	0	
Gross Total					25951	25211	9039	10838	11563	12216	2930	2223	
(C) Actual data of 05.12.23 (Yesterday) Tuesday :													
01.	Max. Demand at eve. peak (Generation end)	:	10838	MW, at =	18:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	10404	MW, at =	18:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	
03.	Highest Generation (Generation end)	:	10838	MW, at =	18:00 hrs	MW	MW	MW	MW	MW	MW	MW	
04.	Minimum Generation (Generation end)	:	7347	MW, at =	5:00 hrs	Dhaka	4122	4122	0	Mymensingh	782	782	
05.	Day-peak Generation (Generation end)	:	9039	MW, at =	12:00 hrs	Chattogram	1144	1144	0	Sylhet	374	374	
06.	Evening-peak Generation (Generation end)	:	10838	MW, at =	18:00 hrs	Khulna	1130	1130	0	Barisal	279	279	
07.	Evening Peak Load-shed (Sub-station end)	:	0	MW, at =	18:00 hrs	Rajshahi	968	968	0	Rangpur	715	715	
08.	Minimum Generation Forecast up to 8:00 hrs.	:	7309	MW, at =	5:00 hrs	Cumilla	891	891	0				
09.	Generation shortfall at evening peak due to :	:				Total						10404	
a)	Gas/LF limitation	:	2741	MW		(a) Gas = 110479281 Taka						50505705	
d)	Coal supply Limitation	:	189	MW		(b) Oil = 224925962 Taka						840460948	
b)	Low water level in Kaptai lake	:	0	MW		Total =							
c)	Plants under shut down/ maintenance	:	2223	MW		Maximum Temperature in Dhaka was : 27.1°C							
10.	Total Energy (Generation + India Import)	:	217.00	MKWh		15. Export through East-West interconnections :							
	By Gas = 108.310 MKWh			By Oil = 17.433 MKWh		At evening peak-hour :						9039	
	By Coal = 75.069 MKWh			By Hydro = 2.070 MKWh		Maximum :						140	
	By Solar= 0.962 MKWh					Energy :						0.198	
11.	Total Gas Supplied	:	814.00	MMCFD									
(D) Forecast of 06.12.23 (Today) Wednesday :													
01.	Maximum Demand	:	11000	MW	(Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)		
02.	Maximum Generation	:	12216	MW	(Generation end)	05.	Total Generation	:	220.24	MKWh			
03.	Reserve / Shortage	:	1216	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	:	30.3°C				

#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation